

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

BUILDINGS ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: Accounts Payable & IT Department
 814 Walnut Street
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 4/5/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
			Emergency lights are inoperable throughout building.*			X	

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

BUILDINGS ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: Food & Nutrition & Operations
 925 Center Street
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 4/6/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		Passed annual inspection.					

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

BUILDINGS ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: H.C. Long Administration
 23 Green Street
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 4/5/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		Passed annual inspection.					

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

BUILDINGS ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: Insurance & Payroll Department
 11 Green Street
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 4/6/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
			Emergency lights are inoperable.*			X	
			Fire extinguishers are mounted to high - no higher than 5 feet to top of extinguisher.*			X	

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58
BUILDINGS ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: Maintenance Department
 905 Center Street
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: _____

INSPECTION DATE: 4/6/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
	9		Emergency lights are inoperable.*			X	

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

BUILDINGS ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: Professional Development
 800 Walnut Street
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 4/6/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
			Fire extinguishers are a year expired.*			X	

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58
BUILDINGS ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: Purchasing Department
 800 Center Street
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 4/6/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		Passed annual inspection.					

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

BUILDINGS ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: Superintendents Office
 900 Walnut Street
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 
 INSPECTION DATE: 4/5/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		Emergency light inoperable in hallway outside room 31.*				X	

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

PORTABLES ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: Green Cove Springs Transportation
 800 Center Street
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: _____

INSPECTION DATE: 5/23/2021

Room	DCA Prefix	DCA Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
12	MB E	001866	Portable not found.					
12A	MB E	001866						
12B	MB E	001866						
12C	MB E	001866						
12D	MB E	001866						
12E	MB E	001866						
12F	MB E	001866						
12G	MB E	001866						
12H	MB E	001866						
12J	MB E	001866						
12K	MB E	001866						
12L	MB E	001866						
12M	MB E	001866						
2	II-B	007455						
2A	II-B	007455						
Total Portables: 1								

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

BUILDINGS ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: Middleburg Transportation
 3674 County Road 220
 Middleburg, FL 32068

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/24/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		Passed annual inspection.					

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

PORTABLES ONLY

FISCAL YEAR: 2020/21
 DISTRICT: CLAY
 FACILITY: Keystone Transportation
 6842 County Road 315C
 Keystone Heights, FL 32656

INSPECTOR SIGNATURE: _____

INSPECTION DATE: 5/29/2021

Room	DCA Prefix	DCA Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
2	II-B	10964		Fire extinguisher not properly hung on wall. There must be an emergency evacuation map placed by door.				X
2A	II-B	10964						

Total Portables: 1