

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 12/6/2022 4:02:54 PM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00530 Name of Facility: Thunderbolt Elementary School Address: 2020 Thunderbolt Road City, Zip: Fleming Island 32003 Type: Public Schools Owner: Clay County School Board Person In Charge: Clay County School District Phone: 9043363675 PIC Email: jessica.eckels@myoneclay.net	Correct By: Next Inspection Re-Inspection Date: None
--	---

Inspection Information

Purpose: Routine Inspection Date: 12/5/2022	Begin Time: 11:34 AM End Time: 12:19 PM
--	--

Additional Information

FEMALES MALES	CENSUS 0
------------------------------	----------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION <u>IN</u> 1. School Site <u>IN</u> 2. Playground, Equip & Athletic Fields* <u>IN</u> 3. Athletic & Playground Equipment BUILDING CONST/MAINT. <u>IN</u> 4. Construction <u>IN</u> 5. Maintenance & Repair <u>IN</u> 6. Lighting Standards <u>IN</u> 7. Heating, Ventilation, A/C Standards <u>IN</u> 8. Natural Ventilation <u>IN</u> 9. Mechanical Ventilation SANITARY FACILITIES <u>IN</u> 10. Provided/Accessible/Separation	<u>IN</u> 11. Group Toilet Rooms <u>IN</u> 12. Toilet Facilities <u>IN</u> 13. Handwashing Facilities <u>IN</u> 14. Soap Dispensers <u>IN</u> 15. Shower Facilities <u>IN</u> 16. Showers Water Temperatures WATER SUPPLY <u>IN</u> 17. Approved Source <u>OUT</u> 18. Drinking Fountains LIQUID WASTE & WASTE WATER <u>IN</u> 19. Sewage Disposal <u>IN</u> 20. Solid Waste PEST CONTROL	<u>IN</u> 21. Pest Control SAFETY <u>IN</u> 22. First Aid Kit DIAPER CHANGING STATION <u>IN</u> 23. Sanitizers <u>IN</u> 24. Changing Station & Mats <u>IN</u> 25. Hand Sink <u>IN</u> 26. Garbage Can ANIMAL HEALTH & SAFETY <u>IN</u> 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES <u>IN</u> 28. Maintenance/Complaint <u>OUT</u> 29. Other
--	---	--

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 12/6/2022 4:02:54 PM ****

2 of 2

General Comments

from last inspection:

playground picnic table has been fixed
- no paper towels in bathrooms by portables and playground - corrected.
laptop batteries taped together in room 321 - corrected from last inspection

portable 701/703/741/739 - no violations found
ESE classroom 306 - no thermometer in fridge or freezer: reading at 40.3 by inspectors thermometer
ese classroom 304 - 38.6/0 - thermometers in both fridge and freezer
ese classroom 310 - 39 in fridge - no thermometer in freezer
classroom 316 - 40 in fridge - no thermometer in freezer
classroom 322 - no thermometer in fridge or freezer

classroom 121/113/105 - no violations found. classroom bathroom in good condition and clean

classroom 111 - water fountain pressure low

bathroom sink in 3rd grade corridor - far right sink not working - water running nonstop. water turned off. work order placed for few months. water fountain by gang bathrooms - out of order x2 weeks. work order placed.

Email Address(es): jessica.eckels@myoneclay.net

Violations Comments

Violation #18. Drinking Fountains

low water pressure in classroom 111

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Violation #29. Other

all ESE/IND classrooms need to have a thermometer in their fridge/freezer.

CODE REFERENCE: 29. Other. This applies to any other applicable state or local standards.

Inspection Conducted By: Morgan Palmer (884987)
Inspector Contact Number: Work: (904) 529-2924 ex.
Print Client Name:
Date: 12/5/2022

Inspector Signature:

Client Signature:

Form Number: DH 4030 12/16A

10-51-00530 Thunderbolt Elementary School

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 4

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00079
Name of Facility: Tynes Elementary School
Address: 1550 Tynes Boulevard
City, Zip: Middleburg 32068

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Clay County School Board Phone: (904) 284-6500
PIC Email:

Inspection Information

Purpose: Routine
Inspection Date: 5/22/2023

Begin Time: 12:17 PM
End Time: 01:30 PM

Additional Information

FEMALES 469
MALES 559

CENSUS 1028

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>OUT</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>OUT</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>NA</u> 15. Shower Facilities	<u>NA</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>NA</u> 16. Showers Water Temperatures	<u>NA</u> 24. Changing Station & Mats
<u>OUT</u> 5. Maintenance & Repair	WATER SUPPLY	<u>NA</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>NA</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>OUT</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>NA</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>IN</u> 20. Solid Waste	<u>NA</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>NA</u> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 4

General Comments

Correct the violations listed within prior to next inspection. Email Melissa.Johnson@FLHealth.gov when the violations listed within have been corrected and/or if you have any questions or concerns.

Satisfactory conditions at time of inspection.

Email Address(es): Sarah.Brennan@MyOneClay.Net;
Stephanie.Raucci@MyOneClay.Net

Inspector Signature:

Melissa Johnson

Client Signature:

[Handwritten Signature]

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 4

Violations Comments

Violation #5. Maintenance & Repair

One light bulb out in the girl's restroom within the library, within the art room, within Portable 62, within room 301, and within room 601. Correct prior to next inspection.

Multiple light bulbs out within Portable 28 and Portable 65. Correct prior to next inspection.

One missing light cover within Portable 41. Correct prior to next inspection.

One cracked and one missing light cover within Portable 10. Correct prior to next inspection.

Two cracked light covers within Portable 22. Correct prior to next inspection.

Signs of water damage on the ceiling of Portable 61. Correct prior to next inspection.

The face plate for one electrical outlet is missing within Portable 41. Correct prior to next inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

Wainscot tiles are missing near the paper towel dispenser and behind some toilets within the girl's restroom 73 and behind some toilets and near the entrance within boy's restroom 73. Correct prior to next inspection.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #13. Handwashing Facilities

Room 733 is missing paper towels. Correct prior to next inspection.

Room 527 is missing soap. Correct prior to next inspection.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

One inoperable drinking fountain near the cafeteria playground. Correct prior to next inspection.

The drinking fountains near Portable 45 are inoperable. Correct prior to next inspection.

Both of the drinking fountains located within each of the playgrounds near the portables are inoperable. Correct prior to next inspection.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



4 of 4

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Robert Johnson
Date: 5/22/2023

Inspector Signature:

Melissa Johnson

Client Signature:

Robert Johnson

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00080 Name of Facility: W E Cherry Elementary School Address: 420 Edson Drive City, Zip: Orange Park 32073 Type: Public Schools Owner: CLAY COUNTY SCHOOL BOARD Person In Charge: CLAY COUNTY SCHOOL BOARD Phone: (904) 284-6500 PIC Email: angela.whiddon@myoneclay.net	Correct By: Next Inspection Re-Inspection Date: None
---	---

Inspection Information

Purpose: Routine Inspection Date: 12/7/2022	Begin Time: 10:04 AM End Time: 10:47 AM
--	--

Additional Information

FEMALES MALES	CENSUS 677
------------------------------	------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION <u>IN</u> 1. School Site <u>IN</u> 2. Playground, Equip & Athletic Fields* <u>IN</u> 3. Athletic & Playground Equipment BUILDING CONST/MAINT. <u>IN</u> 4. Construction <u>IN</u> 5. Maintenance & Repair <u>IN</u> 6. Lighting Standards <u>IN</u> 7. Heating, Ventilation, A/C Standards <u>IN</u> 8. Natural Ventilation <u>IN</u> 9. Mechanical Ventilation SANITARY FACILITIES <u>IN</u> 10. Provided/Accessible/Separation	<u>IN</u> 11. Group Toilet Rooms <u>OUT</u> 12. Toilet Facilities <u>IN</u> 13. Handwashing Facilities <u>IN</u> 14. Soap Dispensers <u>NA</u> 15. Shower Facilities <u>NA</u> 16. Showers Water Temperatures WATER SUPPLY <u>IN</u> 17. Approved Source <u>OUT</u> 18. Drinking Fountains LIQUID WASTE & WASTE WATER <u>IN</u> 19. Sewage Disposal <u>IN</u> 20. Solid Waste PEST CONTROL	<u>IN</u> 21. Pest Control SAFETY <u>IN</u> 22. First Aid Kit DIAPER CHANGING STATION <u>NA</u> 23. Sanitizers <u>NA</u> 24. Changing Station & Mats <u>NA</u> 25. Hand Sink <u>NA</u> 26. Garbage Can ANIMAL HEALTH & SAFETY <u>NA</u> 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES <u>NA</u> 28. Maintenance/Complaint <u>IN</u> 29. Other
--	--	---

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

gang bathrooms - supplied appropriately with paper towels, soap, and running water - major plumbing issues all over campus. flushing issues and water flow/pressure in sinks and water fountains. 6th grade wing girls gang bathroom leaking into downstairs bathroom. hole in bottom part of wall in boys gang bathroom leftover from replacing a urinal. works orders placed in January - still waiting for Plumbers to come out and complete work orders.
P49 - all lights working, all ceilings and floors in good condition
P39 - all lights working, all ceilings and floors in good condition
P70 - walls ceilings and floors in good condition.
P67 - walls ceilings and floors in good condition. bathroom properly supplied with paper towels, soap, and running water.

Email Address(es): angela.whiddon@myoneclay.net;
Matthew.pierce@myoneclay.net;
Stephanie.Raucci@myoneclay.net

Violations Comments

Violation #12. Toilet Facilities
90% of gang bathrooms have 1 stall or urinal out of order due to plumbing issues. 6th grade wing girls gang bathroom (upstairs) leaking into downstairs bathroom. Hole in lower half of wall under urinal in boys gang bathroom left from replacing urinal that was clogged. Middle faucet in downstairs girls gang bathroom rusted and leaking.
CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #18. Drinking Fountains
Many drinking fountains around campus had flow that was not strong enough to drink from
CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Morgan Palmer (884987)
Inspector Contact Number: Work: (904) 529-2924 ex.
Print Client Name:
Date: 12/7/2022

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00041 Name of Facility: Wilkinson Elementary Address: 4965 County Road 218 W City, Zip: Middleburg 32068 Type: Public Schools Owner: Clay County School Board Person In Charge: Clay County School Board Phone: (904) 284-6500 PIC Email:	Correct By: Next Inspection Re-Inspection Date: None
--	---

Inspection Information

Purpose: Routine Inspection Date: 5/23/2023	Begin Time: 12:25 PM End Time: 01:09 PM
--	--

Additional Information

FEMALES 368 MALES 360	CENSUS 728
--------------------------------------	------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers NA 15. Shower Facilities NA 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other
---	--	--

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Email Melissa.Johnson@FLHealth.gov when the violations listed within have been corrected.

Email Address(es): Cassandra.Hall@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

There is one light out within the library. Correct prior to next inspection.

There are four lights out within Portable 45. Correct prior to next inspection.

There is evidence of water damage on the ceiling within Portable 17. Correct prior to next inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Cassandra Hall
Date: 5/23/2023

Inspector Signature:

Handwritten signature of Melissa Johnson.

Client Signature:

Handwritten signature of the client, Cassandra Hall.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 3/29/2023 1:17:48 PM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00729 Name of Facility: Lake Asbury Junior High Address: 2851 Sandridge Road City, Zip: Green Cove Springs 32043 Type: Public Schools Owner: Clay County School Board Person In Charge: Clay County School Board Phone: (904) 284-6500 PIC Email: joyce.aldridge@myoneclay.net	Correct By: None Re-Inspection Date: None
---	--

Inspection Information

Purpose: Routine Inspection Date: 3/28/2023	Begin Time: 11:05 AM End Time: 11:39 AM
--	--

Additional Information

FEMALES 552 MALES 542	CENSUS 1094
--------------------------------------	-------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction IN 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY IN 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other
--	--	--

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 3/29/2023 1:17:48 PM ****

2 of 2

General Comments

all items satisfactory at time of inspection
all gang bathrooms clean and in good condition - all bathrooms supplied with running water, soap, and paper towels
all water fountains clean and in working condition
all classrooms clean and in good condition with proper lighting.
all staff bathrooms clean and in good condition - properly stocked with soap, running water, and paper towels
ESE classroom thermometer 32 fridge, 8 freezer.
portable 404 - proper lighting, in good condition
portable 393 - proper lighting, clean and in good condition
building 8 - clean and in good repair, all water fountains working properly, all floors and walls in good condition
showers in lockers room in good condition - hot water provided to showers
art room kiln being used appropriately
Inspection conducted with Joyce - head custodian

Email Address(es): joyce.aldridge@myoneclay.net

Violations Comments

No Violation Comments Available

Inspection Conducted By: Morgan Palmer (884987)
Inspector Contact Number: Work: (904) 529-2924 ex.
Print Client Name:
Date: 3/28/2023

Inspector Signature:

Handwritten signature of Morgan Palmer.

Form Number: DH 4030 12/16A

Client Signature:

Handwritten signature of the client.

10-51-00729 Lake Asbury Junior High

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/3/2022 12:22:07 PM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00047 Name of Facility: Lakeside Jr High School Address: 2750 Moody Avenue City, Zip: Orange Park 32073 Type: Public Schools Owner: Clay County School Board Person In Charge: Clay County School Board Phone: (904) 284-6500 PIC Email: calvin.dell@myoneclay.net	Correct By: Next Inspection Re-Inspection Date: None
---	---

Inspection Information

Purpose: Routine Inspection Date: 11/1/2022	Begin Time: 11:13 AM End Time: 11:51 AM
--	--

Additional Information

FEMALES MALES	CENSUS
------------------------------	--------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	OUT 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other
---	---	--

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



*** BarnettP 11/3/2022 12:22:07 PM ***

2 of 2

General Comments

building 3 - plumbing issue - no water in entire building - no bathrooms - work order placed 2 months ago - issue has not been resolved.
building 2 - girls bathroom on first floor out of order for past month - leak fixed but toilet still not attached to wall and sitting on floor - fix
ESE portable - fridge 34
all classrooms in good condition with all lights working
no other violations found at time of inspection
gym showers working with hot water available
Email Address(es): calvin.dell@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair
no plumbing or working water in building 3
CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #11. Group Toilet Rooms
building 3 has no toilet, building 2 has a girls toilet out of order for 1 month
CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Inspection Conducted By: Morgan Palmer (884987)
Inspector Contact Number: Work: (904) 529-2924 ex.
Print Client Name:
Date: 11/1/2022

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00768
Name of Facility: Oakleaf Junior High School
Address: 4085 Plantation Oaks Boulevard
City, Zip: Orange Park 32065

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Jimmy Gonzalez Phone: 904-336-5821
PIC Email: Jimmy.Gonzalez@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 4/20/2023

Begin Time: 11:00 AM
End Time: 12:30 PM

Additional Information

FEMALES 597
MALES 640

CENSUS 1237

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

<u>IN</u> SCHOOL SANITATION	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>OUT</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>IN</u> 15. Shower Facilities	<u>IN</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>IN</u> 16. Showers Water Temperatures	<u>IN</u> 24. Changing Station & Mats
<u>IN</u> 5. Maintenance & Repair	WATER SUPPLY	<u>IN</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>IN</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>OUT</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>IN</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>OUT</u> 20. Solid Waste	<u>IN</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>IN</u> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

There was a large puddle of water outside of one of the showers in the male locker room- Unsure if there is a plumbing issue or problem with the shower curtain

There is some visible ice on the line to the cooling unit at the rear of the cafeteria kitchen

Other conditions were satisfactory

Jimmy.Gonzalez@myoneclay.net

Wilnitra.Dixon@myoneclay.net

Email Address(es): Jimmy.Gonzalez@myoneclay.net;

Wilnitra.Dixon@myoneclay.net;

Violations Comments

Violation #12. Toilet Facilities

Two toilets in the girls restroom in bldg 400 (8th grade area) were out of order

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #18. Drinking Fountains

The fountain in the male locker room is out of service

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Violation #20. Solid Waste

One of the dumpsters needs a plug to prevent leakage or vermin entry (Drain plug missing)

CODE REFERENCE: 20. Solid Waste. 5.(1)(e)8.e SREF. Trash and waste containers shall be provided in all areas, sufficient in number and emptied daily. Trash shall be stored in bins or containers in a central waste disposal area until removed. 5(1)(e)8.f SREF. Garbage, trash, & rubbish shall be collected, stored, and disposed of at a frequency and manner that prevents a sanitary nuisance. 5(11)(c)(d) SREF. Waste containers, including dumpsters, shall be accessible for maintenance and sanitation. Collectors and dumpsters shall be located on a concrete slab. Wet garbage shall be stored in impermeable, leak-proof, fly-tight containers. 468.2.3 FBC. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Jimmy Gonzalez
Date: 4/20/2023

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00072
Name of Facility: Orange Park Jr High
Address: 1500 Gano Avenue
City, Zip: Orange Park 32073

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Tania Auguste (Carlton Frazier) Phone: (904) 336-5975
PIC Email: Carlton.Frazier@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 5/3/2023

Begin Time: 11:32 AM
End Time: 01:25 PM

Additional Information

FEMALES 450
MALES 450

CENSUS 900

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>IN</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>OUT</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>IN</u> 15. Shower Facilities	<u>IN</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>IN</u> 16. Showers Water Temperatures	<u>IN</u> 24. Changing Station & Mats
<u>OUT</u> 5. Maintenance & Repair	WATER SUPPLY	<u>IN</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>IN</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>NA</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>OUT</u> 20. Solid Waste	<u>NA</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>NA</u> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Other conditions satisfactory
Possible ground hornets/wasps noted near gate to dumpster area-Recommend checking and treating as needed

Email Address(es): Tania.Auguste@myoneclay.net;
Carlton.Frazier@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

Building 2
1st floor male gang restroom - 1 toilet out of order - work order in
CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #13. Handwashing Facilities

Check water pressure on hand sink in male restroom upstairs in bldg 4
CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #20. Solid Waste

One of the dumpsters needs a plug to prevent leakage or vermin entry
CODE REFERENCE: 20. Solid Waste. 5.(1)(e)8.e SREF. Trash and waste containers shall be provided in all areas, sufficient in number and emptied daily. Trash shall be stored in bins or containers in a central waste disposal area until removed. 5(1)(e)8.f SREF. Garbage, trash, & rubbish shall be collected, stored, and disposed of at a frequency and manner that prevents a sanitary nuisance. 5(11)(c)(d) SREF. Waste containers, including dumpsters, shall be accessible for maintenance and sanitation. Collectors and dumpsters shall be located on a concrete slab. Wet garbage shall be stored in impermeable, leak-proof, fly-tight containers. 468.2.3 FBC. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Tania Auguste (Carlton Frazier)
Date: 5/3/2023

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00042 Name of Facility: Wilkinson Jr High Address: 5025 County Road 218 City, Zip: Middleburg 32068 Type: Public Schools Owner: Clay County School Board Person In Charge: Clay County School Board Phone: (904) 284-6500 PIC Email:	Correct By: Next Inspection Re-Inspection Date: None
---	---

Inspection Information

Purpose: Routine Inspection Date: 3/6/2023	Begin Time: 12:39 PM End Time: 01:47 PM
---	--

Additional Information

FEMALES 340 MALES 373	CENSUS 713
--------------------------------------	------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	IN 11. Group Toilet Rooms OUT 12. Toilet Facilities OUT 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source OUT 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other
---	---	--

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Correct all violations prior to next inspection.

Reach-in Refrigerator: 30 F; 39 F; 37 F
Reach-in Freezer: -4.7 F; 0.5 F; 0.7 F; 0.5 F
Chest Freezer: -30 F; -10 F
Handwashing Sink: 100.3 F; 120.3 F

Email Address(es): Michael.Mosely@myoneclay.net;
Stephanie.Raucci@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

The floor within the cafeteria is uneven and has jagged ends at the end of the cafeteria closest to the serving lines. A workorder has been created to correct this and the section of floor has been taped off. Correct prior to next inspection.

There is a rotted wood plank in front of the field concession stand. A workorder has been created to correct this and there are cones delineating the hole. Correct prior to next inspection.

There is one light out within room 776. A workorder has been created to correct this. Correct prior to next inspection.

There are multiple lights out within the band room. A workorder has been created to correct this. Correct prior to next inspection.

There is water damage on multiple ceiling tiles within building 600. Correct prior to next inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

The toilet within the handicap stall within women's restroom 510 is loose to the floor. A workorder has been created to correct this. Correct prior to next inspection.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #13. Handwashing Facilities

The left faucet within the men's restroom 796 is loose. A workorder has been created to correct this. Correct prior to next inspection.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

Two water fountains near P25 are inoperable. A workorder has been created to correct this. Correct prior to next inspection.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Michael Moseley
Date: 3/6/2023

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00033 Name of Facility: Clay High School Address: 2025 State Road 16 W City, Zip: Green Cove Springs 32043 Type: Public Schools Owner: Clay County School Board Person In Charge: Clay County School Board Phone: (904) 284-6500 PIC Email:	Correct By: Next Inspection Re-Inspection Date: None
--	---

Inspection Information

Purpose: Routine Inspection Date: 3/14/2023	Begin Time: 12:46 PM End Time: 02:52 PM
--	--

Additional Information

FEMALES 816 MALES 816	CENSUS 1632
--------------------------------------	-------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	IN 11. Group Toilet Rooms OUT 12. Toilet Facilities OUT 13. Handwashing Facilities IN 14. Soap Dispensers OUT 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source OUT 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY IN 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other
---	--	--

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

Emailed

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Correct all violations prior to next inspection.

Fridge: 31 F

Email Address(es): keesha.tyler@myoneclay.net;
Stephanie.Raucci@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

The boy's restroom 733 is missing one light cover. Correct prior to next inspection.

The weight room is missing some light covers. Correct prior to next inspection.

There is a ceiling tile with water damage within room 773. Correct prior to next inspection.

There is one light out within room 713, within the chorus room, and within P20. Correct prior to next inspection.

There are multiple lights out within the band room, within the gym, and within room 335. Correct prior to next inspection.

P20 has one cracked light cover. Correct prior to next inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

Two restrooms are currently out of order near the main office. A workorder has been created to address this. Correct prior to next inspection.

The boy's restroom near the carpentry classroom has an out of order toilet. A workorder has been created to address this. Correct prior to next inspection.

A toilet within the girl's restroom near room 510 is leaking. Correct prior to next inspection.

One stall is missing a sanitary box within the women's locker room. Correct prior to next inspection.

The restroom of the men's locker room has a large hole within the floor under the sink. This is not sharp; however, this is a tripping hazard. Correct prior to next inspection.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Inspector Signature:

Client Signature:

Emailed

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Violation #13. Handwashing Facilities

One push-in cap is missing on one sink within the girl's restroom 732. Correct prior to next inspection.

The water pressure of one faucet within the girl's restroom 1102 is too low. Correct prior to next inspection.

One faucet within the boy's restroom 1103 is loose. Correct prior to next inspection.

The sink within the girl's restroom within the carpentry hallway is leaking. A workorder has been created to address this. Correct prior to next inspection.

The girl's restroom near room 233 is missing paper towels. Correct prior to next inspection.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #15. Shower Facilities

There is a large hole in the wall in the men's locker room shower area leaving insulation exposed and chunks of the wall on the floor. A workorder has been created to address this. Correct prior to next inspection.

CODE REFERENCE: 15. Shower Facilities. 5(16)(b)10 SREF. Shower facilities, where provided, shall be maintained in a clean and sanitary condition at all times. 5(16)(b)11 SREF. Foot baths shall not be provided unless they are required by a Board-approved educational program. 468.3.5.5 FBC. Walls. Walls in toilet rooms shall be impervious to a height of at least 4 ft. above the floor. Walls in can wash areas, & shower rooms shall be impervious to a height of at least 6 ft. above the floor. Toilet and shower partitions shall be impervious. 468.3.5.8.1 FBC. Shower heads shall be based on the peak load, provided at the ratio of one shower head for each five students, and located at least of 30 inches apart.

Violation #18. Drinking Fountains

The exterior water fountain near room 201 is inoperable. Correct prior to next inspection.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Keesha Tyler
Date: 3/14/2023

Inspector Signature:

Handwritten signature of Melissa Johnson in black ink.

Form Number: DH 4030 12/16A

Client Signature:

Handwritten signature 'Emailed' in black ink.

10-51-00033 Clay High School

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/26/2023 12:32:37 PM ****

1 of 4

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00673 Name of Facility: Fleming Island High School Address: 2233 Village Square Parkway City, Zip: Fleming Island 32003 Type: Public Schools Owner: Clay County School Board Person In Charge: Clay County School Board Phone: (904) 541-2100 PIC Email: general.forman@myoneclay.net	Correct By: Next Inspection Re-Inspection Date: None
--	---

Inspection Information

Purpose: Routine Inspection Date: 12/22/2022	Begin Time: 09:10 AM End Time: 10:30 AM
---	--

Additional Information

FEMALES 916 MALES 963	CENSUS 1879
--------------------------------------	-------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION <u>IN</u> 1. School Site <u>IN</u> 2. Playground, Equip & Athletic Fields* <u>IN</u> 3. Athletic & Playground Equipment BUILDING CONST/MAINT. <u>IN</u> 4. Construction <u>OUT</u> 5. Maintenance & Repair <u>IN</u> 6. Lighting Standards <u>IN</u> 7. Heating, Ventilation, A/C Standards <u>IN</u> 8. Natural Ventilation <u>IN</u> 9. Mechanical Ventilation SANITARY FACILITIES <u>IN</u> 10. Provided/Accessible/Separation	<u>OUT</u> 11. Group Toilet Rooms <u>IN</u> 12. Toilet Facilities <u>OUT</u> 13. Handwashing Facilities <u>IN</u> 14. Soap Dispensers <u>OUT</u> 15. Shower Facilities <u>IN</u> 16. Showers Water Temperatures WATER SUPPLY <u>IN</u> 17. Approved Source <u>OUT</u> 18. Drinking Fountains LIQUID WASTE & WASTE WATER <u>IN</u> 19. Sewage Disposal <u>IN</u> 20. Solid Waste PEST CONTROL	<u>IN</u> 21. Pest Control SAFETY <u>IN</u> 22. First Aid Kit DIAPER CHANGING STATION <u>IN</u> 23. Sanitizers <u>IN</u> 24. Changing Station & Mats <u>IN</u> 25. Hand Sink <u>IN</u> 26. Garbage Can ANIMAL HEALTH & SAFETY <u>IN</u> 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES <u>NA</u> 28. Maintenance/Complaint <u>NA</u> 29. Other
---	--	---

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/26/2023 12:32:37 PM ****

2 of 4

General Comments

Correct violations prior to next inspection. Contact Matthew.Bowen2@FLHealth.gov if you have any questions.

Email Address(es): general.forman@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

Ramps going up to portables have algae that needs to be cleaned off to remove slip hazard.

Portable 42 3 lights out

Portable 43 2 lights out

Portable 63 and 84, 1 light out

Portable 53 multiple lights out

Classroom 321 2 lights out

several ballast covers hanging down in weight room

Classroom 291 multiple damaged chairs, not sharp

Classroom 1026 cracked desk chair, not sharp

Classroom 220 2 water damaged ceiling tiles

Push plate on door in boys locker room has been pulled away from door frame.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspector Signature:

Handwritten signature of Matthew Bowen.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/26/2023 12:32:37 PM ****

3 of 4

Violation #11. Group Toilet Rooms

Gang restroom 26

Male - no soap dispensers, 1 urinal not working

Gang restroom 128

No soap dispensers

Gang Restroom 64

Female - 1 stall missing sanitary box, no soap in handicap stall

Male - no soap in handicap stall

Gang restroom 210

Female - missing sanitary box in handicap stall

Gang restroom 224 sanitary box missing from handicap stall

Gang restroom 278

Female - sanitary buckets with no lid

Male - missing floor tiles in front of urinals

Gang restroom 309

Female - loose faucet

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Violation #13. Handwashing Facilities

Two hand sinks in boys locker room have broken faucets.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #15. Shower Facilities

Floors, drain trench, and drains are dirty with debris in male and female locker room showers. Many drain covers are missing in both locker room showers.

CODE REFERENCE: 15. Shower Facilities. 5(16)(b)10 SREF. Shower facilities, where provided, shall be maintained in a clean and sanitary condition at all times. 5(16)(b)11 SREF. Foot baths shall not be provided unless they are required by a Board-approved educational program. 468.3.5.5 FBC. Walls. Walls in toilet rooms shall be impervious to a height of at least 4 ft. above the floor. Walls in can wash areas, & shower rooms shall be impervious to a height of at least 6 ft. above the floor. Toilet and shower partitions shall be impervious. 468.3.5.8.1 FBC. Shower heads shall be based on the peak load, provided at the ratio of one shower head for each five students, and located at least of 30 inches apart.

Violation #18. Drinking Fountains

Gang 309 restroom water fountain inoperable

Gang 224 restroom water fountain inoperable

2 water fountains are inoperable near gang restroom 221

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/26/2023 12:32:37 PM ****

4 of 4

Inspection Conducted By: Matthew Bowen (45622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name:
Date: 12/22/2022

Inspector Signature:

Handwritten signature of Matthew Bowen.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 3/1/2023 8:18:46 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00044 Name of Facility: KEYSTONE HEIGHTS JR/SR HIGH Address: 900 Orchid Avenue City, Zip: Keystone Heights 32656 Type: Public Schools Owner: Clay County School Board Person In Charge: Clay County School Board Phone: (904) 336-7775 PIC Email:	Correct By: Next Inspection Re-Inspection Date: None
--	---

Inspection Information

Purpose: Routine Inspection Date: 2/28/2023	Begin Time: 10:45 AM End Time: 12:30 PM
--	--

Additional Information

FEMALES 562 MALES 611	CENSUS 1173
--------------------------------------	-------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction IN 5. Maintenance & Repair OUT 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers OUT 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source OUT 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION IN 23. Sanitizers NA 24. Changing Station & Mats IN 25. Hand Sink IN 26. Garbage Can ANIMAL HEALTH & SAFETY IN 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES IN 28. Maintenance/Complaint IN 29. Other
---	--	--

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

No General Comments Available Email Address(es): herbert.walls@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 3/1/2023 8:18:46 AM ****

2 of 2

Violations Comments

<p>Violation #6. Lighting Standards Need to replace several light bulbs in class rooms several out, worst is in chorus room. CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.</p>
<p>Violation #15. Shower Facilities Safety shower in shop room need braced and adjusted, shower head to low. CODE REFERENCE: 15. Shower Facilities. 5(16)(b)10 SREF. Shower facilities, where provided, shall be maintained in a clean and sanitary condition at all times. 5(16)(b)11 SREF. Foot baths shall not be provided unless they are required by a Board-approved educational program. 468.3.5.5 FBC. Walls. Walls in toilet rooms shall be impervious to a height of at least 4 ft. above the floor. Walls in can wash areas, & shower rooms shall be impervious to a height of at least 6 ft. above the floor. Toilet and shower partitions shall be impervious. 468.3.5.8.1 FBC. Shower heads shall be based on the peak load, provided at the ratio of one shower head for each five students, and located at least of 30 inches apart.</p>
<p>Violation #18. Drinking Fountains Several water fountains need adjusted, low flow not clearing guard. CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.</p>

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 2/28/2023

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 4

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00067 Name of Facility: Middleburg High School Address: 3802 County Road 220 City, Zip: Middleburg 32068 Type: Public Schools Owner: Clay County School Board Person In Charge: Clay County School Board Phone: (904) 284-6500 PIC Email:	Correct By: Next Inspection Re-Inspection Date: None
--	---

Inspection Information

Purpose: Routine Inspection Date: 3/15/2023	Begin Time: 09:28 AM End Time: 11:30 AM
--	--

Additional Information

FEMALES 822 MALES 820	CENSUS 1642
--------------------------------------	-------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION <u>IN</u> 1. School Site <u>IN</u> 2. Playground, Equip & Athletic Fields* <u>IN</u> 3. Athletic & Playground Equipment BUILDING CONST/MAINT. <u>IN</u> 4. Construction <u>OUT</u> 5. Maintenance & Repair <u>IN</u> 6. Lighting Standards <u>IN</u> 7. Heating, Ventilation, A/C Standards <u>IN</u> 8. Natural Ventilation <u>IN</u> 9. Mechanical Ventilation SANITARY FACILITIES <u>IN</u> 10. Provided/Accessible/Separation	<u>IN</u> 11. Group Toilet Rooms <u>OUT</u> 12. Toilet Facilities <u>OUT</u> 13. Handwashing Facilities <u>IN</u> 14. Soap Dispensers <u>IN</u> 15. Shower Facilities <u>OUT</u> 16. Showers Water Temperatures WATER SUPPLY <u>IN</u> 17. Approved Source <u>OUT</u> 18. Drinking Fountains LIQUID WASTE & WASTE WATER <u>IN</u> 19. Sewage Disposal <u>IN</u> 20. Solid Waste PEST CONTROL	<u>IN</u> 21. Pest Control SAFETY <u>IN</u> 22. First Aid Kit DIAPER CHANGING STATION <u>NA</u> 23. Sanitizers <u>NA</u> 24. Changing Station & Mats <u>NA</u> 25. Hand Sink <u>NA</u> 26. Garbage Can ANIMAL HEALTH & SAFETY <u>NA</u> 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES <u>NA</u> 28. Maintenance/Complaint <u>NA</u> 29. Other
---	--	---

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



General Comments

Email Melissa.Johnson@FLHealth.gov when the violations listed within have been corrected.

Email Address(es): Manuel.Gonzales@myoneclay.net;
Stephanie.Raucci@myoneclay.net

Inspector Signature:

Handwritten signature of Melissa Johnson in cursive.

Client Signature:

Handwritten signature of the client in cursive.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 4

Violations Comments

Violation #5. Maintenance & Repair

Cracked floor tiles within P36. This is a tripping hazard. Correct prior to next inspection.

Missing light cover in boys restroom 73. Correct prior to next inspection.

Cracked light cover in P53. Correct prior to next inspection.

Some lights out within the chorus room, the band room, P72, room 68, room 122, room 135, within the hallway near room 139, within room 139, within room 181, and within room 259. Correct prior to next inspection.

Some lights are out within the library. A workorder has been created to correct this.

One light out within the culinary classroom. Correct prior to next inspection.

One light out within P84. A workorder has been created to correct this.

Some ceiling tiles with water damage within room 181 and within the hallway near room 353. Correct prior to next inspection.

One ceiling tile has water damage within room 139. Correct prior to next inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

The boy's restroom 73 has one stall that is missing toilet paper. Correct prior to next inspection.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #13. Handwashing Facilities

The furthest left faucet had low water pressure. This was corrected as the inspector was on-site.

Two faucets are loose within the boy's restroom 353. Correct prior to next inspection.

One faucet within the girl's locker room is inoperable. Correct prior to next inspection.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #16. Showers Water Temperatures

The showers are currently inoperable.

CODE REFERENCE: 16. Shower Water Temperature. 5(13)(h)1 SREF. Hot and cold water shall be provided at the shower. 5(16)(b)10 SREF and 468.3.5.8.3 FBC. Water shall be heated and the temperature at the shower head shall not exceed 110°F nor be less than 95°F.

Violation #18. Drinking Fountains

Low water pressure at water fountain within Garber Auto Academy. A workorder has been created to address this.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



4 of 4

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Manuel Gonzales
Date: 3/15/2023

Inspector Signature:

Handwritten signature of Melissa Johnson in cursive.

Form Number: DH 4030 12/16A

Client Signature:

Handwritten signature of Manuel Gonzales in cursive.

10-51-00067 Middleburg High School

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



Facility Information

RESULT: Satisfactory

Permit Number: 10-51-1288429
Name of Facility: Oakleaf High School
Address: 4035 Plantation Oaks Boulevard
City, Zip: Orange Park 32065

**Correct By: Next Inspection
Re-Inspection Date: None**

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Clay County School Board Phone: (904) 278-5630
PIC Email:

Inspection Information

Purpose: Routine
Inspection Date: 1/4/2023

Begin Time: 09:27 AM
End Time: 11:23 AM

Additional Information

FEMALES 1154
MALES 1181

CENSUS 2335

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>OUT</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>IN</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>OUT</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>IN</u> 15. Shower Facilities	<u>NA</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>OUT</u> 16. Showers Water Temperatures	<u>NA</u> 24. Changing Station & Mats
<u>OUT</u> 5. Maintenance & Repair	WATER SUPPLY	<u>NA</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>NA</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>OUT</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>IN</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>IN</u> 20. Solid Waste	<u>NA</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>NA</u> 29. Other

Marking Key: *IN* = the act or item was observed to meet standards; *OUT* = the act or item was observed not to meet standards; *NO* = the act or item was not observed to be occurring at the time of inspection; *NA* = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 4

General Comments

The men s restroom - 143 - has a leaking toilet within the handicap stall. A work-order had been created to fix this prior to the inspector s arrival.

The men s restroom - 189 - is currently posted as being out of order. This restroom is missing one push-in button on the left sink s faucet, has an inoperable right sink, and has a loose sink faucet within the handicap stall.

Temperatures:

Room 135 Reach-In Fridge: 35 F
Room 135 Reach-in Freezer: -6.7 F
Room 152 Reach-in Fridge: 41 F
Room 152 Reach-in Freezer: 10 F
Room 153 Reach-in Fridge: 40.8 F
Room 153 Reach-in Freezer: 8.2 F

Correct the violations listed within prior to next inspection.

Email Address(es): Christine.Fisher@myoneclay.net;
Stephanie.Raucci@myoneclay.net;

Violations Comments

Inspector Signature:

Handwritten signature of Melisa Johnson.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 4

Violation #5. Maintenance & Repair

Multiple lights are out within the wrestling room, within the gym hallway near the custodial closet, and within room 240. Correct prior to next inspection.

There are some lights out within the men's locker room, within the weight room, within the 530 hallway, within the men's restroom - R1103 -, in front of the library, within the choir room, within the band room, and within rooms 220, 226, 268, 529, and P51. Correct prior to next inspection.

There are four lights out within the women's locker room. Correct prior to next inspection.

There are three lights out within the main office and within room 532. Correct prior to next inspection.

Two lights are out within the women's restroom - 207 -, within room P21, and within room 213. Correct prior to next inspection.

One light is out in rooms 152, 163, 309, 500, and within the men's restroom - 700 -. Correct prior to next inspection.

Two lights within the men's restroom - 351 - and within room P45 are missing covers. Correct prior to next inspection.

Two lights within the men's restroom - 20A - are missing covers. Correct prior to next inspection.

Multiple lights are missing their covers within the wrestling room. Correct prior to next inspection.

One light within the gym hallway near the custodial closet, one light within room P63, and one light within the men's restroom - 403 - are missing a cover. Correct prior to next inspection.

One light cover is cracked within room 500 and within room P35. Correct prior to next inspection.

Loose ceiling tiles within room P21. Correct prior to next inspection.

One loose ceiling tile in Excalibur Hall. Correct prior to next inspection.

Multiple missing ceiling tiles within the wrestling room. Correct prior to next inspection.

Two missing ceiling tiles within the men's restroom - 20A -. Correct prior to next inspection.

One missing ceiling tile within room 213. Correct prior to next inspection.

There is water damage on the tiles over the water fountains near room 190, within room 532, and within the wrestling room. Correct prior to next inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #11. Group Toilet Rooms

The toilet partition within the men's restroom - 20A - is very rusty. The toilet partition was to be finished with noncorrosive materials. Correct prior to next inspection.

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Inspector Signature:

Melissa Johnson

Client Signature:

[Signature]

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



4 of 4

Violation #13. Handwashing Facilities

The women's restroom - 145A -, the women's restroom - 702 -, and the men's restroom - 700 - are missing a push-in cap on one sink faucet. Correct prior to next inspection.

The women's restroom - 207 - and room 306 are missing two push-in covers for the sink faucets. Correct prior to next inspection.

The water pressure is too low on the right sink in the women's restroom - 402 -. Correct prior to next inspection.

The handwashing sinks within rooms 135, 139, 152, and 153 do not get hot. The recorded temperatures at the time of inspection were 70.2 F, 70.7 F, 73.6 F, and 77.5 F. Correct prior to next inspection.

Room 500 has two loose faucets. Correct prior to next inspection.

The left sink's faucet within the men's restroom - 209 - and one faucet within room 306 are loose. Correct prior to next inspection.

One of the sinks within the women's restroom - 20B - is moderately leaking. Correct prior to next inspection.

The women's rest room - 702 - is missing paper towels. Correct prior to next inspection.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #16. Showers Water Temperatures

The showers within the women's and men's locker room do not get hot. The temperature of the water at the shower head shall be between 95 F and 110 F. The inspector measured the temperatures of the water at the shower heads to be 69.5 F and 70.6 F. Correct prior to next inspection.

CODE REFERENCE: 16. Shower Water Temperature. 5(13)(h)1 SREF. Hot and cold water shall be provided at the shower. 5(16)(b)10 SREF and 468.3.5.8.3 FBC. Water shall be heated and the temperature at the shower head shall not exceed 110°F nor be less than 95°F.

Violation #18. Drinking Fountains

There is one inoperable water fountain within the men's locker room, near room 262, and within room P51. Correct prior to next inspection.

The right water fountain outside the gym near the men's restroom, the right water fountain near room 351 in the hallway between the restrooms, the left water fountain in the 500 hallway, and the water fountains near room 700 have low water pressure. Correct prior to next inspection.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Laurie Almodovar
Date: 1/4/2023

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/26/2023 12:31:40 PM ****

1 of 2

Facility Information

RESULT: Satisfactory

**Correct By: Next Inspection
Re-Inspection Date: None**

Permit Number: 10-51-00071
Name of Facility: Orange Park High School
Address: 2300 Kingsley Avenue
City, Zip: Orange Park 32073

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Daniel Allen Phone: (904) 891-0655
PIC Email: Daniel.Allen@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 12/22/2022

Begin Time: 12:47 PM
End Time: 02:05 PM

Additional Information

FEMALES 836
MALES 968

CENSUS 1804

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>OUT</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>IN</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>IN</u> 15. Shower Facilities	<u>IN</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>IN</u> 16. Showers Water Temperatures	<u>IN</u> 24. Changing Station & Mats
<u>OUT</u> 5. Maintenance & Repair	WATER SUPPLY	<u>IN</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>IN</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>IN</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>IN</u> 20. Solid Waste	<u>IN</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>IN</u> 29. Other

Marking Key: *IN* = the act or item was observed to meet standards; *OUT* = the act or item was observed not to meet standards; *NO* = the act or item was not observed to be occurring at the time of inspection; *NA* = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

No General Comments Available

Email Address(es): Daniel.Allen@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/26/2023 12:31:40 PM ****

2 of 2

Violations Comments

Violation #5. Maintenance & Repair

Vocation buildings

V102, V106, V134 have water stained ceiling tiles

Multiple ceiling tiles in hallways are water stained

Classroom 116 water stained tile

Building 1

Room 227 and 223 multiple light out - replace bulbs

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #11. Group Toilet Rooms

Gym gang restroom

male - 1 faucet not working

female - 2 faucets not working

Mens Bathroom 255

loose/broken fixture - repair/replace

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Inspection Conducted By: Matthew Bowen (45622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Daniel Allen
Date: 12/22/2022

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00075 Name of Facility: Ridgeview High School Address: 466 Madison Avenue City, Zip: Orange Park 32065 Type: Public Schools Owner: Clay County School Board Person In Charge: Clay County School Board Phone: (904) 284-6500 PIC Email:	Correct By: Next Inspection Re-Inspection Date: None
--	---

Inspection Information

Purpose: Routine Inspection Date: 12/20/2022	Begin Time: 08:57 AM End Time: 10:45 AM
---	--

Additional Information

FEMALES 1026 MALES 995	CENSUS 2021
---------------------------------------	-------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	IN 11. Group Toilet Rooms IN 12. Toilet Facilities OUT 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source OUT 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other
---	--	--

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Email Melissa.Johnson@FLHealth.gov if you have any questions or concerns.

The water fountain outside of the women s locker room is inoperable. A workorder was created for this prior to inspection.

The right water fountain near room 635 is inoperable. A workorder was created for this prior to inspection.

The men s restroom near portable 41 is out of order.

Email Address(es): Becky.Murphy@myoneclay.net;
Kelly.Williams@myoneclay.net;
Donald.Speights@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

Multiple lights are out within the weight room. Correct prior to next inspection.

Some lights are out within room 524, room 557, room 701, and room 1013. Correct prior to next inspection.

One light is out in portabe 6 and portable 69. Correct prior to next inspection.

There is water damage on the ceiling tiles in the hallway near rooms 630, 639, and 649. Correct prior to next inspection.

There is water damage on the ceiling tiles in rooms 550, 524, 701, and 706. Correct prior to next inspection.

There is cracked ceiling tiles within the weight room. Correct prior to next inspection.

There is water damage on the ceiling tiles in computer lab building 3. Correct prior to next inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #13. Handwashing Facilities

The push-in cap to operate one of the sinks within the men's locker room is missing. Correct prior to next inspection.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

The left water fountain outside the library is inoperable. Correct prior to next inspection.

The water fountain near room 630 has low water pressure. Correct prior to next inspection.

The water fountain near portable 6 is inoperable. Correct prior to next inspection.

The water fountain near portable 66 has low water pressure. Correct prior to next inspection.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Chris Gallagher
Date: 12/20/2022

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/26/2023 8:34:27 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00376 Name of Facility: R C Bannerman Learning Center Address: 608 Mill Street City, Zip: Green Cove Springs 32043 Type: Public Schools Owner: Clay County School Board Person In Charge: Stephane Palmer Phone: 904-336-4975 PIC Email:	Correct By: Next Inspection Re-Inspection Date: None
---	---

Inspection Information

Purpose: Routine Inspection Date: 1/25/2023	Begin Time: 09:50 AM End Time: 10:20 AM
--	--

Additional Information

FEMALES 83 MALES 181	CENSUS 264
-------------------------------------	------------------

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction IN 5. Maintenance & Repair OUT 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation	IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers NA 15. Shower Facilities NA 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL	IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION IN 23. Sanitizers IN 24. Changing Station & Mats IN 25. Hand Sink IN 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES IN 28. Maintenance/Complaint IN 29. Other
---	--	--

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

No General Comments Available Email Address(es): jason.kendall@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/26/2023 8:34:27 AM ****

2 of 2

Violations Comments

Violation #6. Lighting Standards

Need to replace burned out bulbs in classrooms, most not to bad. However p8,5,38 have several lights total not working.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 1/25/2023

Inspector Signature:

Handwritten signature of Alan Davis.

Client Signature:

Handwritten signature of the client.