

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Bannerman Learning Center  
 608 Mill Street  
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/8/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		Passed annual inspection.					

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Clay High School  
 2025 State Road 16  
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/16/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
	919	Emergency lights in hallway outside room are not working.*				X	
	1129	Emergency light in electrical room is out.*				X	
Gym		All lights need to be checked.*				X	

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Clay High School  
 2025 State Road 16  
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/16/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
	300B	Emergency lights in hallway outside room are not working.*				X	
	300C	Emergency lights in hallway outside room are not working.*				X	
	310	Emergency lights in hallway outside room are not working.*				X	
	346	Emergency lights in hallway outside room are not working.*				X	
	366	Emergency light in electrical room and storage room is out.*				X	
	382	Emergency light is out in boys bathroom.*				X	
	729	Hallway emergency light at exit is out.*				X	
	903	Boys bathroom emergency light is out.*				X	
	904	Girls bathroom emergency light is out.*				X	
	910	Emergency lights in hallway outside room are not working.*				X	



**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Fleming Island High School  
 2233 Village Square Parkway  
 Fleming Island, FL 32003

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/23/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
	121		Fire extinguisher expired in 2017.*			X	
	169		Fire extinguisher expired in 2014.*			X	
	170		Storage is to high.				X
	220		Fire sprinkler wrench is missing. Storage needs to be removed.				X
	296		Textbook storage is to high.				X
	1005		Electrical room - no storage.				X

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**

**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Keystone Heights Jr/Sr High School  
 900 Orchid Avenue  
 Keystone Heights, FL 32656

INSPECTOR SIGNATURE: 

INSPECTION DATE: 2/3/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
1	62	Emergency lights are not working.*				X	
	191	Emergency lights are not working.*				X	
2	65	Emergency lights are not working. Hallway lights outside room not working.*				X	
	66	Emergency lights are not working.*				X	
	68	Emergency lights are not working.*				X	
4	411	Emergency lights are not working.*				X	
5	522	Emergency lights are not working.*				X	
	526	Emergency lights are not working.*				X	
7	719	Emergency lights are not working.*				X	
8	813	Emergency lights are not working.*				X	
9		No emergency lights in boys & girls locker rooms, weight rooms and hallway.*				X	

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**

**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Keystone Heights Jr/Sr High School  
 900 Orchid Avenue  
 Keystone Heights, FL 32656

**INSPECTOR SIGNATURE:** \_\_\_\_\_

**INSPECTION DATE:** 2/3/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
	917	Emergency lights are not working.*				X	
	924	No label (mechanical). Softball locker room has no emergency lights.*				X	
	928	Southeast exit is blocked - clear exit.					X
	933	Remove storage except for hurricane shutters.					X



**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

AND

**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Middleburg High School  
 3750 CR 220  
 Middleburg, FL 32068

INSPECTOR SIGNATURE: 

INSPECTION DATE: 2/10/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
	212		Two emergency lights are not working.*			X	
	285 (Gym)	Exit light is broken.	No emergency lighting throughout gym and locker room.*			X	
	361	Commercial food hood does not have annual cleaning tag.					X

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Oakleaf High School  
 4035 Plantation Oaks Boulevard  
 Orange Park, FL 32065

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/3/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		Passed annual inspection.					



**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**  
**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**  
**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**  
**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Orange Park High School (West)  
 2306 Kingsley Avenue  
 Orange Park, FL 32073

INSPECTOR SIGNATURE: 

INSPECTION DATE: 2/1/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
16	1605	Emergency lights are not working.*				X	
	1609	Emergency lights are not working.*				X	
	1610	Emergency lights are not working.*	Missing fire extinguisher.			X	X
17		North hallway emergency lights are not working. West entrance emergency lights are not working.*				X	
18	1803	Emergency lights are not working.*				X	
19	1906	Emergency lights are not working.*				X	
	1915	Emergency lights are not working.*				X	
	1918	Emergency lights are not working.*				X	
20	1921	Emergency lights are not working.*				X	
	2004	Battery dead in the exit sign at east entrance					X

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**  
**BUILDINGS ONLY**

**INSPECTOR SIGNATURE:** \_\_\_\_\_

**INSPECTION DATE:** 2/1/2021

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Orange Park High School (West)  
 2306 Kingsley Avenue  
 Orange Park, FL 32073

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
	2005	Emergency lights are not working.*				X	
	2006	Emergency lights are not working.*				X	
	2007	Emergency lights are not working.*				X	
	2008	Emergency lights are not working.*				X	
	2010	Emergency lights are not working.* Emergency lights outside room are not working.*				X	
	2011	Emergency lights are not working.*				X	
	2013	Emergency lights are not working.*				X	
21		West entrance emergency lights are not working.*	Fire alarm needs annual certification.			X	X
	2106	Battery in emergency lights are low.					X
	2107	Battery in emergency lights are low.					X
	2108	Emergency lights are not working.*				X	

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**  
**BUILDINGS ONLY**

**INSPECTOR SIGNATURE:** \_\_\_\_\_

**INSPECTION DATE:** 2/1/2021

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Orange Park High School (West)  
 2306 Kingsley Avenue  
 Orange Park, FL 32073

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
	2117	Emergency lights are not working.*				X	
	2124	Emergency lights are not working.*				X	
22		Emergency lights throughout the whole building are not working.*				X	
	2207		Fire suppression hood in kitchen needs current cleaning tag.				X



**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Orange Park High School  
 2306 Kingsley Avenue  
 Orange Park, FL 32073

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/21/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		Passed annual inspection.					

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**  
**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Ridgeview High School  
 466 Madison Avenue  
 Orange Park, FL 32065

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/17/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
	108B		Storage in electrical room - needs to be removed.				X
7	705		Class "K" fire extinguisher is mounted to high.				X
	Gym	Lockdown bar is in place - unable to exit south entrance - release lockdown bar.					X
8	818	Paint storage.					
2	214	Paint storage.					