

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**

**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21

DISTRICT: CLAY

FACILITY: Green Cove Springs Junior High School  
 1220 Bonaventure Avenue  
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/30/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		Passed annual inspection.					

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**  
**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Lake Asbury Junior High School  
 2851 Sandridge Road  
 Green Cove Springs, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 2/22/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		No emergency lighting throughout all buildings.*				X	
		Building has backup generator.					



**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**

**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Oakleaf Junior High School  
 4085 Plantation Oaks Boulevard  
 Orange Park, FL 32065

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/2/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		Passed annual inspection.					
	502		Use of table top deep fryers - need to be removed. No fire suppression system.				X

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**  
**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Orange Park Junior High School  
 1500 Gano Avenue  
 Orange Park, FL 32073

INSPECTOR SIGNATURE: 

INSPECTION DATE: 3/16/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
Gym		Girls & boys locker rooms - all emergency lights are inoperable.*				X	
		Boys restroom in gym - emergency lights are inoperable.*				X	
		Gym emergency lights by boys restroom are inoperable.*				X	

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT**  
**STATE BOARD OF EDUCATION**  
**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION**  
**F.S. 1013.12, 1013.20 & NFPA 101**

**AND**  
**FIRE SAFETY INSPECTION REPORT**  
**F.S. 1013.12, 1013.20 & RULE 69A-58**  
**BUILDINGS ONLY**

FISCAL YEAR: 2020/21  
 DISTRICT: CLAY  
 FACILITY: Wilkinson Junior High School  
 5025 CR 218  
 Middleburg, FL 32068

INSPECTOR SIGNATURE: 

INSPECTION DATE: 2/9/2021

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.*	School
		No emergency lighting throughout all buildings.*				X	