

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: ARGYLE ELEMENTARY SCHOOL
 2625 SPENCER PLANTATION BLVD.
 ORANGE PARK, FL 32073

CASUALTY SAFETY & SANITATION INSPECTION

F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
 F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE: *Hue Earl*
 BUILDING INSPECTION DATE: 4/5/2022
 PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Media center hallway shall remain clear of storage				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: CHARLES E. BENNETT ELEM. - 0071
 1 SOUTH OAKRIDGE AVENUE
 GREEN COVE SPRINGS, FL 32043

INSPECTOR SIGNATURE: *David Earl*
 BUILDING INSPECTION DATE: 4/25/2022
 PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			2 burner appliance shall be protected by fire suppression system.				X

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101**

AND

**FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58**

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: COPPERGATE ELEMENTARY - 0601
2250 COUNTY ROAD 209 N.
MIDDLEBURG, FL 32068

INSPECTOR SIGNATURE: *[Signature]*
BUILDING INSPECTION DATE: 3/21/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed Annual Inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE:
BUILDING INSPECTION DATE:
PORTABLE INSPECTION DATE:

Hence 

4/5/2022

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: DISCOVERY OAKS ELEMENTARY
 950 OAKLEAF PLANTATION PARKWAY
 ORANGE PARK, FL 32065

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE:
BUILDING INSPECTION DATE:
PORTABLE INSPECTION DATE:

[Handwritten Signature]

3/22/2022

FISCAL YEAR: CLAY

DISTRICT: DOCTORS INLET ELEMENTARY - 0261

FACILITY: 2634 COUNTY ROAD 220

MIDDLEBURG, FL 32068

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed Annual Inspection				

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

CASUALTY SAFETY & SANITATION INSPECTION

F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT

F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/20122

DISTRICT: CLAY

FACILITY: FLEMING ISLAND ELEMENTARY - 0521

4425 LAKESHORE DRIVE

FLEMING ISLAND, FL 32003

INSPECTOR SIGNATURE: *Brad E...*

BUILDING INSPECTION DATE: 4/25/2022

PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
	213		Electrical storage.				X
			Fire sprinkler system stage missing tag.				X
			Unknown when inspected.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: GROVE PARK ELEMENTARY - 0232
 1643 MILLER STREET
 ORANGE PARK, FL 32073

INSPECTOR SIGNATURE: *Howard Earl*

4/18/22

INSPECTOR SIGNATURE:
BUILDING INSPECTION DATE:
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: KEYSTONE HEIGHTS ELEMENTARY -0301
 335 SW PECAN STREET
 KEYSTONE HEIGHTS, FL 32656

INSPECTOR SIGNATURE: *[Signature]*
2/28/2022

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
10	30		Range - burnt element				X
	20F		Cover plate missing				X
	20A		Storage				X
Gym			Exit sign broke. Exit blocked.				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: LAKE ASBURY ELEMENTARY - 0451
 2901 SANDRIDGE ROAD
 GREEN COVE SPRINGS, FL 32043

INSPECTOR SIGNATURE: *John E.S.*
BUILDING INSPECTION DATE: 3/24/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: LAKESIDE ELEMENTARY - 0352
2752 MOODY ROAD
ORANGE PARK, FL 32073

INSPECTOR SIGNATURE: *[Signature]*
BUILDING INSPECTION DATE: 4/11/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Stage lift unacceptable. Unknown last inspection. Area is being used for storage.				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION

F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT

F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022

DISTRICT: CLAY

FACILITY: MCRAE ELEMENTARY - 0511

6770 COUNTY ROAD 315 C

KEYSTONE HEIGHTS, FL 32656

INSPECTOR SIGNATURE: *[Signature]*

BUILDING INSPECTION DATE: 2/28/2022

PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
1	120		Electrical cover plate missing. HVAC/Electrical room golf cart storage				X
							X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: MIDDLEBURG ELEMENTARY - 0271
 3958 MAIN STREET
 MIDDLEBURG, FL 32068

INSPECTOR SIGNATURE: *[Signature]*
 3/2/2022

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed Annual Inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5


CASUALTY SAFETY & SANITATION INSPECTION

F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: OAKLEAF VILLAGE ELEMENTARY - 0621
 410 OAKLEAF VILLAGE PARKWAY
 ORANGE PARK, FL 32065

INSPECTOR SIGNATURE: 
INSPECTION DATE: 3/23/2022

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: ORANGE PARK ELEMENTARY - 0201
 1401 PLAINFIELD AVENUE
 ORANGE PARK, FL 32073

INSPECTOR SIGNATURE: 
BUILDING INSPECTION DATE: 4/18/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: PLANTATION OAKS ELEMENTARY - 0651
 4150 PLANTATION OAKS BOULEVARD
 ORANGE PARK, FL 32065

INSPECTOR SIGNATURE: 
BUILDING INSPECTION DATE: 3/23/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection				

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION
 F.S. 1013.12, 1013.20 & NFPA 101**

**AND
 FIRE SAFETY INSPECTION REPORT
 F.S. 1013.12, 1013.20 & RULE 69A-58**

FISCAL YEAR: 2021/2022
 CLAY
 RIDEOUT ELEMENTARY - 0541
 2065 APALACHICOLA BOULEVARD
 MIDDLEBURG, FL 32068

INSPECTOR SIGNATURE: 

3/11/2022

INSPECTOR SIGNATURE:

BUILDING INSPECTION DATE:

PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: RIDGEVIEW ELEMENTARY - 0401
 421 JEFFERSON AVENUE
 ORANGE PARK, FL 32065


INSPECTOR SIGNATURE: *[Signature]*
BUILDING INSPECTION DATE: 4/11/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101
AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: S. BRYAN JENNINGS ELEMENTARY - 0331
 215 CORONA DRIVE
 ORANGE PARK, FLORIDA 32073

INSPECTOR SIGNATURE: 
 BUILDING INSPECTION DATE: 4/13/2022
 PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Fire alarm shows trouble				X
			No fire suppression over burners in kitchen				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION

F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT

F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022

DISTRICT: CLAY

FACILITY: SHADOWLAWN ELEMENTARY - 0631

2945 COUNTY ROAD 218

GREEN COVE SPRINGS, FL 32043

INSPECTOR SIGNATURE: *Heather E. Smith*

3/24/2022

INSPECTION DATE: 3/24/2022

INSPECTION TYPE: BUILDING INSPECTION DATE:


INSPECTION TYPE: PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101
AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: SWIMMING PEN CREEK ELEMENTARY - 0571
1630 WOODPECKER LANE
MIDDLEBURG, FL 32068

INSPECTOR SIGNATURE: 
BUILDING INSPECTION DATE: 4/6/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed Annual Inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101
AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: THUNDERBOLT ELEMENTARY - 0531
 2020 THUNDERBOLT ROAD
 FLEMING ISLAND, FL 32003

INSPECTOR SIGNATURE: *David Esposito*

BUILDING INSPECTION DATE: 4/25/2022

PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: TYNES ELEMENTARY - 0501
 1550 TYNES BOULEVARD
 MIDDLEBURG, FL 32068

INSPECTOR SIGNATURE:  Hester
BUILDING INSPECTION DATE: 4/6/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed Annual Inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION

F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT

F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: W. E. CHERRY ELEMENTARY - 0241
 420 EDSON DRIVE
 ORANGE PARK, FLORIDA 32073


INSPECTOR SIGNATURE: *[Signature]*
BUILDING INSPECTION DATE: 4/13/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101
AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: WILKINSON ELEMENTARY - 0491
 4965 COUNTY ROAD 218 W.
 MIDDLEBURG, FL 32068

INSPECTOR SIGNATURE:  3/1/2022
 BUILDING INSPECTION DATE: 3/1/2022
 PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Fire Hydrant out of service in front parking lot				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT

STATE BOARD OF EDUCATION

ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION

F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT

F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE: *[Signature]*

BUILDING INSPECTION DATE: 4/25/2022

PORTABLE INSPECTION DATE:

FISCAL YEAR: 2021/2022

DISTRICT: CLAY

FACILITY: GREEN COVE JUNIOR HIGH - 0021
1220 BONAVENTURE AVENUE
GREEN COVE SPRINGS, FL 32043

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
	422		Label combustible storage room. Is an electrical room				X

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: LAKE ASBURY JUNIOR HIGH - 0481
 2851 SANDRIDGE ROAD
 GREEN COVE SPRINGS, FL 32043

**CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101
AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58**

INSPECTOR SIGNATURE: 
BUILDING INSPECTION DATE: 3/24/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
 F.S. 1013.12, 1013.20 & NFPA 101
 AND
FIRE SAFETY INSPECTION REPORT
 F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/20122
DISTRICT: CLAY
FACILITY: LAKESIDE JUNIOR HIGH -0351
 2750 MOODY AVENUE
 ORANGE PARK, FL 32073

INSPECTOR SIGNATURE: *Nere*
BUILDING INSPECTION DATE: 4/11/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: OAKLEAF JUNIOR HIGH SCHOOL
 4085 PLANTATION OAKS BOULEVARD
 ORANGE PARK, FL 32065

INSPECTOR SIGNATURE:  4/6/2022
 BUILDING INSPECTION DATE:
 PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed Annual Inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: ORANGE PARK JUNIOR HIGH - 0361
1500 GANO AVENUE
ORANGE PARK, FL 32073

INSPECTOR SIGNATURE: *Robert E...*
BUILDING INSPECTION DATE: 4/13/2022
PORTABLE INSPECTION DATE:


Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Fire extinguishers missing in gym				X
			Fire extinguisher cabinet broken				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE:
BUILDING INSPECTION DATE:
PORTABLE INSPECTION DATE:



3/1/2022

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: WILKINSON JUNIOR HIGH - 0371
 5025 COUNTY ROAD 218
 MIDDLEBURG, FL 32068

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed Annual Inspection				

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101**

AND

**FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58**

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: CLAY HIGH SCHOOL - 0341
2025 HIGHWAY 16 WEST
GREEN COVE SPRINGS, FL 30243

**INSPECTOR SIGNATURE: *Noreen Eardley*
BUILDING INSPECTION DATE: 4/26/2022
PORTABLE INSPECTION DATE:**

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Fire alarm shows trouble, fail received - 2				X
			Hood fire suppression not required.				X
	708		Fire sprinkler room: fire sprinkler and fire pump shall be brought up to code. No annual certification.				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: FLEMING ISLAND HIGH SCHOOL - 0551
 2233 VILLAGE SQUARE PARKWAY
 FLEMING ISLAND, FL 32003

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101
AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE: *[Signature]*
 BUILDING INSPECTION DATE: 4/20/2022
 PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
	169		Fire extinguisher cabinet loose on wall in corridor near room 157				X
	170		Electrical room storage still in room (cited last years inspection).				X
	205/207		Athletic storage too high (cited last years inspection).				X
	1005		Missing ceiling tiles.				X
	48		Electrical room - storage still in room (cited last years inspection).				X
			Mechanical/electrical - golf cart storage.				X
	296		Elevator: Southside interior lights out.				X
			Textbook/storage: Storage too high (cited last years inspection).				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL - 0311
 900 S. ORCHID AVENUE
 KEYSTONE HEIGHTS, FL 32656

INSPECTOR SIGNATURE: *Heel*
 BUILDING INSPECTION DATE: 2/28/2022
 PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
1	62		Emergency light inoperable (2 years)				X
7	706		Missing ceiling tiles				X
7	705		Broken cover electrical plate				X
7	709		Storage in hallway				X
7	722		Mechanical golf cart storage				X
Gym			Boys and girls locker rooms - no emergency lights (2 years)				X
9	908		Light fixture hanging				X
9	928		Southeast exit blocked with storage				X
9	924		No emergency lights (2 years). Missed label.				X
9	933		Electrical room remove storage (2 years)				X
35			Fryers in concession stand				X
20			Exits blocked				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: MIDDLEBURG HIGH SCHOOL - 0391
3750 COUNTY ROAD 220
MIDDLEBURG, FL 32068

INSPECTOR SIGNATURE:  **Harold**
BUILDING INSPECTION DATE: 3/21/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
	249		Fire alarm has trouble alarm.				X
	199		Wire exposed in conduit box				X
			No fire protection in Ref Wet Box				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION

F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT

F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE:

Arac Eved

BUILDING INSPECTION DATE:

4/5/2022

PORTABLE INSPECTION DATE:

FISCAL YEAR: 2021/2022

DISTRICT: CLAY

FACILITY: OAKLEAF HIGH SCHOOL - 0661

4035 PLANTATION OAKS BOULEVARD

ORANGE PARK, FL 32065

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency <i>Passed Annual Inspection</i>	Facilities	Info Services	Maint.	School

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: ORANGE PARK HIGH SCHOOL - 0252
 2300 KINGSLEY AVENUE
 ORANGE PARK, FL 32073

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE: 
BUILDING INSPECTION DATE: 4/20/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Fire alarm has trouble signal.				X
			Second floor missing smoke doors.				X
	13		Gym emergency exit sign shall be removed. It empty's into storage room.				X
			Propane tank missing no smoking sign. Flammable sign faded.				X

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: ORANGE PARK HIGH SCHOOL W. CAMPUS
2300 KINGSLEY AVENUE
ORANGE PARK, FL 32073

**CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101**

AND

**FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58**

INSPECTOR SIGNATURE: *Wood E. S.*
BUILDING INSPECTION DATE: 4/20/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
18			Storage in hallway.				X
27			Missing dry chemical extinguisher in kitchen.				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101
AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: RIDGEVIEW HIGH SCHOOL - 0431
466 MADISON AVENUE
ORANGE PARK, FL 32065

INSPECTOR SIGNATURE: *Edward*
 BUILDING INSPECTION DATE: 4/12/2022
 PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Fire alarm panel in cafeteria expired 8/2021. Fire alarm has ground fault trouble.				X
			Small deep fryer in gym concessin stand.				X

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

CASUALTY SAFETY & SANITATION INSPECTION

F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT

F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE: 

BUILDING INSPECTION DATE: 3/23/2022

PORTABLE INSPECTION DATE:

FISCAL YEAR: 2021/2022

DISTRICT: CLAY

FACILITY: BANNERMAN LEARNING CENTER - 0111

608 MILL STREET

GREEN COVE SPRINGS, FL 32043

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: FOOD SERVICES/OPERATIONS
 925 CENTER STREET
 GREEN COVE SPRINGS, FL 32043

INSPECTOR SIGNATURE: *Arac E...*
BUILDING INSPECTION DATE: 4/26/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: MIDDLEBURG TRANSPORTATION
 3674 CR 200
 MIDDLEBURG, FL 32068

INSPECTOR SIGNATURE: *Horie*
BUILDING INSPECTION DATE: 3/21/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Storage in electrical room bus fuel depot				X

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: PURCHASING DEPT./FUEL ISLAND
800 CENTER STREET
GREEN COVE SPRINGS, FL 32043

INSPECTOR SIGNATURE: 

INSPECTION DATE: 4/26/2022

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

**COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5**

**CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101**

AND

**FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58**

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: INSURANCE/PAYROLL DEPARTMENT
800 WALNUT STREET
GREEN COVE SPRINGS, FL 32043

INSPECTOR SIGNATURE: *Howe E. S.*

BUILDING INSPECTION DATE: 4/26/2022

PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

INSPECTOR SIGNATURE: *David E. S.*
BUILDING INSPECTION DATE: 4/26/2022

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

BUILDING INSPECTION DATE:
PORTABLE INSPECTION DATE:

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: FINANCE/ACCOUNTS PAYABLE/I.T.
11 GREEN STREET
GREEN COVE SPRINGS, FL 32043

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

FISCAL YEAR: 2021/2022
 DISTRICT: CLAY
 FACILITY: H. C. LONG ADMINISTRATION
 23 GREEN STREET
 GREEN COVE SPRINGS, FL 32043

INSPECTOR SIGNATURE: *Steve Earl*
BUILDING INSPECTION DATE: 4/26/2022
PORTABLE INSPECTION DATE:

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: PROFESSIONAL DEVELOPMENT
 800 WALNUT
 GREEN COVE SPRINGS, FL 32043

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND

FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE:
BUILDING INSPECTION DATE:
PORTABLE INSPECTION DATE:

[Handwritten Signature]

4/26/2022

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

CASUALTY SAFETY & SANITATION INSPECTION
F.S. 1013.12, 1013.20 & NFPA 101

AND
FIRE SAFETY INSPECTION REPORT
F.S. 1013.12, 1013.20 & RULE 69A-58

INSPECTOR SIGNATURE: *None*
BUILDING INSPECTION DATE: 4/26/2022
PORTABLE INSPECTION DATE:

FISCAL YEAR: 2021/2022
DISTRICT: CLAY
FACILITY: SUPERINTENDENT BUILDING
 900 WALNUT STREET
 GREEN COVE SPRINGS, FL 32043

Building Number	Room Number	Casualty Safety & Sanitation Deficiency	Fire Safety Deficiency	Facilities	Info Services	Maint.	School
			Passed annual inspection.				