

ANCILLARIES





State Fire Marshal - Inspection Report - OFFICES ORANGE PARK ANNEX

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay
School:	ADMINISTRATIVE OFFICES ORANGE PARK ANNEX
Address:	2300 KINGSLEY AVENUE
Inspection Date:	April 19, 2010
Note:	N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.
 I hereby certify that the required fire drills have been completed as of this inspection date.
 Or
 Acknowledgement N/A.

Primary inspector: Raul Feliciano
 Additional inspector: N/A

Powered by [eGroupWare's CSS Design](#) and the [Bureau of Economic and Business Research](#).



State Fire Marshal - Inspection Report - FOOD SERVICES STORAGE

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay						
School:	FOOD SERVICES STORAGE						
Address:	720 CENTER STREET						
Inspection Date:	March 10, 2010						
Note:	N/A						
Inspectors present							
State:	No	District:	Yes	Local:	No		
Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	NVO	No violations noted this date	95-RELOCATABLE	1	Mar 10, 2010	0	N/A
Statements acknowledged							
I hereby certify that the district has complied with section 1013.12(1)(b), F.S.							Yes
I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.							No
I hereby certify that the required fire drills have been completed as of this inspection date.							Yes
Or							
Acknowledgement N/A.							No
Primary inspector:	larry swanson						
Additional inspector:	N/A						



State Fire Marshal - Inspection Report - ADMINISTRATION

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: HARRIS C LONG ADMINISTRATION
 Address: 23 S GREEN STREET
 Inspection Date: March 23, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0410	SYSTEM NOT PROERLY INSPECTED/MAINTAINED	0-Building N/A -- See notes	1	Mar 23, 2010
N/A	0803	EXTENSION CORD NOT RATED FOR USE	3- PERMANENT	311	Mar 23, 2010
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	4- PERMANENT	4	Mar 23, 2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.


I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Raul Feliciano
Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - TRANSPORTATION

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: KEYSTONE TRANSPORTATION
 Address: 6800 COUNTY ROAD 315
 Inspection Date: December 9, 2009
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cit
N/A	0805	GFCI'S NOT INSTALLED IN WET LOCATIONS	90-RELOCATABLE	CI802	Jan 9, 2010	0
N/A	0499	FIRE ALARM OTHER	90-RELOCATABLE	CI2115	Jan 9, 2010	1
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	90-RELOCATABLE	CI2115	Jan 9, 2010	0

N/A	0204	EMERG LIGHTS NOT OPERATIONAL	90- RELOCATABLE	CI2115	Jan 9, 2010	0
N/A	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	90- RELOCATABLE	CI2115	Jan 9, 2010	0
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	0-Building N/A -- See notes	CI2115	Jan 9, 2010	0

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Kevin Mobley

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - TRANSPORTATION

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: MIDDLEBURG TRANSPORTATION
 Address: 3674 COUNTY ROAD 2
 Inspection Date: February 17, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1- PERMANENT	102	Mar 17, 2010
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	1- PERMANENT	107	Mar 17, 2010
N/A	0704	COMPRESSED GAS CYLINDERS NOT SECURED	1- PERMANENT	bay	Mar 17, 2010
N/A	0704	COMPRESSED GAS CYLINDERS NOT SECURED	1- PERMANENT	Outside	Mar 17, 2010
N/A	NVO	No violations noted	2-	000	Feb 17,

N/A	0204	this date EMERG LIGHTS NOT OPERATIONAL	PERMANENT 3- PERMANENT	Upstairsstairs	2010 Mar 17, 2010
N/A	1202	DANGEROUS CONDITION EXISTS	3- PERMANENT	bay	Mar 17, 2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Stephen Arzie

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - GARAGE

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: SCHOOL BUS GARAGE
 Address: 800 CENTER STREET
 Inspection Date: March 23, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cite
N/A	0211	BLOCKED/LOCKED EXITS	1- PERMANENT	1	Mar 23, 2010	1
N/A	0803	EXTENSION CORD NOT RATED FOR USE	2- PERMANENT	203205	Mar 23, 2010	1
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	0-Building N/A -- See notes	2	Mar 23, 2010	1

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Raul Feliciano



State Fire Marshal - Inspection Report - AG LOT

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: SUPPORT SERVICES AG LOT
 Address: ROBERTS STREET
 Inspection Date: April 23, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	NVO	No violations noted this date	0-Building N/A -- See notes	31	Apr 23, 2010	1	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Raul Feliciano

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - CENTER

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: SUPPORT SERVICES CENTER
 Address: 925 W CENTER STREET
 Inspection Date: April 23, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Note
N/A	0803	EXTENSION CORD NOT RATED FOR USE	0-Building N/A -- See notes	1	Apr 23, 2010	1	N/A
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	R25	Apr 23, 2010	1	must flame cabin flamm comb liquid
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	0-Building N/A -- See notes	R14	Apr 23, 2010	1	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Raul Feliciano

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.