



SENIOR HIGH SCHOOLS



Clay

High School



FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0013



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: CLAY HIGH SCHOOL
2025 HIGHWAY 16 WEST
GREEN COVE SPGS., FLORIDA 32043

INSPECTION DATE: OCTOBER 12, 2010

Ted Smeatford
INSPECTOR'S SIGNATURE

10-12-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	102	MISSING OCCUPANCY LOAD SIGN		X						FBC 423.14.2.2
2	233	SWITCH PLATE MISSING		X						NEC 110
3A	329	DESKS STORED IN ELECTRICAL ROOM		X						NEC.90
3A	326	STORE MATERIAL TOO HIGH		X						69A-58.199
3B	304	PANDUIT COVER MISSING BOTH ENDS OF ROOM - ELECTRICAL		X						NEC 110
3C		OK								
3D	396	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
4		OK								
5		OK								
6		OK								
11	1114	OUTLET COVER BROKEN		X						NEC 110
11	1108	EXIT BLOCKED		X						69A-58
11	1109	OUTLET COVER MISSING		X						NEC 110

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0013



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: CLAY HIGH SCHOOL
2025 HIGHWAY 16 WEST
GREEN COVE SPGS., FLORIDA 32043

INSPECTION DATE: OCTOBER 12, 2010

Tom Weather
INSPECTOR'S SIGNATURE

10-12-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
7A		OK								
7B	791	CEILING TILES STAINED AND MISSING		X						FBC 804.2.3
7B	747	NO EMERGENCY EVACUATION SHEET		X						69A-58.1205
7B	756	ROOF DRAIN LEAK	X							
8	805	TWO TOILETS - OUT OF ORDER	X							FBC 403.1
8	835	RISER MISSING TAG/SPRINKLER	X							NFPA 1
8	835	NO EMERGENCY EVACUATION SHEET		X						69A-58.1205
8	822	EXIT LIGHT OUT		X						FBC 1006.3.1
8	820	FIRE ALARM - TROUBLE	X							NFPA 12
9	920	LIGHTS NOT WORKING		X						
9	916	LIGHT NOT WORKING		X						
11	EXT	SOUTHSIDE - COVER MISSING ON SEWER - CLEAN OUT								FPC 301.3

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: CLAY HIGH SCHOOL
2025 HIGHWAY 16 WEST
GREEN COVE SPGS., FLORIDA 32043



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: OCTOBER 12, 2010

Jed Sweetney
INSPECTOR'S SIGNATURE

10-12-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	5A/B	OK								
92	7	OK								
92	8	OK								
92	17	OK								
92	18	OK								
92	19	OK								
92	20	EXTERIOR - ELECTRICAL BOX WIRES EXPOSED	X							NEC 110.26
92	31	OK								
92	32	OK								
92	33	OK								
92	40	WIRES EXPOSED ABOVE ELECTRICAL PANEL	X							NEC 110.26
92	40	NO EMERGENCY LIGHT	X							FBC 423.17.1

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: CLAY HIGH SCHOOL
2025 HIGHWAY 16 WEST
GREEN COVE SPGS., FLORIDA 32043

STATE BOARD OF EDUCATION

**ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"**

INSPECTION DATE: OCTOBER 12, 2010

IN COMPLIANCE WITH

F.S. 1013.12, 1013.20 & NFPA 101

Ted Sweetland
INSPECTOR'S SIGNATURE


10-12-10
DATE



Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	41	INSTALLATION OF WASHER/DRYER INCOMPLETE – VENT IMPROPER	X							FBC 423
92	42	OK								
92	43	OK								
92	44	OK								
92	45	OK								
92	46	OK								
92	47	OK								
92	48	LIGHT @ ENTRY DOOR "RAMP SIDE" NO COVER	X							NEC 110
92	49	OK								
92	51	OK								
92	54	OK								
92	58	OK								

Fleming Island

High School



FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0044

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



FACILITY: FLEMING ISLAND HIGH SCHOOL
2233 VILLAGE SQUARE PARKWAY
FLEMING ISLAND, FLORIDA 32003

INSPECTION DATE: OCTOBER 19, 2010

[Handwritten Signature]
INSPECTOR'S SIGNATURE

10-19-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	125	DOOR CLOSER BROKEN	X							
1	143	CEILING DAMAGED	X							FBC 804.2.3
1	143	FLOOR DRAIN/CONDENSATION LINES "SEPARATE"	X							
1	210	LIGHT OUT	X							FBC 1006.3.1
2		OK								
10		OK								
21		OK								
30		OK								
31		OK								
40		OK								
20		OK								



FISCAL YEAR 2010-2011

**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL
2233 VILLAGE SQUARE PARKWAY
FLEMING ISLAND, FLORIDA 32003

INSPECTION DATE: OCTOBER 19, 2010

[Signature]
 INSPECTOR'S SIGNATURE

10-19-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	10	OK								
92	11	OK								
92	12	EXCESSIVE PAPER ON WALLS		X						69A-58-106
92	12	OUTLET ON NORTH WALL NOT SECURE		X						NFPA 70
92	12	PROJECTOR NOT INSTALLED PROPERLY								FBC 423.14.2.4
92	13	OK								
92	14	OK								
92	15	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.14.2.4
92	20	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.14.2.4
92	21	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.14.2.4
92	22	OK								FBC 423.17.1
92	23	OK								

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0044

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: FLEMING ISLAND HIGH SCHOOL
2233 VILLAGE SQUARE PARKWAY
FLEMING ISLAND, FLORIDA 32003



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: OCTOBER 19, 2010

[Handwritten Signature]
INSPECTOR'S SIGNATURE

10-19-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	24	PROJECTOR NOT INSTALLED PROPERLY			X					FBC 423.14.2.4
92	24	RAMP SLOPE EXCEEDS 1/12	X							FBC 11.4.8
92	25	RAMP SLOPE EXCEEDS 1/12	X							FBC 11.4.8
92	30	EXTENSION CORDS IN PATH OF TRAVEL	X							NFPA 70
92	31	RAMP SLOPE EXCEEDS 1/12	X							FBC 11.4.8
92	32	RAMP SLOPE EXCEEDS 1/12	X							FBC 11.4.8
92	33	OK								
92	34	RAMP SLOPE EXCEEDS 1/12	X							FBC 11.4.8
92	35	OK								
92	40	OK								
92	41	RAMP SLOPE EXCEEDS 1/12	X							FBC 11.4.8
92	42	OK								
92	43	OK								



FISCAL YEAR 2010-2011
COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL
2233 VILLAGE SQUARE PARKWAY
FLEMING ISLAND, FLORIDA 32003

INSPECTION DATE: OCTOBER 19, 2010

[Handwritten Signature]
 INSPECTOR'S SIGNATURE

10-19-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	44	OK								
92	45	OK								
92	46	OK								
92	47	RAMP SLOPE EXCEEDS 1/12	X							FBC 11.4.8
92	48	OK								
92	49	OK								
92	50	OK								
92	51	PROJECTOR NOT INSTALLED PROPERLY				X				NFPA 103.10.4.1
92	51	HEAT DETECTOR HANGING FROM CEILING	X							NFPA 103.10.4.1
92	52	CEILING TILE MISSING		X						FBC 804.2.3
92	53	OK								
92	60	OK								
92	61	OK								



FISCAL YEAR 2010-2011
COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL
2233 VILLAGE SQUARE PARKWAY
FLEMING ISLAND, FLORIDA 32003

INSPECTION DATE: OCTOBER 19, 2010

[Handwritten Signature]
 INSPECTOR'S SIGNATURE

10-19-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	62	PROJECTOR NOT INSTALLED PROPERLY				X				NFPA 103.10.4.1
92	63	OK								
92	64	OK								
92	70	OK								
92	71	OK								
92	72	OK								
92	73	OK								
92	80	OK								
92	81	OK								
92	84	OK								
92	85	OK								
92	86	OK								
92	87	OK								

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0044

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



FACILITY: FLEMING ISLAND HIGH SCHOOL
2233 VILLAGE SQUARE PARKWAY
FLEMING ISLAND, FLORIDA 32003

INSPECTION DATE: OCTOBER 19, 2010


[Handwritten Signature]
INSPECTOR'S SIGNATURE

10/19/10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	90	OK								
92	91	RAMP SLOPE EXCEEDS 1/12	X							FBC 11.4.8
92	92	RAMP SLOPE EXCEEDS 1/12	X							FBC 11.4.8
92	93	OK								
92	94	OK								
92	95	OK								
92	96	OK								

Keystone Heights

Junior/Senior High School



FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0011

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**




FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL
2900 S.W. ORCHID AVENUE
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: OCTOBER 14, 2010

Ed Sweetman
INSPECTOR'S SIGNATURE 10-14-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	180	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.14.2.4
1	180	EXIT STICKER MISSING ON EXTERIOR DOOR		X						FBC 423.17.3
1	119	LIGHT OUT		X						
1	189	EMERGENCY LIGHT OUT		X						69A-58.204
1	189	STORAGE TOO HIGH - 18" DOWN		X						NFPA 101
2	64	WINDOW AC UNIT IT CORNER OF ROOM NOT WORKING	X							
2	64	VENT HOOD NOT PULLING ENOUGH AIR	X							FMC 502.7
2	67	VENT HOOD/LIGHT NOT WORKING PROPERLY	X							FMC 502.7
2	67	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.14.2.4
2	71	REPLACE BROKEN EMERGENCY LIGHT		X						FBC 423.17.1
4	401	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.14.2.4
4	406	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.14.2.4
5	509	STORAGE TOO HIGH - 18" FROM CEILING		X						69A-58



FISCAL YEAR 2010-2011

**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY: 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL
2900 S.W. ORCHID AVENUE
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: OCTOBER 14, 2010

Ted Sweeten
 INSPECTOR'S SIGNATURE 10-14-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
5	539	LP GAS BOTTLE STORED INSIDE		X						NFPA 1
6	607	STORAGE TOO HIGH - 18" FROM CEILING		X						69A-58
6	611B	STOVE EXHAUST MUST BE VENTED TO EXTERIOR	X							FBC 423.15.3
7	715	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.17.1
8		OK								
9	902	EXHAUST FAN DOES NOT SEEM TO WORK		X						FBC 423.15.4
9	911	EXIT BLOCKED - REMOVE IF GYM OCCUPIED FOR GAME		X						NFPA 101
18	10	ROOF TOP FANS OUT OF BALANCE - CLEAN	X							
20	17	EXIT BLOCKED WITH FILING CABINET/EQUIPMENT		X						NFPA 101
20	18	TILE IN BAD SHAPE	X							
35	2	5 GAS BOTTLES STORED IN CONCESSION STAND - REMOVE		X						NFPA 1
35	2A/B	EXHAUST FANS FOR RESTROOMS	X							FBC 423.15.4

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0011

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL
2900 S.W. ORCHID AVENUE
KEYSTONE HEIGHTS, FLORIDA 32656



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: OCTOBER 14, 2010

Tad Sweetman
INSPECTOR'S SIGNATURE

10-14-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	OK								
92	2	OK								
92	3	OK								
92	4	RAMP EXCEEDS 1/12 SLOPE	X							69A-58.204
92	5	OK								
92	6	OK								
92	7	OK								
92	8	OK								
92	9	OK								
92	11	OK								
92	12	OK								
92	13	OK								
92	14	OK								

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0011

**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**



FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL
2900 S.W. ORCHID AVENUE
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: OCTOBER 14, 2010

Ed Sweetser
 INSPECTOR'S SIGNATURE 10-14-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	15	OK								
92	16	OK								
92	17	OK								
92	18	OK								
92	19	OK								
92	20	OK								
92	21	OK								
92	22	OK								
92	23	OK								
92	24	OK								
92	25	OK								
92	26	OK								
92	27	OK								
92	28	OK								



FISCAL YEAR 2010-2011

COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
“CASUALTY SAFETY & SANITATION INSPECTION”
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY: 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL
2900 S.W. ORCHID AVENUE
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: OCTOBER 14, 2010

Ted Sweetland
 INSPECTOR'S SIGNATURE

10-14-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	29	OUTLET COVER MISSING ON NORTH WALL		X						NEC 110
92	30	OUTLET COVER MISSING ON NORTH WALL		X						NEC 110
92	50	OK								
92	51	OK								
92	52	OK								
92	53	OK								
92	54	OK								
92	55	OK								
92	56	OK								
92	57	OK								
92	58	OK								
92	59	OK								
92	60	OK								

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0011

**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**



FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL
2900 S.W. ORCHID AVENUE
KEYSTONE HEIGHTS, FLORIDA 32656


INSPECTION DATE: OCTOBER 14, 2010

Ted Sweatt
 INSPECTOR'S SIGNATURE 10-14-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	61	OK								
92	62	OK								
92	63	OK								
92	64	OK								
92	65	OK								
92	72	OK								
92	74	FIRE ALARM – NO SIREN	X							NFPA 12
92	76	OK – RESTROOM								
92	78	OK								
92	80	OK								
92	82	OK								
92	84	OK								
92	90	OK								
92	91	OK								

Middleburg

High School



FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0019



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**


FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 21, 2010

[Signature]
INSPECTOR'S SIGNATURE

10/21/10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	11	SPRINKLER HEAD TOO HIGH							X	NFPA 13
1	42	REPLAC E LIGHT BALAST		X						
1	122	EXTERIOR LIGHTS NOT ON SWITCHES							X(10/27/10)	
1	138	SWITCHES NOT WORKING							X	
1	144	SPRINKLER HEADS TOO HIGH							X	NFPA 13
1	251	FIRE EXTINGUISHER MISSING		X						NFPA 1
1	238	LIGHT NOT WORKING		X						FBC 1006.3.1
1	229C	DOOR CLOSURE BROKEN	X							
1	222	LENS COVER MISSING		X						NFPA 70
1	272	PAINT STORED IN CLOSET		X						NFPA 101
1	268	LIGHT TOO DIM		X						
1	307	OUTLET COVER BROKEN								NEC 110
1	294	OUTLET COVER MISSING		X						NEC 110
1	313	LIGHT TOO DIM		X						



FISCAL YEAR 2010-2011
COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY: 0019

FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 21, 2010


[Signature]
 INSPECTOR'S SIGNATURE

10-21-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	315	LIGHT OUT		X						FBC 1006.3.1
1	316A	LIGHT OUT		X						FBC 1006.3.1
1	328	SPRINKLER TOO HIGH							X	NFPA 13
1	337A	SPRINKLER TOO HIGH							X	NFPA 13
1	302	WRONG KEY(DOOR BY COACH)		X						
1	366	CEILING COMING DOWN							X	
1	361	EMERGENCY LIGHT OUT		X						FBC 423.17.1
1	361B	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
9		OK								
10		OK								
12		MISSING BUILDING NUMBERS		X						NFPA 1
12		NEEDS EXTERIOR LIGHTS		X						

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0019



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 21, 2010

[Signature]
INSPECTOR'S SIGNATURE

10-21-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	001	STAIRS NOT ATTACHED TO BUILDING	X							FBC 423.27.4
92	5	OK								
92	7	OK								
92	9	OK								
92	31	REPLACE WOOD RAMPS	X					2		
92	32	OK								
92	33	OK								
92	34	OK								
92	35	OK								
92	36	OK								
92	41	OK								
92	42	OK								
92	43	OK								

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0019

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: OCTOBER 21, 2010

[Handwritten Signature]
INSPECTOR'S SIGNATURE

10-21-10
DATE


Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	44	OK								
92	45	OK								
92	46	OK								
92	47	OK								
92	51	OK								
92	52	OK								
92	53	OK								
92	54 A/B	OK								
92	55	OK								
92	60	OK								
92	61	OK								
92	62	OK								
92	63	OK								

FISCAL YEAR 2010-2011


DISTRICT: CLAY FACILITY: 0019

FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 21, 2010


INSPECTOR'S SIGNATURE

10-21-10
DATE



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	64	OK								
92	65	OK								
92	66	OK								
92	67	OK								
92	69	OK								
92	70	OK								
92	71	OK								
92	72	OK								
92	73	OK								
92	74	OK								
92	75	OK								
92	76	OK								
92	77	OK								

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0019

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: OCTOBER 21, 2010


[Handwritten Signature]
INSPECTOR'S SIGNATURE

10-25-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	78	OK								
92	79	OK								
92	80	OK								
92	81	RAMP EXCEEDS 1/12 SLOPE	X					4		FBC 11.4.8
92	82	OK								
92	83	OK								
92	84	RAMP EXCEEDS 1/12 SLOPE	X							FBC 11.4.8
92	85	OK								
92	86	RAMP EXCEEDS 1/12 SLOPE	X					4		FBC 11.4.8
92	87	RAMP EXCEEDS 1/12 SLOPE	X							FBC 11.4.8
92	88	OK								
92	89	OK								
92		OK								

Orange Park

High School



FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0007



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: ORANGE PARK HIGH SCHOOL
2300 KINGSLEY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 26, 2010

Tom Swettenham
INSPECTOR'S SIGNATURE 10-26-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	181h	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
1	181m	FIRE ALARM BREAKER NEEDS LOCK	X							NFPA 13
1	186	OPEN ELECTRICAL BOX AT CEILING	X							NEC 110
1	100	EXIT LIGHT OUT		X						FBC 1006.3.1
1	104	OCCUPANCY SIGN NOT POSTED BY EXIT		X						FBC 423,14,2,2
1	159 a	EXIT LIGHT OUT		X						FBC 423.
1	119	COMPUTER WIRES STRUNG ACROSS CEILING		X						
1	160a	EXIT LIGHT ONLY ONE BULB WORKING		X						FBC 1006.3.1
1	101	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
1	102	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
1	103	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
1	116	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
1	128	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0007

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: ORANGE PARK HIGH SCHOOL
2300 KINGSLEY AVENUE
ORANGE PARK, FLORIDA 32073



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: OCTOBER 26, 2010

Ted Sweetland
INSPECTOR'S SIGNATURE

10-26-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	130	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
1	167a	EXIT LIGHT OUT		X						FBC 1006.3.1
1	800	EXIT LIGHT OUT BY ROOM 204		X						FBC 1006.3.1
1	215	CEILING TILE STAINED - LEAKING		X						FBC 804.2.3
1	211	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
1	224	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
1	223c	STORAGE TOO HIGH IN CLOSET		X						NFPA 1
1	225	SECONDARY EXIT STICKER MISSING AT WINDOW		X						FBC 423.14.2.1
1	227	EXTENSION CORD TO IMPROPER PROJECTOR		X						
1	228	EXTENSION CORD TO IMPROPER PROJECTOR		X						
1	229	EXTENSION CORD TO IMPROPER PROJECTOR		X						
1	219 c	LIGHT COVER MISSING		X						
2	9	EMERGENCY LIGHT OUT		X						FBC 423.17.1

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0007



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: ORANGE PARK HIGH SCHOOL
2300 KINGSLEY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 26, 2010

Paul Sweetland

 INSPECTOR'S SIGNATURE

10-26-10

 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
3	1	EXIT LIGHT BROKEN		X						FBC 1006.3.1
4	5	EXIT LIGHT BROKEN		X						FBC 1006.3.1
4	5C	ROOF LEAK – STAINS		X						
4	13	REMOVE EXIT STICKER/NOT AN EXIT		X						
4	1	EXIT LIGHT BROKEN @ NORTHWEST CORNER		X						FBC 1006.3.1
4	15	BULBS NOT PROTETED		X						NFPA 708 401.3
4	17C	EMERGENCY LIGHT OUT – REST ROOMS		X						FBC 423.17.1
4	17	EMERGENCY LIGHT OUT – REST ROOMS		X						FBC 423.17.1
4	17	BULBS NOT PROTECTED		X						NFPA 708.401.3
4	17	EXIT MARKED ON DOOR – LOCKED TO ROOM 17-E – REMOVE LOCK		X						FBC 1006.3.1
10	100	OCCUPANCY LOAD SIGN MISSING		X						FBC 423.14.2.2
10	102	EMERGENCY LIGHT OUT		X						FBC 423.17.1
10	107	EMERGENCY LIGHT OUT		X						FBC 423.17.1

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0007

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



FACILITY: ORANGE PARK HIGH SCHOOL
2300 KINGSLEY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 26, 2010

Ted Sweetman
INSPECTOR'S SIGNATURE 10-26-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
10	119	LIFT FULL OF TRASH		X						
10	116	OUTLET COVER MISSING BY BACK DOOR		X						NFPA 70 410.1.2
10	116	EXIT LIGHT OUT / EMERGENCY LIGHT OUT		X						FBC 1006.3.1/423.17.1
10	110	EMERGENCY LIGHT OUT		X						FBC 423.17.1
10	132	CEILING TILES MISSING		X						FBC 804.2.3
12	113	EXIT LIGHT MISSING		X						FBC 1006.3.1
12	161A	LIGHT COVERS MISSING		X						NFPA 708.401.3
12	158	LIGHTS HUNG FROM CEILING		X						
12	153	EXIT LIGHT OUT		X						FBC 1006.3.1
12	141	OUTLET COVER MISSING		X						NFPA 70 410.1.2
16		OK								
17		NO EMERGENCY LIGHTS IN WHOLE BUILDING (IMPLEMENT THIS IN REMODEL SCHD. FOR 2011)			X					FBC 423.17.1
17	2	NO EMERGENCY EVACUATION SHEETS		X						FBC 423.14.2.4



FISCAL YEAR 2010-2011

**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION
 INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY: 0007

FACILITY: ORANGE PARK HIGH SCHOOL
2300 KINGSLEY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 26, 2010

Ted Sw. Eatham
 INSPECTOR'S SIGNATURE 10-26-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
17	4	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
17	5	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
17	6	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
17	7	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
18		NO EMERGENCY LIGHTS IN WHOLE BUILDING (IMPLEMENT THIS IN REMODEL SCHD. FOR 2011)			X					FBC 423.17.1
19		NO EMERGENCY LIGHTS IN WHOLE BUILDING (IMPLEMENT THIS IN REMODEL SCHD. FOR 2011)			X					FBC 423.17.1
20	3	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
20	3	NO EMERGENCY LIGHT		X						FBC 423.17.1
20	3	NO EXIT LIGHT		X						FBC 1006.3.1
21	6	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
22	9	EXIT LIGHT OUT		X						FBC 1006.3.1

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0007

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



FACILITY: ORANGE PARK HIGH SCHOOL
2300 KINGSLEY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 26, 2010

Ted Sweatt
INSPECTOR'S SIGNATURE 10-26-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
22	2	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
22	4	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
22	5	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
22	7	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
22	6	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
22	7	NO OCCUPANCY LOAD SIGN		X						FBC 423.14.2.2
27	2	BULBS NOT PROTECTED		X						NFPA 708.401.3
24	22	NO OCCUPANCY LOAD SIGN		X						FBC 423.14.2.2
24	14	BULBS MISSING BY RESTROOMS		X						
24	16	BULBS MISSING BY RESTROOMS		X						
24	1	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
41	1	LENS COVER MISSING		X						NFPA 708 401.3
50		SEE BLEACHER INSPECTION - SAME ITEMS	X							

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0007

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: ORANGE PARK HIGH SCHOOL
2300 KINGSLEY AVENUE
ORANGE PARK, FLORIDA 32073

**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: OCTOBER 26, 2010



Tom Sweatt
INSPECTOR'S SIGNATURE 10-26-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
51	2	EMERGENCY LIGHT OUT		X						FBC 423.17.1
51	9	ICE MAKER LEAKS ONTO FLOOR		X						FBC 423.17.1
51	11	REMOVE FLAMABLE STORAGE BY ELECTRIC		X						NFPA 1
51	15	SHOWER WILL NOT SHUT OFF		X						
51	8	BUBBLES IN FLOOR CREATE A TRIP HAZARD		X						FBC 1006
51	17	EMERGENCY LIGHT BROKEN		X						FBC 423.17.1
51	18	EMERGENCY LIGHT BROKEN		X						FBC 423.17.1
51	17A	PADLOCK ON DOOR - REMOVE		X						NFPA 101
51	19	EXTENSION CORD RUNS FROM RM. 8 - ADD OUTLET	X							NFPA 70
GENERAL		WEST WING - NO EXIT LIGHTS OR EMERGENCY LIGHTS - IMPLEMENT THIS WHEN REMODELED 2011								FBC 423.17.1



FISCAL YEAR 2010-2011

**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY: 0007

FACILITY: ORANGE PARK HIGH SCHOOL
2300 KINGSLEY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 26, 2010

Ted Sweetland
 INSPECTOR'S SIGNATURE

10-26-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	13	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	35	OK								
92	36	OK								
92	37	OK								
92	38	OK								
92	39	OK								
92	40	SMOKE DETECTOR LOOSE AT CEILING	X							NFPA 1(03) 10.4.1
92	49	OK								
92	50	OK								
92	51	OK								
92	52	OK								
92	53	OK								
92	54	PROJECTOR NOT INSTALLED PROPERLY		X						

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0007

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



FACILITY: ORANGE PARK HIGH SCHOOL
2300 KINGSLEY AVENUE
ORANGE PARK, FLORIDA 32073


INSPECTION DATE: OCTOBER 26, 2010

Tom Sweatt
INSPECTOR'S SIGNATURE 10-26-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	54	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	55	OK								
92	56	RAMP EXCEEDS 1/12 SLOPE	X							FBC 11-4.8
92	58	OK								
92	59	EXCESSIVE MATERIAL ON WALLS		X						NFPA 1
92	60	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	61	OK								
92	62	OK								
92	63	CEILING TILES MISSING		X						FBC 804.2.3
92	63	ENTRY LIGHT MISSING COVER		X						NFPA 708 401.3
92	64	ENTRY LIGHT MISSING COVER								NFPA 708 401.3
92	65	OK								
92	66	TRIP HAZARD @ RAMP	X							FBC 11-4.8
92	67	OK								

Ridgerview

High School



FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0022



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: OCTOBER 28, 2010

[Handwritten Signature]
INSPECTOR'S SIGNATURE

10-28-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	124	STAINED CEILING TILES – REPLACE		X						FBC 804.2.3
1	135A	STAINED CEILING TILES – REPLACE		X						FBC 804.2.3
1	137	OUTLET COVER MISSING		X						NEC 110
1	149	OCCUPANCY LOAD SIGN MISSING		X						FBC 423.14.2.2
2		FIRE EXTINGUISHER NOT SIGNED		X						FAC 69A-58
2	207	WIRES EXPOSED –F.A. BOX NEEDS COVER		X						NEC 110
2	225	SMOKE DETECTOR HANGING BY WIRES		X						
2	234	STORAGE IN ELECTRICAL ROOM – REMOVE		X						NFPA 1
2	209	LIGHT NOT WORKING BY LIFT		X						
2	217	CEILING TILES MISSING		X						FBC 804.2.3
2	216	SIGN MISSING @ RESTROOMS		X						FBC 423.14.2
2	211	THUMB LATCH MISSING LOCK		X						FBC423.13.6
2	213	SIGN MISSING BY RESTROOMS		X						FBC 423.14.2
3	302	STAINED CEILING TILES – REPLACE (MOLD FORMING)		X						FBC 804.2.3



FISCAL YEAR 2010-2011

**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY: 0022

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: OCTOBER 28, 2010

[Handwritten Signature]
 INSPECTOR'S SIGNATURE

10-28-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
3	307	TWO GRILLS HANGING DOWN		X						
3	307	FIRE ALARM/SMOKE DETECTOR HANGING		X						
3	315	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
3	315	STAINED CEILING TILES		X						FBC 804.2.3
3	320	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
3	320	CEILING TILES MISSING		X						FBC 804.2.3
3	329	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
3	329	CEILING TILES MISSING		X						FBC 804.2.3
3	333	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
3	353	STAINED CEILING TILES		X						FBC 804.2.3
5	526	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
5	530	NO EMERGENCY EVACUATION SHEETS		X						FBC 423.14.2.4
5	544	SWITCH PLATE BROKEN		X						NEC 110


FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0022

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065


INSPECTION DATE: OCTOBER 28, 2010


INSPECTOR'S SIGNATURE

10-28-10
DATE



Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
5	513	WEEDS GROWN UP AROUND AC YARD		X						
6	632	FIRE ALARM BREAKER NOT LOCKED/LABELED	X							NFPA 13
6	691	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
6	667	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
6	679	EXTENSION CORD TO PROJECTOR – ADD ELEC.OUTLET	X							NEC
7	724	BAD SEWER – GAS SMELL		X						
7	701	SOFFIT HANGING DIOWN OUTSIDE BACK DOOR	X							
8	804	FIRE EXTINGUISHER NOT SIGNED		X						FBC 69A-58
8	827	EMERGENCY LIGHT OUT		X						FBC 423.17.1
8	804	EXIT LIGHT OUT		X						FBC 1006.3.1
8	827	LOCK BROKEN	X							FBC 423.17.1
8	827	REMOVE AEROSAL SPRAY PAINT AND ALL STORAGE MATERIAL		X						NFPA 101
9	924	FIRE EXTINGUISHER NOT SIGNED		X						FAC 69A-58



FISCAL YEAR 2010-2011

COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY: 0022

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: OCTOBER 28, 2010

[Handwritten Signature]
 INSPECTOR'S SIGNATURE

10-28-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
9	924	FIRE EXTINGUISHER NOT IN CABINETS		X						FAC 69A-58
9	914	ROOF LEAK DAMAGE; ROOFING IN PROGRESS			X					
9	924	LENS COVER MISSING		X						NFPA 708.401.3
9	904	LOCK DAMAGED; MISSING SCREW		X						FBC 423.13.1
9	910	CEILING DAMAGED, ROOF IN PROGRESS			X					FBC 804.2.3
9	903	EMERGENCY LIGHT BROKEN OFF WALL		X						FBC 423.17.1
9	938	URINAL OUT OF ORDER	X							
10		FIRE EXTINGUISHER NOT SIGNED		X						FAC 69A-58
10	17	TILE DAMAGED ON FLOOR BY ROOM 37 – COKE MACHINE?		X						
10	6	NO EXIT LIGHT		X						FBC 1006.3.1
10	6	PROJECTOR IMPROPERLY HUNG		X						
10	12	NO EXIT LIGHT		X						FBC 1006.3.1
10	23	RESTROOM LOCKED – REMOVE PADLOCK		X						FBC 423.13.1

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0022

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: OCTOBER 28, 2010

[Handwritten Signature]
INSPECTOR'S SIGNATURE

10-28-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
10	22	NO SIGN ON RESTROOM DOOR		X						FBC 423.14.2.2
11	1101	EMERGENCY LIGHT OUT		X						FBC 423.17.1
11	1102	THUMB LATCH MISSING LOCK	X							FBC 423.13.1
11	1103	THUMB LATCH MISSING LOCK FROM INSIDE RESTROOM	X							FBC 423.13.1
11	1103	URINAL DIVIDERS MISSING		X						
12	1201	EMERGENCY LIGHT OUT		X						FBC 423.17.1
12	1201	BUILDING NUMBERS MISSING		X						FBC 423.14.2.3
13	1301	EMERGENCY LIGHT OUT		X						FBC 423.17.1
13	1305	STORAGE ON TRANSFORMER – REMOVE FROM ELECTRICAL ROOM		X						NEC 110

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0022

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: OCTOBER 28, 2010

[Handwritten Signature]
INSPECTOR'S SIGNATURE

10-28-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	2	COVER MISSING ON FIRE ALARM AT ENTRANCE	X							NFPA 70
92	3	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	4	OK								
92	5	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	6	OK								
92	7	OK								
92	8	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	9	OK								
92	10	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	10	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	11	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	12	OK								

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0022



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: OCTOBER 28, 2010

[Signature]
INSPECTOR'S SIGNATURE

10-28-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	13	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	14	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	21	OK								
92	22	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	23	OK								
92	24	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	25	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	26	OK								
92	27	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	28	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	28	ENTRY DOOR HINGES BROKEN	X							FBC 423.13
92	29	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	30	OK								

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0022



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: OCTOBER 28, 2010

[Handwritten Signature]
 INSPECTOR'S SIGNATURE

10-28-10
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	31	NO EVACUATION SHEET.		X						FBC 423.14.2.4
92	32	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	33	OK								
92	34	OK								
92	41	OK								
92	42	OK								
92	43	RAMP EXCEEDS 1/12 SLOPE	X							FBC 11-4.8
92	44	OK								
92	45	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	46	OK								
92	47	OK								
92	48	OK								
92	49	OK								

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0022



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: OCTOBER 28, 2010

[Handwritten Signature]
INSPECTOR'S SIGNATURE

10/28/10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	50	EXCESSIVE MATERIAL ON WALL/CEILING		X						FBC 423.14.2.6
92	51	OK								
92	52	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	53	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	54	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	61	NAIL IN RAMP - TRIP HAZARD		X						FBC 11-4.8
92	61	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	62	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	63	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	64	OK								
92	65	OK								
92	66	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	67	EMERGENCY LIGHT OUT		X						FBC 423.17.1

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0022



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: OCTOBER 28, 2010

[Handwritten Signature]
INSPECTOR'S SIGNATURE

10/28/10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	68	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	69	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	69	DOOR AT RAMP BROKEN	X							FBC 423.16.10.1
92	69	REMOVE THREE BETWEEN RAMP & BUILDING		X						FBC 423.17.1
92	70	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	71	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	72	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	73	OK								
92	74	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	81	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	82	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	83	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	84	OK								

FISCAL YEAR 2010-2011

DISTRICT: CLAY FACILITY: 0022

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: RIDGEVIEW HIGH SCHOOL
466 MADISON AVENUE
ORANGE PARK, FLORIDA 32065



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: OCTOBER 28, 2010

[Handwritten Signature]
INSPECTOR'S SIGNATURE

10-28-10
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	85	OK								
92	86	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	87	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	88	OK								
92	89	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	90	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	91	OK								
92	92	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	101 A/B	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	103	OK								