

JUNIOR HIGH SCHOOLS



BANNERMAN LEARNING CENTER



State Fire Marshal - Inspection Report

District - Clay

School - R C BANNERMAN LEARNING RESOURCE CENTER

Address - 608 MILL STREET

Inspection date - 2010-11-02

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
	NVO No violations noted this date	0- Building N/A -- See notes	ALL	2010-11-02	0	N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



Primary inspector
Larry, swanson

Additional inspector
N/, A

GREEN COVE SPRINGS JUNIOR HIGH



State Fire Marshal - Inspection Report

District - Clay

School - GREEN COVE SPRINGS JUNIOR HIGH

Address - 1220 BONAVENTURE AVENUE

Inspection date - 2010-11-04

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC1003	0210 EXIT ACCESS NOT MAINTAINED	2-PERMANENT	19	2010-12-04	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	4-PERMANENT	404	2010-12-04	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	3-PERMANENT	14A	2010-12-04	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	4-PERMANENT	421	2010-12-04	0	N/A
FBC1003	0211 BLOCKED/LOCKED EXITS	8-PERMANENT	804	2010-12-04	0	N/A
FBC1003	0211 BLOCKED/LOCKED EXITS	8-PERMANENT	808	2010-12-04	0	N/A
FBC1003	0210 EXIT ACCESS NOT MAINTAINED	9-PERMANENT	919	2010-12-04	0	N/A
FBC423.17.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	92-RELOCATABLE	74	2010-12-04	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	103	2010-12-04	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	106	2010-12-04	0	N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



Primary inspector
larry, swanson

Additional inspector
N, A

LAKE ASBURY JUNIOR HIGH



State Fire Marshal - Inspection Report

District - Clay

School - LAKE ASBURY JUNIOR HIGH

Address - 2851 SANDRIDGE ROAD

Inspection date - 2010-11-09

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
NFPA114.3.2	0211 BLOCKED/LOCKED EXITS	7-PERMANENT	709	2010-12-09	0	N/A
NFPA70	0804 IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	8056	2010-12-09	0	N/A
NFPA70	0804 IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	8047	2010-12-09	0	REMOVE ELECTRIC CORD TO PROJECTOR AND INSTALL A NEW OUTLET
NFPA70	0803 EXTENSION CORD NOT RATED FOR USE	8-PERMANENT	8103	2010-12-09	0	REMOVE ELECTRIC CORD TO PROJECTOR AND INSTALL A NEW OUTLET
NFPA70	0804 IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	8098	2010-12-09	0	REMOVE ELECTRIC CORD TO PROJECTOR AND INSTALL A NEW OUTLET
NFPA70	0804 IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	8090	2010-12-09	0	REMOVE ELECTRIC CORD TO PROJECTOR AND INSTALL A NEW OUTLET
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	8-PERMANENT	8067	2010-12-09	0	N/A
NFPA10314.5.1.2	0210 EXIT ACCESS NOT MAINTAINED	8-PERMANENT	8067	2010-12-09	0	N/A
NFPA101	0901 IMPROPER STORAGE	8-PERMANENT	8131	2010-12-09	0	REMOVE GOLF CARTS
NFPA1	0899 UTILITIES OTHER	92-RELOCATABLE	405	2010-12-09	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	421	2010-12-09	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	423	2010-12-09	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of **No**
this inspection date.

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

LAKESIDE JUNIOR HIGH



State Fire Marshal - Inspection Report

District - Clay

School - LAKESIDE JUNIOR HIGH

Address - 2750 MOODY ROAD

Inspection date - 2010-11-10

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FAC69A-58	0503 MONTHLY INSPECTION NOT DONE/RECORDED	1-PERMANENT	1	2010-12-10	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	21	2010-12-10	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	50	2010-12-10	0	N/A
FBC423.14.2.2	0102 OCCUPANCY LOAD EXCEEDED/NOT POSTED	5-PERMANENT	215	2010-12-10	0	N/A
FBC1006.3.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	8-PERMANENT	804	2010-12-10	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	701	2010-12-10	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	702	2010-12-10	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	745	2010-12-10	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

OAKLEAF JUNIOR HIGH



State Fire Marshal - Inspection Report

District - Clay

School - OAKLEAF SCHOOL

Address - 4085 PLANTATION OAKS BOULEVARD

Inspection date - 2011-01-07

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC1003.3.4 0211	BLOCKED/LOCKED EXITS	92-RELOCATABLE	823	2011-02-07	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

ORANGE PARK JUNIOR HIGH



State Fire Marshal - Inspection Report

District - Clay

School - ORANGE PARK JUNIOR HIGH

Address - 1500 GANO AVENUE

Inspection date - 2010-11-16

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
NFPA70	0802 CIRCUITS NOT LEGIBLE/PERMANENTLY LABELED	0-Building N/A -- See notes	133A	2010-12-16	0	N/A
NFPA70	0807 MISSING/BROKEN RECEPTACLE/FACEPLATE	1-PERMANENT	133A	2010-12-16	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	4-PERMANENT	406	2010-12-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	5-PERMANENT	514	2010-12-16	0	N/A
NFPA70	0807 MISSING/BROKEN RECEPTACLE/FACEPLATE	92-RELOCATABLE	504	2010-12-16	0	N/A
FBC423.18.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	505	2010-12-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	511	2010-12-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	515	2010-12-16	0	N/A
NFPA70	0901 IMPROPER STORAGE	92-RELOCATABLE	702	2010-12-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	703	2010-12-16	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

WILKINSON JUNIOR HIGH



State Fire Marshal - Inspection Report

District - Clay

School - JACK L WILKINSON JUNIOR HIGH

Address - 5025 STATE ROAD 218

Inspection date - 2010-11-08

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
NFPA1-10.1	0410 SYSTEM NOT PROERLY INSPECTED/MAINTAINED	0-Building N/A -- See notes	ALL	2010-12-08 0	FIRE ALARM OUT OF SERVICE
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	8-PERMANENT	828	2010-12-08 0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	8-PERMANENT	829	2010-12-08 0	N/A
NFPA1-10.1	0405 SMOKE DETECTORS INOPERABLE/MISSING	9-PERMANENT	917B	2010-12-08 0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	1A	2010-12-08 0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	1B	2010-12-08 0	N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



Primary inspector
Larry, swanson

Additional inspector
N/, A

CLAY HIGH SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - CLAY HIGH SCHOOL

Address - 2025 HIGHWAY 16 W

Inspection date - 2010-10-12

Notes -

Inspectors present

State No District Yes Local No

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.2 0102	OCCUPANCY LOAD EXCEEDED/NOT POSTED	1-PERMANENT	102	2010-11-12	0	N/A
NEC110 0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	3-PERMANENT	329	2010-11-12	0	N/A
NEC110 0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	3-PERMANENT	304	2010-11-12	0	PANDUIT COVER MISSING AT BOTH ENDS OF ELECTRICAL ROOM
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	3-PERMANENT	396	2010-11-14	0	N/A
69A-58 0211	BLOCKED/LOCKED EXITS	11-PERMANENT	1108	2010-11-14	0	N/A
69A-58.1205 1205	FIRE EVACUATION PLAN(S) NOT POSTED	7-PERMANENT	747	2010-11-12	0	N/A
69A-58.1205 1205	FIRE EVACUATION PLAN(S) NOT POSTED	8-PERMANENT	835	2010-11-12	0	N/A
FBC1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	8-PERMANENT	822	2010-11-12	0	N/A
FBC423171 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	40	2010-11-12	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

FLEMING ISLAND HIGH SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - FLEMING ISLAND SENIOR HIGH

Address - 2233 VILLAGE SQUARE PARKWAY

Inspection date - 2010-10-19

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC804.2.3	0799 BUILDING SERVICES OTHER	1-PERMANENT	143	2010-11-19	0	CEILING DAMAGED
FBC1006.3.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	210	2010-11-19	0	N/A
69A-58.106	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	92-RELOCATABLE	12	2010-11-19	0	EXCESSIVE PAPER ON WALLS
NFPA70	0807 MISSING/BROKEN RECEPTACLE/FACEPLATE	92-RELOCATABLE	12	2010-11-19	0	OUTLET ON WALL NOT SECURE
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	92-RELOCATABLE	15	2010-11-19	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	92-RELOCATABLE	20	2010-11-19	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	92-RELOCATABLE	21	2010-11-19	0	N/A
NFPA10310.4.1	0899 UTILITIES OTHER	92-RELOCATABLE	24	2010-11-19	0	PROJECTOR NOT INSTALLED PROPERLY
NFPA103.10.4.1	0899 UTILITIES OTHER	92-RELOCATABLE	12	2010-11-19	0	N/A
NFPA10310.4.1	0405 SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	51	2010-11-19	0	HEAT DETECTOR HANGING FROM CEILING
NFPA103.10.4.1	0899 UTILITIES OTHER	92-RELOCATABLE	62	2010-11-19	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector
larry, swanson

Additional inspector
N/, A

KEYSTONE HEIGHTS JUNIOR/SENIOR HIGH



State Fire Marshal - Inspection Report

District - Clay

School - KEYSTONE HEIGHTS JUNIOR/SENIOR HIGH

Address - 900 SW ORCHID AVENUE

Inspection date - 2010-10-14

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	180	2010-11-14	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	189	2010-11-14	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	2-PERMANENT	67	2010-11-14	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	71	2010-11-14	0	N/A
FBC423.17.1	1205	FIRE EVACUATION PLAN (S) NOT POSTED	4-PERMANENT	401	2010-11-14	0	N/A
FBC423.17.1	1205	FIRE EVACUATION PLAN (S) NOT POSTED	4-PERMANENT	406	2010-11-14	0	N/A
NFPA1	0702	LP GAS CYL IMPROPERLY LOCATED/STORED	5-PERMANENT	539	2010-11-14	0	N/A
FBC423.17.1	1205	FIRE EVACUATION PLAN (S) NOT POSTED	7-PERMANENT	715	2010-11-14	0	N/A
NFPA101	0211	BLOCKED/LOCKED EXITS	9-PERMANENT	911	2010-11-14	0	N/A
NFPA101	0211	BLOCKED/LOCKED EXITS	20-PERMANENT	17	2010-11-14	0	N/A
NFPA1	0702	LP GAS CYL IMPROPERLY LOCATED/STORED	35-PERMANENT	2	2010-11-14	0	N/A
NFPA12	0411	HORN/STROBE DEVICE INADEQUATE/INOPERABLE	92-RELOCATABLE	74	2010-11-14	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

MIDDLEBURG HIGH SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - MIDDLEBURG SENIOR HIGH

Address - 3750 STATE ROAD 220

Inspection date - 2010-10-21

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	11	2010-11-21	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	144	2010-11-21	0	N/A
NFPA1	0506	EXTINGUISHER MISSING FROM LOCATION	1-PERMANENT	251	2010-11-21	0	N/A
NFPA101	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	1-PERMANENT	272	2010-11-21	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	328	2010-11-21	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	337A	2010-11-21	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	361	2010-11-21	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	351B	2010-11-21	0	N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**


Primary inspector
 larry, swanson

Additional inspector
 N/, A

ORANGE PARK HIGH SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - ORANGE PARK SENIOR HIGH

Address - 2300 KINGSLEY AVENUE

Inspection date - 2010-11-26

Notes -

Inspectors present

State No District Yes Local No

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	181h	2010-12-15	0	N/A
FBC1006.3.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	100	2010-11-29	0	N/A
FBC423.17.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	159A	2010-11-29	0	N/A
FBC423.17.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	160A	2010-11-29	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	101	2010-11-29	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	102	2010-11-29	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	103	2010-11-29	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	116	2010-11-29	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	128	2010-11-29	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	129	2010-11-29	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	130	2010-11-29	0	N/A
FBC1006.3.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	167A	2010-11-29	0	N/A
FBC1006.3.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	800	2010-11-29	0	N/A
FBC804.2.3	0399 PROTECTION OTHER	1-PERMANENT	215	2010-11-29	0	CEILING TILE STAINED - LEAK?
FBC423.14.2.1	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	211	2010-11-21	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	224	2010-11-29	0	N/A

FBC423.14.2.1	0209	RATED OPENINGS NOT MAINTAINED	1-PERMANENT	225	2010-11-29	0	SECONDARY EXIT STICKER MISSING AT WINDOW
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	9	2010-11-29	0	N/A
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	3-PERMANENT	1	2010-11-29	0	N/A
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	4-PERMANENT	5	2010-11-29	0	N/A
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	4-PERMANENT	1	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	4-PERMANENT	17c	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	4-PERMANENT	17	2010-11-29	0	N/A
FBC1006.3.1	0211	BLOCKED/LOCKED EXITS	4-PERMANENT	17	2010-11-29	0	N/A
FBC423.14.2.2	0102	OCCUPANCY LOAD EXCEEDED/NOT POSTED	10-PERMANENT	100	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	10-PERMANENT	102	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	10-PERMANENT	107	2010-11-29	0	N/A
FBC423.17.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	10-PERMANENT	116	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	10-PERMANENT	110	2010-11-29	0	N/A
FBC1006.3.1	0299	MEANS OF EGRESS OTHER	12-PERMANENT	113	2010-11-29	0	EXIT LIGHT MISSING
FBC1006.3.1	0299	MEANS OF EGRESS OTHER	12-PERMANENT	153	2010-11-29	0	EXIT LIGHT MISSING
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	0-Building N/A -- See notes	1	2010-11-26	0	Building # 17 needs to be added.
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	0-Building N/A -- See notes	2	2010-11-29	0	PLEASE ADD BUILDING 17
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	0-Building N/A -- See notes	4	2010-11-29	0	PLEASE ADD BUILDING 17
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	0-Building N/A -- See notes	6	2010-11-29	0	PLS. ADD BUILDING 17
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	0-Building N/A -- See notes	5	2010-11-29	0	PLS. ADD BUILDING 17
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	0-Building N/A -- See notes	7	2010-11-29	0	PLS. ADD BUILDING 17
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	18-PERMANENT	00	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	19-PERMANENT	00	2010-11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	20-PERMANENT	3	2010-11-29	0	N/A
FBC423.14.2.4	0204	EMERG LIGHTS NOT	20-	3	2010-	0	N/A

		OPERATIONAL	PERMANENT		11-29		
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	20- PERMANENT	3	2010- 11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	21- PERMANENT	6	2010- 11-29	0	N/A
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	22- PERMANENT	9	2010- 11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	22- PERMANENT	2	2010- 11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	22- PERMANENT	4	2010- 11-22	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	22- PERMANENT	5	2010- 11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	22- PERMANENT	6	2010- 11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	22- PERMANENT	7	2010- 11-22	0	N/A
FBC423.14.2.2	0102	OCCUPANCY LOAD EXCEEDED/NOT POSTED	24- PERMANENT	22	2010- 11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	24- PERMANENT	1	2010- 11-29	0	N/A
FBC1006.3.1	0806	OUTSIDE GFCI'S IMPROPERLY PROTECTED	41- PERMANENT	1	2010- 11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	51- PERMANENT	2	2010- 11-29	0	N/A
NFPA1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	51- PERMANENT	11	2010- 11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	51- PERMANENT	17	2010- 11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	51- PERMANENT	18	2010- 11-29	0	N/A
NFPA101	0211	BLOCKED/LOCKED EXITS	51- PERMANENT	17A	2010- 11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	0-Building N/A -- See notes	GENERAL	2010- 11-29	0	NO EXIT LIGHT OR EMERGENCY LIGHT; THIS WING IS BEING REMODELED IN 2011.
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	13	2010- 11-29	0	N/A
	0499	FIRE ALARM OTHER	92- RELOCATABLE	40	2010- 11-29	0	SMOKE DETECTOR LOOSE AT CEILING
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92- RELOCATABLE	54	2010- 11-29	0	N/A
NFPA1	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	92- RELOCATABLE	59	2010- 11-29	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**


I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A.

No



Primary inspector
Larry, Swanson

Additional inspector
N/, A

RIDGEVIEW HIGH SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - RIDGEVIEW SENIOR HIGH

Address - 466 MADISON AVENUE

Inspection date - 2010-10-28

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
NEC110	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	1-PERMANENT	137	2010-11-29	0	N/A
FBC423.14.2.2	0102	OCCUPANCY LOAD EXCEEDED/NOT POSTED	1-PERMANENT	149	2010-11-29	0	N/A
FAC69A-58	0503	MONTHLY INSPECTION NOT DONE/RECORDED	2-PERMANENT	00	2010-11-29	0	N/A
NFPA101	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	2-PERMANENT	234	2010-11-29	0	N/A
FBC423.13.6	0299	MEANS OF EGRESS OTHER	2-PERMANENT	211	2010-11-29	0	THUMB LATCH MISSING - LOCK
FBC423	0199	GENERAL REQUIREMENTS	2-PERMANENT	213	2010-11-29	0	SIGN MISSING AT RESTROOMS
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	3-PERMANENT	315	2010-11-29	0	N/A
FBC423.14.2.4	0010	IMMINENT HAZARD	3-PERMANENT	320	2010-11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	3-PERMANENT	329	2010-11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	3-PERMANENT	333	2010-11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	5-PERMANENT	526	2010-11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	5-PERMANENT	530	2010-11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	6-PERMANENT	691	2010-11-09	0	N/A
FAC69A-58	0403	FACP CIRCUIT BREAKER NOT MARKED/SECURED	8-PERMANENT	804	2010-11-29	0	N/A
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	8-PERMANENT	804	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	8-PERMANENT	827	2010-11-29	0	N/A
NFPA101	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	8-PERMANENT	807	2010-11-29	0	N/A
FAC69A-58	0506	EXTINGUISHER MISSING FROM LOCATION	9-PERMANENT	924	2010-11-29	0	N/A
		MONTHLY INSPECTION	9-		2010-		

FAC69A-58	0503	NOT DONE/RECORDED	PERMANENT	924	11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	9-PERMANENT	903	2010-11-29	0	N/A
FBC69A-58	0503	MONTHLY INSPECTION NOT DONE/RECORDED	10-PERMANENT	00	2010-11-29	0	N/A
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	10-PERMANENT	6	2010-11-29	0	N/A
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	10-PERMANENT	12	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	11-PERMANENT	1101	2010-11-29	0	N/A
FBC423.13.1	0199	GENERAL REQUIREMENTS	11-PERMANENT	1102	2010-11-29	0	THUMB LATCH MISSING LOCK
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	12-PERMANENT	1201	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	13-PERMANENT	1301	2010-11-29	0	N/A
NEC110	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	13-PERMANENT	1305	2010-11-29	0	N/A
FBC423.17.1	0408	MANUAL PULL STATION MISSING/INOPERABLE	92-RELOCATABLE	1	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	3	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	5	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	8	2010-11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	10	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	10	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	11	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	13	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	14	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	22	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	24	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	25	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	29	2010-11-29	0	N/A
FBC423.13	0210	EXIT ACCESS NOT MAINTAINED	92-RELOCATABLE	28	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	28	2010-11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	31	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	32	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	45	2010-11-29	0	N/A
FBC423.14.2.6	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	92-RELOCATABLE	50	2010-11-29	0	N/A
		EMERG LIGHTS NOT	92-		2010-		

FBC423.17.1	0204	OPERATIONAL	RELOCATABLE	52	11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	53	2010-11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	54	2010-11-21	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	61	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	62	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	63	2010-11-29	0	N/A
FBC423.17.1	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	63	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	66	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	67	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	68	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	69	2010-11-29	0	N/A
	0210	EXIT ACCESS NOT MAINTAINED	92-RELOCATABLE	69	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	70	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	71	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	72	2010-11-29	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	74	2010-11-21	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	81	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	82	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	83	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	86	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	87	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	89	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	90	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	92	2010-11-29	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	101AB	2010-11-29	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of


this inspection date.

No

(Or)

Acknowledgement N/A.

No


Primary inspector
Larry, Swanson

Additional inspector
N/A