



Bounce!

**Learning
Quest**



Green Gate Springs

Junior High School



FISCAL YEAR 2007-2008

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0001

FACILITY: GREEN COVE SPRINGS JUNIOR HIGH SCHOOL
1220 BONAVENTURE AVENUE
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 7, 2007

[Signature]
INSPECTOR'S SIGNATURE

11-7-07
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	27	DOOR STICKS	X							NFPA 14.5.2
5	545	EXPOSED WIRES	X							NFPA 70 110.12
5	501	LIGHTS OVER BLEACHERS NOT PROTECTED	X							NFPA 70 401.3
5	527	LIGHTS NOT PROTECTED	X							NFPA 70 401.3
5	525	LIGHTS NOT PROTECTED	X							NFPA 70 401.3
5	517	LIGHTS NOT PROTECTED	X							NFPA 70 401.3
5	511	LIGHTS NOT PROTECTED	X							NFPA 70 401.3
5	415A	LENS CRACKED	X							NFPA 70 401.3

FISCAL YEAR 2007-2008

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0001

FACILITY: GREEN COVE SPRINGS JUNIOR HIGH SCHOOL
1220 BONAVENTURE AVENUE
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 7, 2007


[Signature]
INSPECTOR'S SIGNATURE

11-7-07
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	70	OK								
92	104	OK								
92	105	OK								
92	106	OK								
92	107	OK								
92	112	OK								
92	113	OK								

Lake High

Junior High School



FISCAL YEAR 2007-2008

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0025

FACILITY: LAKE ASBURY JUNIOR HIGH SCHOOL
2851 SANDRIDGE ROAD
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 6, 2007

Darrell A. Hutto
INSPECTOR'S SIGNATURE

11-6-07
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
3		OK								
5		OK								
6		OK								
7		OK								
8		OK								

FISCAL YEAR 2007-2008

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0025

FACILITY: LAKE ASBURY JUNIOR HIGH SCHOOL
2851 SANDRIDGE ROAD
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 6, 2007


[Signature]
INSPECTOR'S SIGNATURE

11-6-07
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	401	OK								
92	402	OK								
92	403	OK								
92	404	OK								
92	405	OK								
92	406	OK								
92	407	OK								
92	408	OK								
92	409	OK								
92	410	OK								
92	422	OK								
92	423	OK								

Library

Junior High School



FISCAL YEAR 2007-2008

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY #: 0014

FACILITY: LAKESIDE JUNIOR HIGH SCHOOL
2750 MOODY ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 30, 2007
[Signature]
INSPECTOR'S SIGNATURE DATE 10.30.07

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
5	105	LIGHT COVERS MISSING		X						NFPA 70 401.3
5	116A	ACCESS HOLE MISSING COVER		X						NFPA 70
5	116A	STAIR BLOCKED		X						FBC 423.20.1
5	124	EMERGENCY LIGHT OUT	X							FBC 423.17.1
5	211	UNPROTECTED BULB		X						
5	245	UNPROTECTED BULB		X						
5	216	EMERGENCY LIGHT TEST BUTTON BROKEN	X							FBC 423.17.1
5	221	EMERGENCY LIGHT OUT	X							FBC 423.17.1
5	238	EMERGENCY LIGHT OUT	X							FBC 423.17.1
1		EMERGENCY LIGHT OUT IN ALL CLASSROOMS	X							FBC 423.17.1
1	26	NO EMERGENCY LIGHT	X							FBC 423.17.1
1	8	NO EMERGENCY LIGHT	X							FBC 423.17.1
2	31	EMERGENCY LIGHT OUT	X							FBC 423.17.1

FISCAL YEAR 2007-2008

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES

FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: √ NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY #: 0014

FACILITY: LAKESIDE JUNIOR HIGH SCHOOL
2750 MOODY ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 30, 2007

David L. Brown
INSPECTOR'S SIGNATURE

10-30-07
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2	54	EMERGENCY LIGHT OUT	X							FBC 423.17.1
2	53	EMERGENCY LIGHT OUT	X							FBC 423.17.1
2	53	NO EVACUATION SHEET		X						FBC 423.14.2.4
2	54	EMERGENCY LIGHT OUT	X							FBC 423.17.1
2	40	EMERGENCY LIGHT OUT	X							FBC 423.17.1
2	45	EMERGENCY LIGHT OUT	X							FBC 423.17.1
2	45	NO EVACUATION SHEET		X						FBC 423.14.2.4
3		EMERGENCY LIGHT OUT (GENERAL)	X							FBC 423.17.1
3	70	NO EVACUATION SHEET		X						FBC 423.14.2.4
8	828	LIGHTS OUT		X						FBC 423.17.1

FISCAL YEAR 2007-2008

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY #: 0014


FACILITY: LAKESIDE JUNIOR HIGH SCHOOL
2750 MOODY ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 30, 2007 DATE 10-30-07
INSPECTOR'S SIGNATURE *[Signature]*

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	704	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	706	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	733	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	791/92	TV BLOCKING ELECTRICAL PANEL	X							
92	793	EMERGENCY LIGHT OUT	X							FBC 423.17.1

Orange ~~Is~~ Not

Junior High School



FISCAL YEAR 2007-2008

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: √ NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0016

FACILITY: ORANGE PARK JUNIOR HIGH SCHOOL
1500 GANO AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 15, 2007

Samuel Brown
INSPECTOR'S SIGNATURE

11-15-07
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2	202	ELECTRICAL SHUNT TRIPS NOT LABELED	X							NFPA 70
2	252	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
2	253	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
2	254	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
2	255	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
2	256	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
2	257	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
2	258	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
2	202	ELECTRICAL SHUNT TRIPS NOT LABELED	X							NFPA 70
3	352	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
3	353	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
3	354	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
3	355	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1

FISCAL YEAR 2007-2008

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: √ NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0016

FACILITY: ORANGE PARK JUNIOR HIGH SCHOOL
1500 GANO AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 15, 2007

Denny D. Brown
INSPECTOR'S SIGNATURE 11.15.07
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
3	356	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
3	357	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
3	358	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
4	416	EXIT LIGHT OUT		X						FBC 1006.3.1
4	452	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
4	453	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
4	454	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
4	455	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
4	456	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
4	457	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
4	458	EMERGENCY EXIT LABEL MISSING ON DOORS		X						FBC 423.13.1
5	510	EMERGENCY LIGHT OUT		X						FBC 423.17.1
5	506A	EMERGENCY LIGHT OUT		X						FBC 423.17.1
5	517A	EMERGENCY LIGHT OUT		X						FBC 423.17.1

Williamson

Junior High School



FISCAL YEAR 2007-2008

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0017

FACILITY: WILKINSON JUNIOR HIGH SCHOOL
5025 C.R. 218
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: NOVEMBER 27, 2007

INSPECTOR'S SIGNATURE: *Ed Sweetland* DATE: Nov 27, 2007

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2	220	REMOVE BROKEN LIGHT	X							
3	311	DOORS SWING IN WRONG DIRECTION - USED AS CLASSROOM	X							
3	314A	COVER MISSING ON AC CONTROL		X						
4	409	LIGHT OUT		X						FBC 1006.3.1
4	407	EXCESSIVE COMBUSTABLES ON WALLS								NFPA 70 210
5	503	FIRE ALARM COVER REMOVED		X						NFPA 70 419.12
6	612	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
7	790	FIRE ALARM COVER REMOVED		X						NFPA 70 419.12
8		OK								
9		OK								

FISCAL YEAR 2007-2008

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0017

FACILITY: WILKINSON JUNIOR HIGH SCHOOL
5025 C.R. 218
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: NOVEMBER 27, 2007

INSPECTOR'S SIGNATURE: [Signature] DATE: Nov 27, 2007

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	2	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	3	TRIP HAZARD @ BASE OF RAMP	X							
92	4	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	5	ROTTED WOOD TREAD @ ENTRANCE	X							
92	6	OK								
92	7	OK								
92	8	OK								
92	9	OK								
92	10	OK								
92	11	OK								
92	12	OK								
92	17	OK								
92	18	OK								
92	21	OK								

FISCAL YEAR 2007-2008

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0017

FACILITY: WILKINSON JUNIOR HIGH SCHOOL
5025 C.R. 218
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: NOVEMBER 27, 2007

[Signature]
INSPECTOR'S SIGNATURE

DATE: Nov 27, 2007

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	22	OK								
92	23	OK								
92	24	OK								
92	25	OK								
92	26	OK								
92	27	OK								
92	30	OK								
92	40AB	OK								
92	40	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	41	WOOD SPINDLES MISSING	X							FBC 1013.7
92	41	EMERGENCY LIGHT OUT	X							FBC 423/17.1
92	42	OK								
92	43	OK								
92	46	OK								

