

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0001

FACILITY: GREEN COVE SPRINGS JUNIOR HIGH SCHOOL  
1220 BONAVENTURE AVENUE  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 7, 2012

INSPECTOR'S SIGNATURE: [Signature] DATE: 11-7-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2	21	LIGHT COVER MISSING		X						
3		OK								
4		OK								
5		OK								
6		OK								
7	705	OUTLET COVER MISSING								
8	819	BROKEN TILE AT DOORWAY AND HALF WALL - REPAIR	X							
9		OK								
92	70	EXTENSION CORD THRU CEILING TO PROJECTOR - REMOVE		X						
92	71	OK								
92	74	OK								

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0001

FACILITY: GREEN COVE SPRINGS JUNIOR HIGH SCHOOL  
1220 BONAVENTURE AVENUE  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 7, 2012

*[Signature]*  
INSPECTOR'S SIGNATURE

11-7-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	75	OK								
92	76	OK								
92	103	OK								
92	104	OK								
92	105	OK								
92	106	OK								
92	107	OK								
92	112	OK								
92	113	OK								

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0025

FACILITY: LAKE ASBURY JUNIOR HIGH SCHOOL  
2851 SANDRIDGE ROAD  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 13, 2012

*Ed Swinton*  
INSPECTOR'S SIGNATURE

11-13-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	133	REMOVE ALL CUSTODIAL EQUIPMENT FROM ELECTRICAL ROOM		X						
1	105	REPLACE STAINED CEILING TILES	X	X						
1	108	REPAIR LEAK OR AC (STAINED CEILING TILES)	X	X						
2		OK								
3		OK								
5		OK								
6		OK								
7	706	COVER MISSING EXIT LIGHT		X						
8	8131	REMOVE FERTILIZER FROM MECHANICAL ROOM - 10 BAGS MUST BE REMOVED		X						
8	8131	RED TAG ON SPRINKLER RISER - 5 YEAR INSPECTION?	X							
*		RED TAG ALL SPRINKLER RISERS FOR 5 YEAR INSPECTION	X							

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0025

FACILITY: LAKE ASBURY JUNIOR HIGH SCHOOL  
2851 SANDRIDGE ROAD  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 13, 2012

*Ted Sweetland*  
INSPECTOR'S SIGNATURE 11-13-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	390									
92	391									
92	392									
92	393									
92	394									
92	401									
92	402									
92	403									
92	404									
92	405									
92	406									
92	407									

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0025

FACILITY: LAKE ASBURY JUNIOR HIGH SCHOOL  
2851 SANDRIDGE ROAD  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 13, 2012

*Ed Sweetland*  
INSPECTOR'S SIGNATURE 11-13-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	408	OK								
92	409	OK								
92	410	OK								
92	421	OK								
92	422	OK								
92	423	OK								
92	425	OUT OF SERVICE								
92	427	OK								
92	428	OUT OF SERVICE								
92	430	OK								

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0014

FACILITY: LAKESIDE JUNIOR HIGH SCHOOL  
2750 MOODY ROAD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 15, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 11-15-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	18	EXTENSION CORD THROUGH CEILING		X						
1	26	FAN COVER MISSING		X						
1	26	CEILING TILES MISSING		X						
2	35	TOILET PARTITION NOT BRACED	X							
2	46	CEILING TILES STAINED		X						
2	54	EXTENSION CORD THROUGH CEILING		X						
3	64	CEILING TILE MISSING		X						
3	67C	REPLACE CEILING TILE		X						
5	123	REPLACE CEILING TILE		X						
5	223	ELEVATOR OUT OF ORDER	X							
5	208	NEED LONGER POWER STRIP CORDS FOR COMPUTERS		X						
7	OK									
8	808	EXIT DOOR PANIC HARDWARE BROKEN		X						

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0014

FACILITY: LAKESIDE JUNIOR HIGH SCHOOL  
2750 MOODY ROAD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 15, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 11-15-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
8	814	BROKEN OUTLET COVER		X						
8	819	BLOCKED EXIT		X						
9	914	BROKEN CEILING TILE		X						
9	912	ELECTRIC PANEL BLOCKED		X						
92	701	OK								
92	702	OK								
92	703	OK								
92	704	OK								
92	705	OK								
92	706	OK								
92	707	OK								
92	708	OK								
92	710	OK								

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0014

FACILITY: LAKESIDE JUNIOR HIGH SCHOOL  
2750 MOODY ROAD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 15, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 11-15-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	721	OK								
92	722	OK								
92	723	OK								
92	732	OK								
92	733	OK								
92	734	COVER MISSING ON LIGHTS		X						
92	735	OK								
92	737	COVER MISSING ON LIGHTS		X						
92	745	EMERGENCY LIGHT OUT	X							
92	791	OK								
92	792	OK								
92	793	EMERGENCY LIGHT OUT	X							
92	794	OK								



**FISCAL YEAR 2012-2013**

DISTRICT: CLAY FACILITY: 0048

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT**

FACILITY: OAKLEAF JUNIOR HIGH SCHOOL  
410 OAKLEAF VILLAGE PARKWAY  
ORANGE PARK, FLORIDA 32065



**STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"**

INSPECTION DATE: DECEMBER 5, 2012

**IN COMPLIANCE WITH**

**F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTOR'S SIGNATURE: [Signature] DATE: 12-5-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
3	308	ELECTRICAL OUTLET NEEDS TO BE ADDED - OVERLOADED COMPUTERS	X							
2	229	FIRE SPRINKLER RISER - RED TAG, 5 YEAR INSPECTION ON GAUGE, FIRE DEPARTMENT CONNECTION, AND PLAQUE MISSING	X							
2	227	ON THE MEZANINE, THE CHILLED WATER RETURN LINE IS CONDENSATING OR LEAKING	X							
4	409	CLASSROOM NOT BY DESIGN. DOOR SWINGS WRONG DIRECTION FOR 16 STUDENTS (EITHER MOVE TO NORMAL SIZE CLASSROOM OR CHANGE DOOR SWING)		X						
4	417	CLASSROOM NOT BY DESIGN. DOOR SWINGS WRONG DIRECTION FOR 16 STUDENTS (EITHER MOVE TO NORMAL SIZE CLASSROOM OR CHANGE DOOR SWING)		X						
5	521	FIRE SPRINKLER RISER - 5 YEAR INSPECTION FOR GAUGE, MISSING FIRE DEPARTMENT CONNECTION	X							
92	601	EMERGENCY LIGHT NOT WORKING		X						
92	604	EMERGENCY LIGHT NOT WORKING		X						

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT**

**STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0048

FACILITY: OAKLEAF JUNIOR HIGH SCHOOL  
410 OAKLEAF VILLAGE PARKWAY  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: DECEMBER 5, 2012

DATE: 12/5/12

INSPECTOR'S SIGNATURE: *[Signature]*

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	611	EMERGENCY LIGHT NOT WORKING		X						
92	612	EMERGENCY LIGHT NOT WORKING		X						
92	705	EMERGENCY LIGHT NOT WORKING		X						
92	709	EMERGENCY LIGHT NOT WORKING		X						
92	710	EMERGENCY LIGHT NOT WORKING		X						
92	715	EMERGENCY LIGHT NOT WORKING		X						
92	821	EMERGENCY LIGHT NOT WORKING		X						
92	823	EMERGENCY LIGHT NOT WORKING		X						
92	824	EMERGENCY LIGHT NOT WORKING		X						
92	602	OK								
92	603	OK								
92	605	OK								
92	607	OK								

**FISCAL YEAR 2012-2013**

DISTRICT: CLAY FACILITY: 0048

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT**

FACILITY: OAKLEAF JUNIOR HIGH SCHOOL  
410 OAKLEAF VILLAGE PARKWAY  
ORANGE PARK, FLORIDA 32065

**STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"**

INSPECTION DATE: DECEMBER 5, 2012

**IN COMPLIANCE WITH**

**F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 12-5-12



Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	608	OK								
92	609	OK								
92	610	OK								
92	613	OK								
92	614	OK								
92	615	OK								
92	616	OK								
92	617	OK								
92	618	OK								
92	619	OK								
92	620	OK								
92	704	OK								
92	706	OK								

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0048

FACILITY: OAKLEAF JUNIOR HIGH SCHOOL  
410 OAKLEAF VILLAGE PARKWAY  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: DECEMBER 5, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: *12.5.12*

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	707	OK								
92	708	OK								
92	711	OK								
92	712	OK								
92	713	OK								
92	606	NO EMERGENCY EVACUATION SHEET		X						
96	622	OK								
96	808	OK								
92	714	OK								
92	716	OK								
92	807	OK								
92	809	OK								
92	810	OK								

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0048

FACILITY: OAKLEAF JUNIOR HIGH SCHOOL  
410 OAKLEAF VILLAGE PARKWAY  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: DECEMBER 5, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: *12-5-12*

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	811	OK								

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0016

FACILITY: ORANGE PARK JUNIOR HIGH SCHOOL  
2750 MOODY ROAD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 27, 2012

*Ed Swanton*  
INSPECTOR'S SIGNATURE

11-27-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	123A	ELECTRICAL PANEL RB - KNOCKOUT MISSING	X							
2	204	EMERGENCY EVACUATION SHEET MISSING		X						
3		OK								
4		OK								
5	517A	2 EMERGENCY LIGHTS OUT		X						
5	517A	EXIT LIGHT DAMAGED	X							
6		OK								
92	501	EMERGENCY LIGHT NOT WORKING		X						
92	503	EMERGENCY LIGHT NOT WORKING		X						
92	503	NO EMERGENCY EVACUATION SHEET		X						
92	504	ELECTRICAL PANEL MISSING KNOCKOUT	X							
92	504	EMERGENCY LIGHT NOT WORKING		X						
92	505	OK								

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0016

FACILITY: ORANGE PARK JUNIOR HIGH SCHOOL  
2750 MOODY ROAD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 27, 2012

*[Signature]*  
INSPECTOR'S SIGNATURE

11-27-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	510	OK								
92	511	OK								
92	514	OK								
92	515	OK								
92	516	OK								
92	703	OK								
92	704	OK								
92	708	WOOD RAMP IN POOR CONDITION		X						
92	712	WIRES EXPOSED/LIGHT CLOSET	X							
92	507	EMERGENCY LIGHT OUT		X						
92	702	EMERGENCY LIGHT OUT		X						
92	710	EMERGENCY LIGHT OUT		X						
92	508	EMERGENCY EVACUATION SHEET MISSING		X						

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0016

FACILITY: ORANGE PARK JUNIOR HIGH SCHOOL  
2750 MOODY ROAD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 27, 2012

*Tom McArthur*  
INSPECTOR'S SIGNATURE

11-27-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	509A	EMERGENCY EVACUATION SHEET MISSING		X						
92	706	LIGHT COVER MISSING GIRLS RESTROOM		X						



**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0017

FACILITY: WILKINSON JUNIOR HIGH SCHOOL  
5025 COUNTY ROAD 218  
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: NOVEMBER 8, 2012

*[Signature]*  
INSPECTOR'S SIGNATURE

11-8-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
3		OK								
4		OK								
5		OK								
6	604	REMOVE EXIT LIGHT	X							
6	607	NO EVACUATION SHEET		X						
7		OK								
8	808	REMOVE CABINETS BLOCKING EXIT		X						
8	814	OPEN BOX - WIRE EXPOSED CLOCK OUTLET	X							
9		OK								

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0017

FACILITY: WILKINSON JUNIOR HIGH SCHOOL  
5025 COUNTY ROAD 218  
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: NOVEMBER 8, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 11-8-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	2	OK								
92	3	OK								
92	4	OK								
92	5	OK								
92	6	OK								
92	7	OK								
92	8	OK								
92	9	OK								
92	10	OK								
92	11	OK								
92	12	OK								
92	17	OK								
92	18	OK								

**FISCAL YEAR 2012-2013**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0017

FACILITY: WILKINSON JUNIOR HIGH SCHOOL  
5025 COUNTY ROAD 218  
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: NOVEMBER 8, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 11-8-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	21	OK								
92	22	OK								
92	23	OK								
92	24	OK								
92	25	OK								
92	26	OK								
92	27	OK								
92	30	OK								
92	40	OK								
92	41	OK								
92	42	OK								
92	43	OK								
92	44	OK								

**FISCAL YEAR 2012-2013**


**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0017

FACILITY: WILKINSON JUNIOR HIGH SCHOOL  
5025 COUNTY ROAD 218  
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: NOVEMBER 8, 2012

INSPECTOR'S SIGNATURE:  DATE: 11-8-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	46	OK								
92	48	OK								
92	96	OK								