Munderbott





	DISTRICT: CLAY FACILITY #: 0042
	FACILITY: THUNDERBOLT ELEMENTARY SCHOOL
	2020 THUNDERBOLT ROAD ORANGE PARK, FLORIDA 32003
	INSPECTION DATE: FEBRUARY 8, 2007
	Larry 1. Juan 3/8/07
,	/INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	111,	EMERGENCY EVACUATION SHEET		Х						FBC 423.14.2.4
1	111	BREAKER KNOCKOUT MISSING		X						NFPA – 70
1	305	WET ROOF TILES - ROOF LEAK	Х							
2	247	OCCUPANCY LOAD SIGN MISSING - 86 PEOPLE		×						FBC 423.14.2.2
2	231	OCCUPANCY LOAD SIGN MISSING - 360 PEOPLE		Х						FBFC 423.14.2.2
i pe										



DISTRICT:_	<u>CLAY</u> FA	ACILITY #:	0042
FACILITY:	THUNDERBOLT EL	EMENTARY	SCHOOL
	2020 THUNDERBO	LT ROAD	
	ORANGE PARK, FL	ORIDA 3200	3
INSPECTIO	N DATE: FEBRUA	RY 8, 2007	
X and	11 hours		1/4/10
1000	R'S SIGNATURE		

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	701	ок								
92	703	OK								
92	704	ОК								
92	705	ОК								
92	706	ОК								
92	707	ОК								
92	708	ок								
92	709	ОК								
92	710	ОК								
92	711	ОК								
92	721	ОК								
92	722	ОК								
92	723	ОК								
92	724	OK								



	DISTRICT: CLAY FACILITY #: 0042
	FACILITY: THUNDERBOLT ELEMENTARY SCHOOL 2020 THUNDERBOLT ROAD
	ORANGE PARK, FLORIDA 32003
	INSPECTION DATE: FEBRUARY 8, 2007
1/	Larrett hom 3/8/07
V	NSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	725	270K								
92	727	ОК								
92	728	ок							:	
92	729	ОК								
92	730	ок								
92	731	OK								
92	732	ок								
92	733	ОК								
92	735	ОК								
92	737	ОК								
92	738	ОК								
92	739	ОК								
92	740	ок								
92	741	OK								



FISCAL YEAR 2006-2007

FACILITY: THUNDERBOLT ELEMENTARY SCHOOL **2020 THUNDERBOLT ROAD**

COMPREHENSIVE SAFETY INSPECTION REPORT STATE BOARD OF EDUCATION **ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5** "FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN **COMPLIANCE WITH** F.S. 1013.12, 1013.20 & NFPA 101

INSPECTOR'S SIGNATURE

INSPECTION DATE: FEBRUARY 8, 2007


ORANGE PARK, FLORIDA 32003

DISTRICT: CLAY

FACILITY #: 0042

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	742	ок								
92	743	ок								
92	744	ок								
92	702	REMOVE EXIT CORD TO COMPUTER		X						NFPA 70
92	726	KNOCK OUT MISSING ELECTRICAL BOX EXT. BY RAMP	х							NFPA 70
92	734	DOOR BY STAIRS STICKS		X						

Types



DISTRICT:		/# : 0040
FACILITY:	TYNES ELEMENTARY SC	HOOL
	1550 TYNES BOULEVARD)
	MIDDLEBURG, FLORIDA	
\wedge		
INSPECTION	DN DATE! FEBRUARY 13.	2007
4	/// /	. / /
Tan.	14 Duran	2/12/10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	144	OCCUPANCY LOAD SIGN MISSING - 80 PEOPLE		Х						FBC 423.14.2.2
4	ALL	FIRE EXTINGUISHER NOT SIGNED IN HALL		X						69A-58 FAC
4	414	EMERGENCY EVACUATION SHEET MISSING		Х						FBC 423.2.4

|--|

	DISTRICT: CLAY FACILITY #: 0040
	FACILITY: TYNES ELEMENTARY SCHOOL
	1550 TYNES BOULEVARD
	MIDDLEBURG, FLORIDA 32068
	INSPECTION DATE: FEBRUARY 13, 2007
/	Harry 5/13/17
,	INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	ок								
92	2	ОК								Maria de la companya
92	3	ОК								
92	4	ОК								
92	5	ОК								
92	6	OK								
92	7	ОК								
92	10	ОК								
92	22	ОК								
92	23	OK								ALC:
92	24	ок								
92	25	OK								
92	26	ОК								
92	27	OK								

|--|

FACILITY: TYNES ELEMENTARY SCHOOL

1550 TYNES BOULEVARD

MIDDLEBURG, FLORIDA 32068

COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

INSPECTION DATE! FEBRUARY 13, 2007

DISTRICT: CLAY FACILITY #: 0040

INSPECTOR'S SIGNATURE DAT

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	30	ОК								
92	41	OK								
92	61	ОК								
92	62	ОК								
92	63	ОК								
92	64	ОК								
92	65	ОК								
92	66	ОК								
92	67	ОК								
92	68	OK								
92	8	EMERGENCY LIGHT NOT WORKING		Х						FBC 423.17.1
92	43	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1

W. E. Cherry





DISTRICT; CLAY FACILITY#: 0006
FACILITY: W.E. CHERRY ELEMENTARY SCHOOL 420 EDSON DRIVE ORANGE PARK, FLORIDA 32073
INSPECTION DATE: FEBRUARY 16, 2007 South Mans DATE INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2	77	EMERGENCY LIGHT OUT		Х						FBC 423.17.1
3	55	OCCUPANCY LOAD SIGN MISSING		X						FBC 423.14.2.2
3	64	LIGHT COVER MISSING		Х						NFPA – 70
3	66	EMERGENCY LIGHT OUT		X						FBC 423.17.1
4	12A	ROOF LEAK – PAINT PEELING	Х							
4	14A	ROOF LEAK – PAINT PEELING	X							
4	13	CEILING TILES MISSING		Х						FBC 803.2
4	68	EMERGENCY LIGHT OUT		X						FBC 423.17.1



·············	DISTRICT: CLAY FACILITY #: 0006
	FACILITY: W.E. CHERRY ELEMENTARY SCHOOL
	420 EDSON DRIVE
	ORANGE PARK, FLORIDA 32073
	INSPÈCTION DATE: FEBRUARY 16, 2007
	Land S/16/01
/	INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	26	ок								
92	27	OK:								
92	29	ок								
92	30	OK								
92	32	ок							of estimate to hear power to	
92	33	ок								
92	34	ок								
92	34A	ОК								
92	34B	ОК								
92	36	ок								
92	38	ОК								
92	39	OΚ								
92	40	ОК								
92	42A	ОК						Herie		



FISCAL YEAR 2006-2007

	DISTRICT: CLAY FACILITY #: 0006
	FACILITY: W.E. CHERRY ELEMENTARY SCHOOL
	420 EDSON DRIVE
	ORANGE PARK, FLORIDA 32073
	INSPECTION DATE: FEBRUARY 16, 2007
	Hard horas 3/16/0
/	INSPECTOR'S SIGNATURE DATE


Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	42B	ок								
92	43	OK								
92	48	ок								
92	49	OK								
92	50	ок								
92	51	OK								
92	54	ОК								
92	55	OK								
92	59	ок								
92	63	OK								
92	64	ок								
92	31	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	37	HANDRAIL EXTENDS INTO WALK PATH	Х							
92	41	EMERGENCY LIGHT OUT		X						FBC 423.17.1



DISTRICT:	CLAY FAC	31LITY #:00)06
FACILITY:	W.E. CHERRY ELEM	ENTARY SCH	OOL
	420 EDSON DRIVE		
	ORANGE PARK, FLO	RIDA 32073	
INSPECTION	M DATE: FEBRUAR	Y 16, 2007	
		٠	3/11/0
/ arry 7	sur-		<i>3//6/01</i>
✓ INSPECTO	R'S SIGNATURE	DAT	TE '

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	58	EMERGENCY LIGHT NOT SECURED TO WALL		Х						FBC 423.17.1
92	60	EMERGENCY LIGHT OUT		X						FBC 423.17.1

Wilkinson





FISCAL YEAR 2006-2007

DISTRICT: CLAY FACILITY#: 0026
FACILITY: J. L. WILKINSON ELEMENTARY SCHOOL
4965 C.R. 218 MIDDLEBURG, FLORIDA 32068
INSPECTION DATE; FEBRUARY 23, 2007
LANGE TOPS SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper:	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
3 ·	300	LENSE COVER MISSING BY ROOM 301		х						
5	528	EXIT LIGHT OUT		X						FBC 1006.3.1



	DISTRICT: CLAY FACILITY #: 0026
	FACULTY. I I MULKINGON ELEMENTARY COLOGI
	FACILITY: J. L. WILKINSON ELEMENTARY SCHOOL
	4965 C.R. 218
	MIDDLEBURG, FLORIDA 32068
	INSPECTION DATE: /FEBRUARY 23, 2007
/	Turres # h 3/23/07
,	INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. 1	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	ОК								
92	2	OK								
92	3	ОК								
92	4	OK								
92	5	ОК								
92	1:16	OK								
92	7	ОК								
92	8	OK*								
92	9	OK .								
92	10	OK								
92	11	ОК								
92	12	OK								
92	13	ок								
92	14	OK								



COMPREHENSIVE SAFETY INSPECTION REPORT STATE BOARD OF EDUCATION **ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5** "FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN

> **COMPLIANCE WITH** F.S. 1013.12, 1013.20 & NFPA 101

FACILITY:	J. L. WILKINSON ELEMENTARY SCHOOL
	4965 C.R. 218

DISTRICT: CLAY FACILITY# 0026

MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 23, 2007

INSPECTOR'S SIGNATURE

Building	Room	Deficiency Description and Corrective Action Required:	Maint: "M"	Oper. "O"	Fac: "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	15	OK	recentative in the property of the second		den menetalist and market	arango anterno sea muna	strinis in AUSINI Sympth	entilitisiste allistuudise		
92	16	ОК								
92	17	ок								
92	18	OK								
92	19	ок						argum compring the gric		
92	20	OK								
92	31	ок								
92	33	OK								
92	34	ОК								
92	35A	OK		100 Miles						
92	35B	ОК								
92	36	ОК								
92	37	ОК								
92	38	OK								



COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN

COMPLIANCE WITH F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY	FACILITY	/#: 0026	3
The state of the second control of the secon	Control of the president of the second	the second secon	the first terminal and the state of the stat

FACILITY: J. L. WILKINSON ELEMENTARY SCHOOL

4965 C.R. 218

MIDDLEBURG, FLORIDA 32068

INSPECTION DATE, FEBRUARY 23, 2007

INSPECTOR'S SIGNATURE

DATE

Bullding	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	39	OK						EUSAA AAAA AAAA		
92	40	OK								
92	414	ок								
92	2	OK								
92	43	ОК								And the state of t
92	44	OK								
92	45	ОК								
92	46	OK								
92	47	ОК							West fill and all appropriate sources	
92	48	ОК			Franks St.					
92	49	ОК					300 700 000	militar et a de la come	sommer sommer som state of the	
92	50	ОК								
92	51	ОК								
92	52	OK								



FACILITY: J. L. WILKINSON ELEMENTARY SCHOOL

DISTRICT: CLAY FACILITY #: 0026

4965 C.R. 218 MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 23, 2007

INSPECTOR'S SIGNATURE

8/25/1

COMPLIANCE WITH F.S. 1013.12, 1013.20 & NFPA 101

COMPREHENSIVE SAFETY INSPECTION REPORT STATE BOARD OF EDUCATION

ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	61	OK								
92	62	ok								
92	63	ок							Marchine are to commend	
92	64	OK								
92	66	ОК					T Bana nother strong countries	nemojas kamsangas		
92	68	TRIM MISSING @ WALL	X							