Care Asbuily





DISTRICT: CLAY FACILITY #: 0023
FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
GREEN COVE SPRINGS, FLORIDA 32043
INSPECTION DATE: JANUARY 2, 2007
Tod Xiveatland Jan 2, 2007
ÍNSPECTOR'S SIGNATURE DATE

Building	Room.	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	101	EXIT LIGHT NOT WORKING		Х						FBC 423.17.1
1.	128	FIRE ALARM BOX COVER MISSING	X							NFPA 70
1	136	OCCUPANCY LOAD SIGN MISSING		Х						FBC 423.14.2.2
2	217	FIRE ALARM BOX COVER MISSING	X							NFPA 70
2	217	AC CONTROL BOX COVER MISSING	Х							NFPA 70
5	508	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.14.2.4
5	514	EMERGENCY EVACUATION SHEET MISSING		Х						FBC 423.14.2.4
5	537	MALE BATHROOM SIGN MISSING		X						FBC 423.14.2.3



DISTRICT: CLAY FACILITY#: 0023
FACILITY: LAKE ASBURY ELEMENTARY SCHOOL 2901 SANDRIDGE ROAD
GREEN COVE SPRINGS, FLORIDA 32043
INSPECTION DATE: JANUARY 2, 2007
INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint: "M"	Oper. "O"	Fac. "C"	Info: Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	9	92								
92	111	92								
92	12	92								
92	14	92								
92	15	92								
92	16	92								
92	18	92								
92	19.	92								
92	20	92								
⊪ 92 :	39A	92								
92	39B	92								
92	41	92								
92	42	92								
92	43	92								



DISTRICT: CLAY FACILITY#	: 0023
FACILITY: LAKE ASBURY ELEMENTAR	Y SCHOOL
2901 SANDRIDGE ROAD	ODID 4 000 40
GREEN COVE SPRINGS, FL	ORIDA 32043
INSPECTION DATE: <u>JANUARY 2, 2007</u>	,
INSPECTOR'S SIGNATURE	Jan 2, 2007

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper: "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	44	ок								
92	45	OΚ								
92	46	ок								
92	47	OK								
92	48	ок								
92	69	OK								
92	71	ОК								
92	72	OK								
92	73	ОК								
92	74	ок								
92	75	ОК								
92	76	ОК								
92	77	ок								
92	78	OΚ								



DISTRICT: CLAY FACILITY	Y#: 0023
FACILITY, LAKE ACCURAGE EMENT	ADV SCHOOL
FACILITY: <u>LAKE ASBURY ELEMENT</u> 2901 SANDRIDGE ROAD	
GREEN COVE SPRINGS,	FLORIDA 32043
INSPECTION DATE: _JANUARY 2, 20	007
Tod Sweatland	Jan 2, 2007
INSPECTOR'S SIGNATURE	(p)ATE


Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def.	Scheduled for Correction	Rule
								Cited		
92	79	ОК								
92	80	OK								
92	81	ОК								
92	82	OK 1								
92	85	ОК								
92	86	ОК								
92	87	ОК					i			
92	88	OK								
92	89	ок								
92	90	ОК								
92	10	EMERGENCY LIGHT OUT		Х						FBC 423.17.1
92	<u> </u> 13	ENERGENCY EVACUATION SHEET MISSING		×X						FBC 423.14.2.4
92	40	EMERGENCY LIGHT OUT		Х						FBC 423.17.1
92	84	BATHROOM SINK LEAKS @ WALL	X							FBC 423,17.1



DISTRICT: CLAY FACILITY #: 0023
FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
GREEN COVE SPRINGS, FLORIDA 32043
INSPECTION DATE: JANUARY 2, 2007
LOCAL STRUCTURE Jan 2, 2007
INSPECTOR'S SIGNATURE (DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac.	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	96	HANDLE @ DRINKING FOUNTAIN BROKEN	Х							
92	91	OΚ						To the same		
92	92	ок								
92	93	ОК								
92	94	ок								
92	95	OK								
92	97	ок								
92	98	OK T								

CARESIAE





F.S. 1013.12, 1013.20 & NFPA 101

COMPREHENSIVE SAFETY INSPECTION REPORT STATE BOARD OF EDUCATION ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5 "FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN COMPLIANCE WITH

FACILITY: LAKESIDE ELEMENTAR	Y SCHOOL
2752 MOODY AVENUE	
ORANGE PARK, FLORID	OA 32073
INSPECTION DATE: JANUARY 4, 2	007
Sand & Jum	1-4-07
INSPECTOR'S SIGNATURE	DATE '

DISTRICT: CLAY **FACILITY** #: 0015

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac, "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	109	EXIT LIGHT OUT		Х						FBC 1006.3
1	11A	REMOVE EXIT LIGHT		Х						
2	127	EMERGENCY LIGHT OUT		Х						FBC 423.17.1
6	611	FIRE ALARM COVER MISSING		X						NFPA 70 110-26
7	700	FIRE EXTINGUISHER NOT SIGNED		Х						69A-58
7	705	EXIT DOOR STICKS		X						NFPA 14.5.2
7	701	EXCESSIVE STORAGE BY EXIT		X						NFPA 70 110.26
					V September 1					



DISTRICT: CLAY FACILITY#	0015
FACILITY: LAKESIDE ELEMENTARY SO 2752 MOODY AVENUE	
ORANGE PARK, FLORIDA 3 INSPECTION-DATE: JANUARY 4, 2007	2073
INSPECTOR'S SIGNATURE	1. 4.07 DATE

Bullding	Room	Deficiency Description and Corrective Action Required:	Maint.	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times	Scheduled for	Rule
						"I.S."		Def. Cited	Correction	
92	10	ок								
92	11	OK								
92	12	ок .								
92	13	OK								
92	14	ок								
92	15	OK								
92	16	ок								
92	17	OK								
92	18	ок								
92	20	OK								
92	22	ок								
92	23	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	24	EMERGENCY LIGHT OUT		Х						FBC 423.17.1
92	25	OK								



	DISTRICT: CLAY FACILITY#: 0015
	FACILITY: LAKESIDE ELEMENTARY SCHOOL
	2752 MOODY AVENUE
	ORANGE PARK, FLORIDA 32073
	INSPECTION DATE: JANUARY 4, 2007
	Tarult- Ivan 1-4-67
Ϊ	INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	26	ок								
92	27	OK								
92	42A	ок								
92	42B	OK								
92	43	ок								
92	44	OK								
92	45	ок								
92.	46	OK								
92	47	ок								
92	51	OK								

MERAE





	DISTRICT: CLAY FACILITY# 0041
	FACILITY: MCRAE ELEMENTARY SCHOOL
	6770 COUNTY ROAD 315 C
	KEYSTONE HEIGHTS, FLORIDA 32656
	INSPECTION DATE: JANUARY 9, 2007
/	Yarry It Swarm 1-9-07
/	INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint: "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	125	EXIT LIGHT OUT		Х						FBC 423.17.1
2	229	FIRE EXTINGUISHER NOT SIGNED		Х						59A-58
6	614	EXIT LIGHT OUT		Х						FBC 423.17.1



COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

FACILITY:	MCRAE ELEME			
	6770 COUNTY			2
	KEYSTONE HE	<u>=1GH1S, FL</u>	JRIDA 32651	<u>9</u>

DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def.	for Correction	Rule
								Cited		
92	401	ОК						==-		
92	402	0K								
92	403	ок					Lagrana i Sano Februaria	oninger sometromen	Capatrical states their states at	
92	404	OK								
92	405	0K			PROPERTY CONTROL OF THE	ton the transfer of the transfer of	Francisco Constitucio	edoveno nemenschier	John schrollen springer Sens	
92	406	0K day								
92	407	ОК					was deligned the lines	sare three health returns		Pres, Centrinoma, and Designor (Scholath) Chilling Park
.92	408	0K								
92	701	0K				and the second second second second	Partie Propriésament de	School wind in Chryston	to Editori Provinski sandracev Cina	S. Instrument representation of the state of
92	702	0K								
92	703	0K				an we make dealermous so	a the about the effective but	nill hearts considered in the	ia Logialis-Chilochabis-Hallistini	io Parkusaten kwasa shakasateli singkikan si 71 menda 22.2
92	704	0K								
92	705	ОК								er i neveles na senekomana an menangan kanon pantah berapan seria.
-92	706	lok I								



COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

FACILITY: MCRAE ELEMENTARY SCHOOL	
6770 COUNTY ROAD 315 C	
KEYSTONE HEIGHTS, FLORIDA 32656	
INSPECTION DATE: JANUARY 9, 2007	
INSPECTOR'S SIGNATURE DATE	07_

DISTRICT: CLAY FACILITY# 0041

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac.	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	707	ок								
92	708	0K								
92	801	ок								
92	802	0K								
92	803	ОК								
92	804	0K								
92	821	ок								
92	823	oK .								
92	824	EMERGENCY LIGHT OUT		Х						FBC 423.17.1
92	825	loK					fundes (25 febr			
92	826	ок								
92	827	0K								
92	828A	ок								
92	828B	oκ								

Made Duig





DISTRICT: CLAY	FACILITY #: 0009
FACILITY: MIDDLEBURG E 3958 MAIN STRI MIDDLEBURG, I	EET
INSPECTION DATE: JANU	
MULE Home INSPECTOR'S SIGNATURE	Jan 11,2007

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	2	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.14.2.4
1	10	EXHAUST FAN NOT WORKING	X							FBC 423.15.4
2	1	EMERGENCY LIGHT NOT WORKING		Х						FBC 423.17.1
2	3	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
2	3	EMERGENCY EVACUATION SHEET MISSING		Х						FBC 423.14.2.4
2	7	COMMUNICATION BOX OPEN @ CEILING		Х						
3	3	FIRE EXTINGUISHER NOT SIGNED		Х						69A-58
7	37	EXIT LIGHT OUT		X						FBC 1006.3
7	39	EXIT LIGHT OUT		Х						FBC 1006.3
9	101	OCCUPANCY LOAD SIGN MISSING		X						FBC 423.14.2.2
9	101	FIRE EXTINGUISHER NOT SIGNED		X					All and the second seco	69A-58
9	115	EMERGENCY EVACUATION SHEET MISSING		Х						FBC 423.14.2.4
9	118	EMERGENCY LIGHT OUT		X						FBC 423.17.1
9	119			Х						FBC 423.17.1



DISTRICT: CLAY FACILI	TY#. 0009
FACILITY: MIDDLEBURG ELEMEN 3958 MAIN STREET	
MIDDLEBURG, FLORID	
INSPECTION DATE: JANUARY 11	Jan 11 2007
INSPECTOR'S SIGNATURE	DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	23	OK						University of the Control of the Con		
92	24	OΚ								
92	25	ОК			- 1500 to 1500 to 1500 to			5141141-1584-1564-1	W	
92	26	ОК								
92	29	ОК								
92	36	ОК								
92	37	ОК					6	91. 3 Uples (200		
92	38	ОК	je 19							
92	40	ОК								
92	41	OK	or in View 1							
92	42	ОК							N FRANCIS A 28 PRO LUBBIUS	
92	43	OK								
92	57	ОК								
92	64	OK								



DISTRICT: CLAY FACIL	11 Y #: 0009
FACILITY: MIDDLEBURG ELEMEN	TARY SCHOOL
3958 MAIN STREET	
MIDDLEBURG, FLORID	A 32068
INSPECTION DATE: JANUARY 11	, 2007
Tod Sweathout	Jan 11,2007
ÍNSPECTOR'S SIĞNATURE	DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	65A	ОК						And resident district		
92	65B	OK								
92	66	ок				50 S.	13 4 48 6 5 5 6 5 5 C 18 1	Angert des gares		
92	67	OK								
92	68	ОК		Bayeria Bayeria da Su						
92	69	ОК								
92	35	EMERGENCY LIGHT OUT		X	7		Alberta stori da	na wekowa		FBC 423.17.1
92	39	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.14.2.4

Montclair



|--|

DISTRICT: CLAY FACILITY#: 0018
FACILITY: MONTCLAIR ELEMENTARY SCHOOL
2398 MOODY ROAD
ORANGE PARK, FLORIDA 32073
INSPECTION DATE JANUARY 16, 2007
Turel 4. hopes 1-16-07
INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. / "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	126	OCCUPANCY LOAD SIGN MISSING	Х							FBC 1004.3
5	501	NO EMERGENCY EVACUATION SHEET		×						FBC 423.14.2.4
	1.4									



COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN

COMPLIANCE WITH F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0018	

FACILITY: MONTCLAIR ELEMENTARY SCHOOL

2398 MOODY ROAD ORANGE PARK, FLORIDA 32073

INSPECTION DATE JANUARY 16, 2007

NSPECTOR'S SIGNATURE

DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint: "M"	Oper. "O": کر	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	21	ок								
92	22	OK .								
92	23	ОК								
92	25	ОК								
92	26	ОК								
92	27	OK								
92	28	ОК								
92	31	OK								
92	32	ОК								
92	33	OK				12 (12 (12 (12 (12 (12 (12 (12 (12 (12 (Calcut	
92	34	ОК								
92	35	OK								
92	36	ОК								
92	37	OK								




COMPREHENSIVE SAFETY INSPECTION REPORT STATE BOARD OF EDUCATION ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5 "FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN COMPLIANCE WITH F.S. 1013.12, 1013.20 & NFPA 101

FACILITY: MONTCLAIR ELEMENTARY S 2398 MOODY ROAD	
ORANGE PARK, FLORIDA 33 INSPECTION DATE: JANUARY 16, 200	
INSPECTOR'S SIGNATURE	DATE

DISTRICT: CLAY FACILITY #: 0018

Building	Room	Deficiency Description and Corrective Action Required:	Maint: "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rüle
92	38	ок								
92	39	ОК								
92	40 ~	ОК					Bernstring California German	Delossos visionis vai sul		
92	41	OK This								
.92	44	ОК					eracciones majaministico			National experience of the property of the second of the s
92	45	OK								
92	46	ОК			e de source de la commencia de	e Constitue marcania (Albania)		ELI SHARENCE GERBUR VAND	n saaytassassaaraanin	

Orange Mark





COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

FACILITY: ORANGE PARK ELEN	IENTARY SCHOOL
1401 PLAINFIELD AV	
ORANGE PARK, FLO	RIDA 32073
INSPECTION DATE: JANUARY	18, 2007
That weatland	Jan 18,2007
INSPECTOR'S SIGNATURE	DATE

DISTRICT: CLAY FACILITY #: 0004

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. E	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
4	82	EMERGENCY LIGHT OUT		Х				·		FBC 423.17.1
4	83	OCCUPANCY LOAD SIGN MISSING		Χ						FBC 423.14.2
5	16	WATER COMING THROUGH WALL, CARPET WET, GUTTER NEEDED	Х							
7	. 74	EXHAUST FAN NOT WORKING	X							FBC 423.15.4



DISTRICT: CLAY FACI	LITY#: 0004
FACILITY: ORANGE PARK ELEM	ENTARY SCHOOL
1401 PLAINFIELD AVI	ENUE
ORANGE PARK, FLOI	RIDA 32073
INSPECTION DATE: _JANUARY	
Tod weathand	Jan 18,2007
INSPECTOR'S SIGNATURE	(pate '

Building	Room:	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac: "C"	info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	21	ОК								
92	34	OK								
92	35	ок								
92	36	OK								
92	37	ок								
92	38	OK								
92	39	ОК						The State Street, 18 of	Transport Committee (Committee (C	
92	41	OK								
92	42	ОК						Delicações accepanação		
92	43	OK								
92	44	ОК					SSET 2000 1 2 10 2 10 2 10 7 10 10 10 10 10 10 10 10 10 10 10 10 10		E THERESON SHEET AND A	
92	45	ОК								
92	50	ОК					Training property assure	Determine Administration was		
92	51	OK								



COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DEMANG	
FACILITY: ORANGE PARK ELEM	IENTARY SCHOOL
1401 PLAINFIELD AVI	
ORANGE PARK, FLOI	
INSPEÇTION DATE: JANUARY	18, 2007
Toll Sw Entland	Jan 18,2007
INSPECTOR'S SIGNATURE	DĂTE

BIGTRICT CLAY EACH ITY # 0000

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac, #C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	53	ок								
92	54	OK.								
92	22	EMERGENCY LIGHT OUT		Х						FBC 423.17.1