

State Fire Marshal - Inspection Report

District Clay

School ADMINISTRATIVE OFFICES ORANGE PARK ANNEX

Address 2300 KINGSLEY AVENUE

Inspection date 2010-03-24

Notes -

Inspectors present

State No District Yes

Local No

| Ref | Code Violation | Bldg | Room | Comp date | Cited | Notes |
|-----|-----------------------------------|------------------|------|----------------|-------|-------|
| | NVO No violations noted this date | 16- PERMANENT | ALL | 2010- 03-24 | 0 | N/A |
| | NVO No violations noted this date | 17- PERMANENT | ALL | 2010- 03-24 | 0 | N/A |

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A.

No

Primary inspector
larry, swanson

Additional inspector
N/A

State Fire Marshal - Inspection Report

District Clay

School CLAY SUPERINTENDENT'S OFFICE

Address 900 WALNUT STREET

Inspection date 2010-03-10

Notes -

Inspectors present

State No **District Yes** **Local No**

| Ref | Code Violation | Bldg | Room | Comp date | Cited | Notes |
|------------|------------------------------|-------------|------|------------|-------|-------|
| 69A-58.204 | EMERG LIGHTS NOT OPERATIONAL | 3-PERMANENT | 7 | 2010-04-10 | 0 | N/A |

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(OR)

Acknowledgement N/A. **No**

Primary inspector larry, swanson **Additional inspector** N/, A

State Fire Marshal - Inspection Report

District Clay

School FOOD SERVICES STORAGE

Address 720 CENTER STREET

Inspection date 2010-03-10

Notes -

Inspectors present

State No **District Yes** **Local No**

| Ref | Code Violation | Bldg | Room | Comp date | Cited | Notes |
|-----|----------------|-------------------------------|----------------|-----------|------------|-------|
| | NVO | No violations noted this date | 95-RELOCATABLE | 1 | 2010-03-10 | N/A |

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) Yes (b), F.S.

I hereby certify that the local authority having jurisdiction has No complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of Yes this inspection date.

(Or)

Acknowledgement N/A. No

Primary inspector

larry, swanson

Additional inspector

N/A

State Fire Marshal - Inspection Report

District Clay

School HARRIS C LONG ADMINISTRATION

Address 23 S GREEN STREET

Inspection date 2010-03-10

Notes

Inspectors present

State No District Yes Local No

| Ref | Code Violation | Bldg | Room | Comp date | Cited | Notes |
|------------|------------------------------------|------|----------------|------------|-------|----------------------|
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 1- | PERMANENT 100 | 2010-03-10 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 3- | PERMANENT 300 | 2010-04-25 | 0 | N/A |
| 69A-58.299 | 0209 RATED OPENINGS NOT MAINTAINED | 3- | PERMANENT 312 | 2010-04-25 | 0 | WINDOWS PAINTED SHUT |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 3- | PERMANENT 312 | 2010-04-25 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 4- | PERMANENT 404A | 2010-04-25 | 0 | N/A |

Statements acknowledgedI hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No****Primary inspector**
larry, swanson**Additional inspector**
N/A

State Fire Marshal - Inspection Report

District Clay

School KEYSTONE TRANSPORTATION

Address 6800 COUNTY ROAD 315

Inspection date 2010-02-25

Notes -

Inspectors present

State No **District Yes** **Local No**

| Ref | Code Violation | Bldg | Room | Comp date | Cited | Notes |
|------------|----------------------------------------|----------------|------|------------|-------|-------|
| 69A-58.204 | EMERG LIGHTS NOT OPERATIONAL | 91-RELOCATABLE | 95 | 2010-04-25 | 0 | N/A |
| 69A-58.204 | EMERG LIGHTING NOT TESTED/RECS MAINT'D | 91-RELOCATABLE | 2 | 2010-04-25 | 0 | N/A |

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector
larry, swanson

Additional inspector
N/A

State Fire Marshal - Inspection Report

District Clay

School MIDDLEBURG TRANSPORTATION

Address 3674 COUNTY ROAD 2

Inspection date 2010-02-11

Notes -

Inspectors present

State No **District Yes** **Local No**

| Ref | Code Violation | Bldg | Room | Comp date | Cited | Notes |
|-----------------|-----------------------------------------------|----------------|------|------------|-------|------------------------------------------------------------------------------------|
| NPPA10129.3.2.1 | 0103 BLDG CONST/RENOVAT WITHOUT PLAN APPROVAL | 3-PERMANENT | ALL | 2010-04-12 | 0 | SHOP BEING USED AS SPRAY BOOTH. NO PROTECTION, NO VENTILATION, NO FIRE SUPPRESSION |
| 69A-48.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 95-RELOCATABLE | 201 | 2010-04-12 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 95-RELOCATABLE | 601 | 2010-04-12 | 0 | |

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector Larry, swanson **Additional inspector** N/A

State Fire Marshal - Inspection Report

District Clay

School SCHOOL BUS GARAGE

Address 800 CENTER STREET

Inspection date 2010-03-10

Notes -

Inspectors present

State No **District Yes** **Local No**

| Ref | Code Violation | Bldg | Room | Comp date | Cited | Notes |
|------------|-----------------------------------|------|---------------|------------|-------|-------|
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 1- | PERMANENT 11 | 2010-04-10 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 1- | PERMANENT 200 | 2010-04-10 | 0 | N/A |

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector Larry, Swanson **Additional inspector** N/A

State Fire Marshal - Inspection Report

District Clay

School SUPPORT SERVICES AG LOT

Address ROBERTS STREET

Inspection date 2010-03-10

Notes -

Inspectors present

State No District Yes Local No

| Ref | Code Violation | Bldg | Room | Comp date | Cited | Notes |
|-----|----------------|-------------------------------|----------------|-----------|------------|-------|
| | NVO | No violations noted this date | 95-RELOCATABLE | ALL | 2010-03-10 | N/A |

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(OR)

Acknowledgement N/A: **No**

Primary inspector larry/swanson **Additional inspector** N/A

State Fire Marshal - Inspection Report

District Clay
School SUPPORT SERVICES CENTER
Address 925 W CENTER STREET
Inspection date 2010-03-10

Notes -

Inspectors present
State No **District Yes** **Local No**

| Ref | Code Violation | Bldg | Room | Comp date | Cited | Notes |
|------------|-----------------------------------|------|-----------------|------------|-------|-------|
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 1- | PERMANENT 11A | 2010-04-10 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 1- | PERMANENT 15A | 2010-04-10 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 1- | PERMANENT 18 | 2010-04-10 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 2- | PERMANENT 2 | 2010-04-10 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 2- | PERMANENT 9 | 2010-04-10 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 10- | PERMANENT 104 | 2010-04-10 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 10- | PERMANENT 107 | 2010-04-10 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 10- | PERMANENT 115 | 2010-04-10 | 0 | N/A |
| 69A-58.204 | 0204 EMERG LIGHTS NOT OPERATIONAL | 91- | RELOCATABLE 012 | 2010-04-10 | 0 | N/A |

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector larry, swanson **Additional inspector** N/A