

State Fire Marshal - Inspection Report

District - Clay

School - MIDDLEBURG ELEMENTARY

Address - 3958 MAIN STREET

Inspection date - 2009-12-08

Notes -

Inspectors present

State No District Yes Local No

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	2-PERMANENT	1	2010-01-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	3-PERMANENT	2	2010-01-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	7-PERMANENT	55	2010-01-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	7-PERMANENT	35	2010-01-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	7-PERMANENT	36	2010-01-08	0	N/A
69A-58.1308	0802	CIRCUITS NOT LEGIBLE/PERMANENTLY LABELED	92-RELOCATABLE	42	2010-01-08	0	N/A
69A-58.899	0899	UTILITIES OTHER	92-RELOCATABLE	68	2010-01-08	0	N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



Primary inspector
Larry, swanson

Additional inspector
N/, A

State Fire Marshal - Inspection Report

District - Clay

School - MONTCLAIR ELEMENTARY

Address - 2398 MOODY ROAD

Inspection date - 2009-12-10

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	131	2010-01-10	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	4-PERMANENT	407	2010-01-10	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	435	2010-01-10	0	N/A
	1299	OPERATING FEATURES OTHER	92-RELOCATABLE	36	2010-01-10	0	GLOBE MIWSING ON CLOSET LIGHT
69A-58.206	0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	134	2010-01-10	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	5-PERMANENT	507	2010-01-10	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector
larry, swanson

Additional inspector
N/, A

State Fire Marshal - Inspection Report

District - Clay

School - MCRAE ELEMENTARY

Address - 6770 COUNTY ROAD 315

Inspection date - 2009-12-03

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
69A-58.1204	1205 FIRE EVACUATION PLAN(S) NOT POSTED	5-PERMANENT	501	2010-01-13	0	N/A
69A-58.1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	5-PERMANENT	514	2010-01-13	0	N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	407	2010-01-13	0	N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	408	2010-01-10	0	N/A
	0408 MANUAL PULL STATION MISSING/INOPERABLE	92-RELOCATABLE	801	2010-01-13	0	N/A
NVPA70	0411 HORN/STROBE DEVICE INADEQUATE/INOPERABLE	92-RELOCATABLE	803	2010-01-13	0	N/A
69A-58.1205	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	827	2010-01-13	0	N/A
69A-58.1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	92-RELOCATABLE	828	2010-01-13	0	N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**


Primary inspector
 Larry, swanson

Additional inspector
 N/, A

State Fire Marshal - Inspection Report

District - Clay

School - ORANGE PARK ELEMENTARY

Address - 1401 PLAINFIELD AVENUE

Inspection date - 2009-12-17

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
NVO	No violations noted this date	0- Building N/A -- See notes	NA	2009-12-17	0	ALL BUILDINGS/ROOMS OK

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**


Primary inspector
 Larry, swanson

Additional inspector
 N/, A

State Fire Marshal - Inspection Report

District - Clay

School - OAKLEAF VILLAGE ELEMENTARY

Address - 410 OAKLEAF VILLAGE PARKWAY

Inspection date - 2009-12-14

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	500	2010-01-14	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	511	2010-01-14	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	514	2010-01-14	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	700	2010-01-14	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	723	2010-01-14	0	N/A
69A-48.204	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	0-Building N/A -- See notes	909	2010-01-14	0	PLEASE ADD BUILDING 92 - THIS IS A PORTABLE OR RELOCATABLE THAT HAS BEEN ADDED TO OAKLEAF ELEMENTARY SCHOOL THIS YEAR.
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	0-Building N/A -- See notes	913	2010-01-14	0	PLEASE ADD BUILDING 92 - THIS IS A PORTABLE OR RELOCATABLE THAT HAS BEEN ADDED TO OAKLEAF ELEMENTARY SCHOOL THIS YEAR.

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**


Primary inspector
 larry, swanson

Additional inspector
 N/, A

State Fire Marshal - Inspection Report

District - Clay

School - ROBERT M PATERSON ELEMENTARY

Address - 5400 PINE AVENUE

Inspection date - 2010-01-05

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
69A-58.901	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	134	2010-02-11	0	N/A
69A-58.1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	2-PERMANENT	209	2010-02-05	0	N/A
69A-58.899	0399 PROTECTION OTHER	92-RELOCATABLE	25	2010-02-05	0	GLOBE MISSING ON CLOSET LIGHT
69A-58.899	0399 PROTECTION OTHER	92-RELOCATABLE	26	2010-02-05	0	GLOBE MISSING ON CLOSET LIGHT
69A-58-.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	53	2010-02-05	0	N/A
69A-58.1205	1101 COMBUSTIBLE MATERIAL IMPROPERLY STORED	1-PERMANENT	134	2010-02-05	0	N/A
69A-58.1205	1101 COMBUSTIBLE MATERIAL IMPROPERLY STORED	2-PERMANENT	209	2010-02-05	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



Primary inspector
Larry, swanson

Additional inspector
N/, A

State Fire Marshal - Inspection Report

District - Clay

School - RIDEOUT ELEMENTARY

Address - 3065 APALACHICOLA BOULEVARD

Inspection date - 2010-01-06

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
69A-58-202	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	302	2010-02-06	0	N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



Primary inspector
larry, swanson

Additional inspector
N/, A