

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - CLAY HIGH SCHOOL

**Address** - 2025 HIGHWAY 16 W

**Inspection date** - 2010-02-04

**Notes** -

### Inspectors present

**State No**      **District Yes**      **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	3-PERMANENT	303	2010-03-04	0	N/A
FBC1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	4-PERMANENT	340	2010-03-04	0	N/A
fbc1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	4-PERMANENT	401	2010-03-04	0	N/A
NFPA70 0299	MEANS OF EGRESS OTHER	4-PERMANENT	401	2010-03-04	0	N/A
FBC1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	5-PERMANENT	501B	2010-03-04	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	7-PERMANENT	702	2010-03-04	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	7-PERMANENT	706	2010-03-04	0	N/A
NFPA70 0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	11-PERMANENT	1104	2010-03-04	0	N/A
NFPA70 0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	11-PERMANENT	1114	2010-03-04	0	N/A
NFPA70 0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	11-PERMANENT	1124	2010-03-04	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	5A	2010-03-04	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	5B	2010-03-04	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	20	2010-03-04	0	N/A
	1308 BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	92-RELOCATABLE	49	2010-03-04	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	58	2010-03-04	0	N/A

### Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**


I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

---

I hereby certify that the required fire drills have been completed as of **No**  
this inspection date.

(Or)

Acknowledgement N/A. **No**



**Primary inspector**  
Larry, Swanson

---

**Additional inspector**  
N/, A

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - FLEMING ISLAND SENIOR HIGH

**Address** - 2233 VILLAGE SQUARE PARKWAY

**Inspection date** - 2010-02-16

**Notes** -

**Inspectors present**

**State No**      **District Yes**      **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC1006.3.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	57	2010-03-16	0	N/A
FBC1006.3.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	001	2010-03-16	0	N/A
	0199 GENERAL REQUIREMENTS	2-PERMANENT	203	2010-03-16	0	SIGNAGE MISSING AT ENTRANCE TO ROOM
	0199 GENERAL REQUIREMENTS	2-PERMANENT	207	2010-03-16	0	SIGNAGE MISSING AT ENTRANCE TO ROOM
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	22	2010-03-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	23	2010-03-16	0	N/A
FBC423.17.1	1205 FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	24	2010-03-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	30	2010-03-16	0	N/A
fbc423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	30	2010-03-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	33	2010-03-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	42	2010-03-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	43	2010-03-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	44	2010-03-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	45	2010-03-16	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	46	2010-03-16	0	N/A
NFPA70110.26	0804 IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	51	2010-03-16	0	N/A
NFPA70110.26	0804 IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	52	2010-03-16	0	N/A
	EMERG LIGHTS NOT	92-		2010-		

FBC423.17.1	0204	OPERATIONAL	RELOCATABLE	61	03-16	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	62	2010-03-16	0	N/A
NFPA70110.26	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	62	2010-03-16	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	64	2010-03-16	0	N/A
FBC423.20.1	0211	BLOCKED/LOCKED EXITS	92-RELOCATABLE	73	2010-03-16	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	81	2010-03-16	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	82	2010-03-16	0	N/A
FBC423.17.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	92-RELOCATABLE	86	2010-03-16	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	87	2010-03-16	0	N/A

**Statements acknowledged**


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



**Primary inspector**  
larry, swanson

**Additional inspector**  
N/, A

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - CLAY SUPERINTENDENT'S OFFICE

**Address** - 2233 VILLAGE SQUARE PARKWAY

**Inspection date** - 2010-02-16

**Notes** -

**Inspectors present**

**State No**      **District Yes**      **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
fbc1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	10- PERMANENT	081	2010- 03-16	0	N/A
0299	MEANS OF EGRESS OTHER	10- PERMANENT	1019	2010- 04-16	0	Move exit light to Rm. 1019B

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

**Primary inspector**

larry, swanson

**Additional inspector**

N/, A



Ben H. Wortham  
Superintendent of Schools

## SCHOOL DISTRICT OF CLAY COUNTY

925 West Center Street  
Green Cove Springs, Florida 32043

### Telephones

904/284-6500 (GCS) - 904/272-8100 (OP)  
1-888-633-2529 (KH)  
FAX: 904/284-6566 - TDD: 904/284-6584

### BOARD MEMBERS

Carol Vallencourt  
*District 1*  
Carol Studdard  
*District 2*  
Charles Van Zant, Jr.  
*District 3*  
Frank Farrell  
*District 4*  
Lisa Graham  
*District 5*

TO: Sam Ward  
Principal, Fleming Island High School

FROM: Larry F. Swanson  
Director, Code Enforcement Department

DATE: March 15, 2010

RE: 2009-2010 SREF (Casualty, Safety & Sanitation Inspection Report) and Fire Safety  
Inspection Report

Please find attached the above referenced inspection reports.

Those items identified as Maintenance "M" are the responsibility of the Maintenance Department. The school needs to initiate the work orders on these items.


Those items identified as Operations "O" are the school's responsibility to correct. These items should be corrected within the next thirty days.

The school has been assigned the responsibility for light fixtures that are identified as "out", but if the corrections are beyond the school's capabilities, please put in a work order to Maintenance for correction. Many times the lamp or tube just needs to be replaced. The school will issue all work orders for the deficiencies noted.

A completion letter to this department is required within the next thirty days. Should more time be required on a specific item, please note it on the completion letter and include a time certain that the deficiency will be corrected.

Please feel free to contact me at 590-0810, should you have any questions or if I can be of further assistance.

Thank you,



Larry F. Swanson  
Director, Code Enforcement Department

LFS/kpg

Attachments:

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - KEYSTONE HEIGHTS JUNIOR/SENIOR HIGH

**Address** - 900 SW ORCHID AVENUE

**Inspection date** - 2010-02-18

**Notes** -

**Inspectors present**

**State No**            **District Yes**            **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	192	2010-03-16	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	4-PERMANENT	406	2010-03-16	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	4-PERMANENT	410	2010-03-16	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	2-PERMANENT	68	2010-03-16	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	8-PERMANENT	803	2010-03-16	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	5-PERMANENT	540	2010-03-15	0	N/A
69a-58.801	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	11	2010-03-18	0	N/A
69a-58.801	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	54	2010-03-18	0	N/A
69a-58.804	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	61	2010-03-18	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	82	2010-03-18	0	N/A

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

**Primary inspector**  
larry, swanson

**Additional inspector**  
N/, A

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - KEYSTONE HEIGHTS JUNIOR/SENIOR HIGH

**Address** - 900 SW ORCHID AVENUE

**Inspection date** - 2010-02-18

**Notes** -

**Inspectors present**

**State No**            **District Yes**            **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	192	2010-03-16	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	4-PERMANENT	406	2010-03-16	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	4-PERMANENT	410	2010-03-16	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	2-PERMANENT	68	2010-03-16	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	8-PERMANENT	803	2010-03-16	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	5-PERMANENT	540	2010-03-15	0	N/A
69a-58.801	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	11	2010-03-18	0	N/A
69a-58.801	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	54	2010-03-18	0	N/A
69a-58.804	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	61	2010-03-18	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	82	2010-03-18	0	N/A

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

**Primary inspector**

larry, swanson

**Additional inspector**

N/, A

## State Fire Marshal - Inspection Report

**District** ~ Clay

**School** ~ MIDDLEBURG SENIOR HIGH

**Address** ~ 3750 STATE ROAD 220

**Inspection date** ~ 2010-02-24

**Notes** ~

**Inspectors present**

**State No**      **District Yes**      **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	170	2010-03-29	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	262	2010-03-29	0	N/A
NFPA110319.1.2	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	215	2010-03-29	0	N/A
NFPA7099110-12	0899 UTILITIES OTHER	1-PERMANENT	278	2010-03-29	0	N/A
NFPA708401.3	0899 UTILITIES OTHER	1-PERMANENT	282	2010-03-29	0	N/A
FBC423.17.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	294	2010-03-29	0	N/A
NFPA708401.3	0899 UTILITIES OTHER	1-PERMANENT	280	2010-03-29	0	N/A
NFPA13	0508 INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	316	2010-03-29	0	N/A
NFPA70	0899 UTILITIES OTHER	1-PERMANENT	316A	2010-03-29	0	LIGHT NOT PROTECTED
NFPA13	0508 INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	320	2010-03-29	0	N/A
NFPA13	0508 INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	337	2010-03-29	0	N/A
FBC423.17.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	360	2010-03-29	0	NO EXIT LIGHT
NFPA13	0508 INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	289	2010-03-29	0	N/A
NFPA70	0800 UTILITIES	1-PERMANENT	341	2010-03-29	0	OUTLET SHORTED OUT
NFPA1.10.4.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	87	2010-03-29	0	N/A

NFPA110.4.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	89	2010-03-29	0	N/A
NFPA1-10.4.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	32	2010-03-29	0	N/A
NFPA10314.13.1.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	5	2010-03-29	0	N/A
NFPA110.4.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	35	2010-03-29	0	N/A
NFPA110.4.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	51	2010-03-29	0	N/A
NFPA304-3.1	1200	OPERATING FEATURES	92-RELOCATABLE	66	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	72	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	96	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	152	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	120	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	135	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	137	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	140	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	141	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	149	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	161	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	168	2010-03-29	0	N/A
FBC423.17.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	148	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	182	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	190	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	259	2010-03-29	0	N/A
NFPA13	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1-PERMANENT	263	2010-03-29	0	N/A

0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	1- PERMANENT	212	2010- 03-29	0	N/A
------	--	-----------------	-----	----------------	---	-----

---

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

---

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

---

**Primary inspector**

larry, swanson

**Additional inspector**

N/, A

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - ORANGE PARK SENIOR HIGH

**Address** - 2300 KINGSLEY AVENUE

**Inspection date** - 2010-03-24

**Notes** -

**Inspectors present**

**State No**      **District Yes**      **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	101	2010-04-26	0	N/A
NFPA70	0899	UTILITIES OTHER	1-PERMANENT	112	2010-04-27	0	EXPOSED WIRES AT CLOCK OUTLET
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	113	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	109	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	110	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	111	2010-04-24	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	118	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	121	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	117	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	128	2010-04-24	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	129	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	130	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	203	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	213	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	216	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	224	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	231	2010-04-26	0	N/A
FBC423.17.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	4-PERMANENT	5h	2010-04-26	0	N/A

NFPA70	0200	MEANS OF EGRESS	4-PERMANENT	17	2010-04-26	0	LIGHT BULBS EXPOSED
FBC1006.3.1	0199	GENERAL REQUIREMENTS	4-PERMANENT	21A	2010-04-26	0	LENS MISSING ON LIGHT
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	12-PERMANENT	141	2010-04-26	0	N/A
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	12-PERMANENT	153	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	22-PERMANENT	4	2010-04-26	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	23-PERMANENT	5	2010-04-26	0	N/A
NFPA10.4.1	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	24-PERMANENT	1	2010-04-26	0	N/A
NFPA70	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	24-PERMANENT	28	2010-04-26	0	N/A
NFPA708.401.3	0399	PROTECTION OTHER	27-PERMANENT	2	2010-04-26	0	N/A
NFPA70	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	27-PERMANENT	1	2010-04-26	0	CEILING J-BOX MISSING
	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	31-PERMANENT	1	2010-04-26	0	BUILDING NUMBER - FLAMABLE STORAGE SIGN ON EXTERIOR
NFPA70	0402	SYSTEM NEEDS INSPECTION	51-PERMANENT	2	2010-04-26	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	31	2010-04-26	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	30	2010-04-26	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	25	2010-04-26	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	13AB	2010-04-26	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	42	2010-04-26	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	43	2010-04-26	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	47	2010-04-26	0	N/A
69A-58.024	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	39	2010-04-26	0	N/A
69A-58.503	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92-RELOCATABLE	44	2010-04-26	0	N/A
69A-58.503	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92-RELOCATABLE	49	2010-04-26	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	51	2010-04-26	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	52	2010-04-26	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	54	2010-04-26	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	60	2010-04-26	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	62	2010-04-26	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	63	2010-04-26	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	67	2010-04-26	0	N/A

69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	72	2010-04-26	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	73	2010-04-26	0	N/A

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

**Primary inspector**

larry, swanson

**Additional inspector**

N/, A

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - RIDGEVIEW SENIOR HIGH

**Address** - 466 MADISON AVENUE

**Inspection date** - 2010-04-05

**Notes** -

**Inspectors present**

**State No**      **District Yes**      **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.3	0102 OCCUPANCY LOAD EXCEEDED/NOT POSTED	1-PERMANENT	149	2010-04-05	0	N/A
	0100 GENERAL REQUIREMENTS	2-PERMANENT	233	2010-04-05	0	NO ROOM NUMBER
NFPA70	0200 MEANS OF EGRESS	2-PERMANENT	233	2010-04-05	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	3-PERMANENT	315	2010-04-05	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	3-PERMANENT	320	2010-04-05	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	5-PERMANENT	528	2010-04-05	0	N/A
	0209 RATED OPENINGS NOT MAINTAINED	6-PERMANENT	635	2010-04-05	0	MAGNETIC DOOR HOLDER BROKEN
FBC1006.3.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	6-PERMANENT	675	2010-04-05	0	NORTH END EXTERIOR LIGHT BROKEN
NFPA70	0807 MISSING/BROKEN RECEPTACLE/FACEPLATE	8-PERMANENT	829	2010-04-05	0	N/A
NFPA70	0807 MISSING/BROKEN RECEPTACLE/FACEPLATE	9-PERMANENT	911	2010-04-05	0	WEST SIDE & EAST SIDE ELECTRICAL COVERS MISSING
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	9-PERMANENT	901	2010-04-05	0	N/A
FBC423.17.1	0202 EXIT LIGHTS INOPERABLE NORMAL MODE	9-PERMANENT	930	2010-04-05	0	N/A
69a-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	96-RELOCATABLE	2	2010-04-05	0	N/A
69a-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	96-RELOCATABLE	42	2010-04-05	0	N/A
69a-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	1	2010-04-05	0	N/A
69a-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	3	2010-04-05	0	N/A
69a-58.802	0802 CIRCUITS NOT LEGIBLE/PERMANENTLY LABELED	92-RELOCATABLE	3	2010-04-05	0	N/A
69a-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	4	2010-04-05	0	N/A

69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	5	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	8	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	10	2010-04-05	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	10	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	11	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	13	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	14	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	22	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	24	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	25	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	27	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	29	2010-04-05	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	31	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	32	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	45	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	52	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	53	2010-04-05	0	N/A
69a-58.1204	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	54	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	61	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	62	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	63	2010-04-05	0	N/A
69a-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	63	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	66	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	67	2010-04-05	0	N/A
69a-58.506	0499	FIRE ALARM OTHER	92-RELOCATABLE	67	2010-04-05	0	N/A
69a-58.211	0211	BLOCKED/LOCKED EXITS	92-RELOCATABLE	67	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	69	2010-04-05	0	N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	70	2010-04-05	0	N/A
69a-58.802	0802	CIRCUITS NOT LEGIBLE/PERMANENTLY	92-RELOCATABLE	72	2010-04-05	0	N/A

Labeled						
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	74	2010-04-05	0 N/A
69a-58.1205	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	74	2010-04-05	0 N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	81	2010-04-05	0 N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	82	2010-04-05	0 N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	83	2010-04-05	0 N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	86	2010-04-05	0 N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	89	2010-04-05	0 N/A
69a-58.204	0205	EMERG LIGHTING NOT TESTED/RECS MAINT'D	92-RELOCATABLE	92	2010-04-05	0 N/A
69a-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	101a	2010-04-05	0 N/A
69a-58.204	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	92-RELOCATABLE	101b	2010-04-05	0 N/A

**Statements acknowledged**


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



**Primary inspector**  
larry, swanson

**Additional inspector**  
N/, A