

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - R C BANNERMAN LEARNING RESOURCE CENTER

**Address** - 608 MILL STREET

**Inspection date** - 2010-03-23

**Notes** -

**Inspectors present**

**State No**      **District Yes**      **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
	NVO No violations noted this date	1- PERMANENT	ALL	2010-03-23	0	N/A
	NVO No violations noted this date	2- PERMANENT	ALL	2010-03-23	0	N/A
	NVO No violations noted this date	92- RELOCATABLE	ALL	2010-03-23	0	N/A

**Statements acknowledged**


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



**Primary inspector**  
larry, swanson

**Additional inspector**  
N/, A

## State Fire Marshal - Inspection Report

**District** ~ Clay

**School** ~ GREEN COVE SPRINGS JUNIOR HIGH

**Address** ~ 1220 BONAVENTURE AVENUE

**Inspection date** ~ 2009-10-01

**Notes** ~

### Inspectors present

**State No**      **District Yes**      **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	1	2009-11-01	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	3	2009-11-01	0	N/A
69A-901 1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	4-PERMANENT	422	2009-11-01	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	4-PERMANENT	415	2009-11-01	0	N/A
FBC423.14.2.2 0102	OCCUPANCY LOAD EXCEEDED/NOT POSTED	5-PERMANENT	501	2009-11-01	0	OCCUPANCY LOAD SIGN MISSING - 800 MAX
69A-58.106 0199	GENERAL REQUIREMENTS	7-PERMANENT	706	2009-11-01	0	STORAGE TOO HIGH, 24" TO CEILING
69A-58.503 0503	MONTHLY INSPECTION NOT DONE/RECORDED	9-PERMANENT	904	2009-11-01	0	N/A
69A-58.805 0806	OUTSIDE GFCI'S IMPROPERLY PROTECTED	0-Building N/A -- See notes	1	2009-11-01	0	Please add Building 41, Room 1 to this school's inspection report. This is a Football Field Concession Stand.
69A-69.801 0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	92-RELOCATABLE	104	2009-11-01	0	N/A
69A-58.803 0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	106	2009-11-01	0	N/A
69A-58.803 0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	107	2009-11-01	0	MOVE SHELF IN FRONT OF ELECTRIC PANEL

### Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



---

**Primary inspector**  
larry, swanson

**Additional inspector**  
N/, A

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - LAKE ASBURY JUNIOR HIGH

**Address** - 2851 SANDRIDGE ROAD

**Inspection date** - 2009-10-06

**Notes** -

**Inspectors present**

**State No**      **District Yes**      **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
69A-58.901	0199	GENERAL REQUIREMENTS	7-	713	2009-11-06	0	N/A
			PERMANENT				
69A-58.503	0503	MONTHLY INSPECTION NOT DONE/RECORDED	92-	391	2009-11-06	0	N/A
			RELOCATABLE				
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-	391	2009-11-06	0	N/A
			RELOCATABLE				
69A-58.503	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92-	393	2009-11-06	0	N/A
			RELOCATABLE				
69A-58.503	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92-	394	2009-11-06	0	N/A
			RELOCATABLE				
	0204	EMERG LIGHTS NOT OPERATIONAL	92-	422	2009-11-06	0	N/A
			RELOCATABLE				

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

  
**Primary inspector**  
 Larry, swanson

**Additional inspector**  
 N/, A

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - LAKESIDE JUNIOR HIGH

**Address** - 2750 MOODY ROAD

**Inspection date** - 2009-10-08

**Notes** -

**Inspectors present**

**State No**      **District Yes**      **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	2	2009-10-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	3	2009-10-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	4	2009-10-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	10	2009-10-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	11	2009-10-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	18	2009-10-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	19	2009-10-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	20	2009-10-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	29	2009-10-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	30	2009-10-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	2-PERMANENT	43	2009-11-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	2-PERMANENT	45	2009-11-08	0	N/A
69A-58.1205	1200	OPERATING FEATURES	2-PERMANENT	55	2009-11-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	3-PERMANENT	56	2009-11-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	3-PERMANENT	66	2009-11-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	3-PERMANENT	70	2009-11-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	3-PERMANENT	71	2009-11-06	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	3-PERMANENT	80	2009-11-06	0	N/A

69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	5-PERMANENT	116	2009-11-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	92-RELOCATABLE	704	2009-11-08	0	N/A
69A-58.807	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	92-RELOCATABLE	710	2009-11-08	0	N/A
69A-58.807	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	710	2009-11-08	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	721	2009-11-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	92-RELOCATABLE	721	2009-11-08	0	N/A
69A-58.204	0211	BLOCKED/LOCKED EXITS	92-RELOCATABLE	737	2009-11-08	0	N/A
69A-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	737	2009-11-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	92-RELOCATABLE	745A	2009-11-08	0	N/A
69A-58.1205	1205	FIRE EVACUATION PLAN(S) NOT POSTED	92-RELOCATABLE	745B	2009-11-08	0	N/A

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

  
**Primary inspector**  
 Larry, swanson

**Additional inspector**  
 N/, A

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - OAKLEAF SCHOOL

**Address** - 4085 PLANTATION OAKS BOULEVARD

**Inspection date** - 2009-10-13

**Notes** -

**Inspectors present**

**State No**      **District Yes**      **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
69A-59.1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	0-Building N/A -- See notes	219	2009-11-13	0 PLEASE ADD BUILDING 2, ROOM 219
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	605	2009-11-13	0 N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	606	2009-11-13	0 N/A
	0304 PENETRATION PROTECT MISSING/INADEQUATE	92-RELOCATABLE	613	2009-11-13	0 LIGHT COVER MISSING IN STORAGE ROOM
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	619	2009-11-13	0 N/A
69A-58-1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	92-RELOCATABLE	821	2009-11-13	0 N/A

**Statements acknowledged**


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



**Primary inspector**  
larry, swanson

**Additional inspector**  
N/, A

## State Fire Marshal - Inspection Report

**District** - Clay

**School** - ORANGE PARK JUNIOR HIGH

**Address** - 1500 GANO AVENUE

**Inspection date** - 2009-10-15

**Notes** -

**Inspectors present**

**State No      District Yes      Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
69a-58.809	0806	OUTSIDE GFCI'S IMPROPERLY PROTECTED	2-PERMANENT	217A	2009-11-15	0	N/A
69A-58.809	0806	OUTSIDE GFCI'S IMPROPERLY PROTECTED	4-PERMANENT	402	2009-11-15	0	N/A
69A-58.809	0806	OUTSIDE GFCI'S IMPROPERLY PROTECTED	4-PERMANENT	403	2009-11-15	0	N/A
69A-58.809	0806	OUTSIDE GFCI'S IMPROPERLY PROTECTED	4-PERMANENT	454	2009-11-15	0	N/A
69A-58.901	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	92-RELOCATABLE	762	2009-11-15	0	N/A
698-58.204	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	707	2009-11-15	0	N/A
69A-58.204	0299	MEANS OF EGRESS OTHER	92-RELOCATABLE	509	2009-11-15	0	ADD EMERGENCY LIGHT IN BUILDING/UNIT

**Statements acknowledged**


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

  
**Primary inspector**  
 larry, swanson

**Additional inspector**  
 N/, A



## State Fire Marshal - Inspection Report

**District** - Clay

**School** - JACK L WILKINSON JUNIOR HIGH

**Address** - 5025 STATE ROAD 218

**Inspection date** - 2009-10-20

**Notes** -

**Inspectors present**

**State No**      **District Yes**      **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
69A-58-499	0499 FIRE ALARM OTHER	1-PERMANENT	102	2009-11-20 0	FIRE ALARM BEING REPAIRED AFTER BEING HIT BY LIGHTENING
69A-58-1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	7-PERMANENT	757	2009-11-20 0	N/A
69A-58.802	0802 CIRCUITS NOT LEGIBLE/PERMANENTLY LABELED	92-RELOCATABLE	3	2009-11-20 0	N/A
69A-58.807	0899 UTILITIES OTHER	92-RELOCATABLE	6	2009-11-20 0	KNOCKOUT IN PANEL GLUED IN
69A-58-200	0899 UTILITIES OTHER	92-RELOCATABLE	27	2009-11-20 0	KNOCKOUTS MISSING IN ELECTRICAL PANELS
69A-58.807	1200 OPERATING FEATURES	92-RELOCATABLE	41	2009-11-20 0	KNOCKOUT MISSING IN ELECTRICAL PANEL
69A-58.899	0899 UTILITIES OTHER	92-RELOCATABLE	48	2009-11-20 0	COVER MISSING SMALL STORAGE ROOM LIGHT
69A-58.899	0899 UTILITIES OTHER	92-RELOCATABLE	46	2009-11-20 0	COVER MISSING ON FLO LIGHT IN CLOSET

**Statements acknowledged**


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

  
**Primary inspector**  
 larry, swanson

**Additional inspector**  
 N/, A