

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00744
Name of Facility: Argyle Elementary School
Address: 2625 Spencer Plantation Boulevard
City, Zip: Orange Park 32073

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Ana Sanchez Viera -Head Custodian Phone: 904-336-0375
PIC Email: Ana.SanchezViera@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 2/12/2025

Begin Time: 11:23 AM
End Time: 12:45 PM

Additional Information

FEMALES 355
MALES 390

CENSUS 745

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>OUT</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>NA</u> 15. Shower Facilities	<u>NA</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>NA</u> 16. Showers Water Temperatures	<u>NA</u> 24. Changing Station & Mats
<u>IN</u> 5. Maintenance & Repair	WATER SUPPLY	<u>NA</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>NA</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>NA</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>OUT</u> 20. Solid Waste	<u>NA</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>NA</u> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

[Signature]

[Signature]

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Classrooms 532 and 526 have had a plumbing leak and are currently unoccupied and have floor fans blowing to remove any residual moisture, there is a slight odor.
All other conditions appear satisfactory

Email Address(es): Ana.SanchezViera@myoneclay.net

Violations Comments

Violation #12. Toilet Facilities

Restroom 625 out of order

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #20. Solid Waste

One dumpster needs a plug to be leak-proof and prevent vermin entry

CODE REFERENCE: 20. Solid Waste. 5.(1)(e)8.e SREF. Trash and waste containers shall be provided in all areas, sufficient in number and emptied daily. Trash shall be stored in bins or containers in a central waste disposal area until removed. 5(1)(e)8.f SREF. Garbage, trash, & rubbish shall be collected, stored, and disposed of at a frequency and manner that prevents a sanitary nuisance. 5(11)(c)(d) SREF. Waste containers, including dumpsters, shall be accessible for maintenance and sanitation. Collectors and dumpsters shall be located on a concrete slab. Wet garbage shall be stored in impermeable, leak-proof, fly-tight containers. 468.2.3 FBC. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Ana Sanchez Viera -
Date: 2/12/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00376
Name of Facility: R C Bannerman Learning Center
Address: 608 Mill Street
City, Zip: Green Cove Springs 32043

Correct By: None
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Jason Kendall Phone: (904) 284-6589
PIC Email: Jason.Kendall@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 2/11/2025

Begin Time: 11:03 AM
End Time: 11:52 AM

Additional Information

FEMALES 80
MALES 120

CENSUS 200

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	IN 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

No violations noted
All Restrooms were stocked with soap/towels
All issues from previous inspection corrected

Email Address(es): Jason.Kendall@myoneclay.net

Violations Comments

No Violation Comments Available

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name:
Date: 2/11/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00031
Name of Facility: C E Bennett Elementary School
Address: 1 S Oakridge Avenue
City, Zip: Green Cove Springs 32043

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Shalon Britt (James Marshall) Phone: 904-336-0475
PIC Email: Shalon.britt@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 1/29/2025

Begin Time: 12:26 PM
End Time: 01:30 PM

Additional Information

FEMALES 420
MALES 380

CENSUS 800

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	OUT 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

Other conditions satisfactory

Email Address(es): Shalon.britt@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #12. Toilet Facilities

Boys restroom 1667 out of order

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #18. Drinking Fountains

Fountain in 1668 out of service

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Shalon Britt
Date: 1/29/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00033
Name of Facility: Clay High School
Address: 2025 State Road 16 W
City, Zip: Green Cove Springs 32043

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Keesha Tyler Phone: (904) 284-6500
PIC Email: Keesha.Tyler@MyOneClay.net

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 1/3/2025

Begin Time: 10:15 AM
End Time: 11:38 AM

Additional Information

FEMALES 907
MALES 872

CENSUS 1779

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Melissa Johnson

Client Signature:

Keesha Tyler

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Correct all violations prior to next inspection.

ESE Fridge: 39 F

Satisfactory conditions at time of inspection.

Email Address(es): Keesha.Tyler@MyOneClay.net

Violations Comments

Violation #5. Maintenance & Repair

CORRECT PRIOR TO NEXT INSPECTION: Restroom 773 has one tile with evidence of water damage.

CORRECTED ON-SITE: One portable had two water-damaged ceiling tiles. These were replaced as the inspector was on-site.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #18. Drinking Fountains

CORRECT PRIOR TO NEXT INSPECTION: Three water fountains within the gym have low water pressure.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Keesha Tyler
Date: 1/3/2025

Inspector Signature:

Melissa Johnson

Client Signature:

Keesha Tyler

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/20/2024 11:47:09 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00032
Name of Facility: Clay Hill Elementary School
Address: 6345 County Road 218
City, Zip: Jacksonville 32234

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Ms Reed Phone: 904-336-0775
PIC Email:

Correct By: None
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 11/18/2024

Begin Time: 11:45 AM
End Time: 12:45 PM

Additional Information

FEMALES 223
MALES 206

CENSUS 429

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	IN 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

Please verify cleaning products are keep out of reach of children.

Email Address(es): Barbara.griffis@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/20/2024 11:47:09 AM ****

2 of 2

Violations Comments

No Violation Comments Available

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 11/18/2024

Inspector Signature:

Handwritten signature of Alan Davis.

Client Signature:

Handwritten signature of the client.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00780
Name of Facility: Coppergate Elementary
Address: 2250 County Road 209
City, Zip: Middleburg 32068

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Randall Smith Phone: (904) 284-6500
PIC Email: Randall.Smith@MyOneClay.net

Inspection Information

Purpose: Routine
Inspection Date: 2/27/2025

Begin Time: 12:17 PM
End Time: 12:52 PM

Additional Information

FEMALES 282
MALES 321

CENSUS 606

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	OUT 12. Toilet Facilities	SAFETY
OUT 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Satisfactory conditions at time of inspection. Email Melissa.Johnson@FLHealth.gov when the violations listed within have been corrected.

Reach-in Fridge Temperature: 38 F
Reach-in Freezer Temperature: -10 F

Email Address(es): Stephanie.Raucci@MyOneClay.net;
Randall.Smith@MyOneClay.net

Violations Comments

Violation #2. Playground, Equipment & Athletic Fields

WORK ORDER: There is exposed concrete underneath the playground equipment. A work order has been created prior to inspection. The sand has been delivered and just needs to be spread.

CODE REFERENCE: 2. Playgrounds, Equipment and Athletic Fields. 5(2)(k) SREF. Playgrounds, equipment, and athletic fields where provided, shall be maintained in a safe and acceptable condition for the intended function. 5(2)(k)1 SREF. Play areas and athletic fields where fencing is provided shall comply with SREF, Section 5(2)(d). 5(2)(k)2 SREF. Pre-K, kindergarten, or day-care play areas, where provided, shall have direct access to and from their related classrooms or to a corridor providing immediate and safe access to the play area. 5 (2)(k)3 SREF. Play areas and athletic fields, where provided, shall have either direct access from the facility without crossing roads, traffic lanes, drives, or parking lots, or have appropriate safety devices provided where access crosses parking areas or drives. 5(2)(a)8 SREF. The playground shall be graded and drained to prevent an unintentional accumulation of standing surface water and debris. 468.2.2 FBC. Playground and equipment shall be safe, structurally sound, vermin proof, and shall not have jagged or sharp projections. Playground equipment shall be anchored to prevent toppling or dislodgement. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.

Violation #5. Maintenance & Repair

CORRECT PRIOR TO NEXT INSPECTION: Multiple lights are out throughout the school. There are a few lights out within the library. Replacement bulbs were delivered yesterday.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

WORK ORDER: One inoperable urinal within the boy's restroom. A work order was created prior to inspection.

WORK ORDER: One inoperable toilet within room 436. A work order was created prior to inspection.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #18. Drinking Fountains

CORRECT PRIOR TO NEXT INSPECTION: One water fountain is inoperable within room 483.

WORK-ORDER: The fountains near room 115 are inoperable. A work order was created prior to this inspection.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Melissa Johnson

Client Signature:

Randall Smith

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Randall Smith
Date: 2/27/2025

Inspector Signature:

Melissa Johnson

Client Signature:

Randall Smith

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-1873500
Name of Facility: Discovery Oaks Elementary
Address: 950 Plantation Oaks Parkway
City, Zip: Orange Park 32065

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Gilbert Yrigollen Phone: (904) - 336-4275
PIC Email: Gilbert.Yrigollen@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 9/3/2024

Begin Time: 12:17 PM
End Time: 01:25 PM

Additional Information

FEMALES 435
MALES 455

CENSUS 970

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
OUT 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	IN 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory at time of inspection

-

Email Address(es): Gilbert.Yrigollen@myoneclay.net

Violations Comments

Violation #3. Athletic & Playground Equipment

The rope ladder on the secondary playground is frayed and wires are exposed , It had been repaired with a pool noodle and duct tape but has deteriorated. Ensure no sharp edges or protrusions are exposed

CODE REFERENCE: 3. Athletic and Playground Equipment. 5(2)(k)4 SREF. Athletic and playground equipment, where provided, shall be structurally sound, maintained firm and stable, vermin-proof, free of pockets or crevices where water will collect or vermin and pests may hide, and free from jagged or sharp projections, edges, or corners. Playground equipment includes the equipment itself (backstops, swings, slides, etc.) and its structural components (foundations, supporting members, exposed fasteners, etc.).

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Gilbert Yrigollen
Date: 9/3/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00035
Name of Facility: Doctor s Inlet Elementary
Address: 2634 County 220 Road
City, Zip: Middleburg 32068

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Neha Dave Phone: (904) 284-6500
PIC Email: neha.dave@myoneclay.net

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 2/20/2025

Begin Time: 11:25 AM
End Time: 12:12 PM

Additional Information

FEMALES 259
MALES 310

CENSUS 627

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory conditions at time of inspection.

Correct all listed violations prior to the next routine inspection.

Email Address(es): neha.dave@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

CORRECT PRIOR TO NEXT INSPECTION: One inoperable light within portable 899.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #13. Handwashing Facilities

CORRECT PRIOR TO NEXT INSPECTION: One inoperable sink within the bathroom 910.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

CORRECT PRIOR TO NEXT INSPECTION: Two drinking fountains between 899 and 897 are inoperable. REPEAT.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Carolyn Ayers
Date: 2/20/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00036
Name of Facility: Fleming Island Elementary School
Address: 4425 Lakeshore Drive
City, Zip: Fleming Island 32003

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Allyn Crooms Phone: 904-336-1075
PIC Email: Allyn.Crooms@myonedclay.net

Inspection Information

Purpose: Routine
Inspection Date: 8/21/2024

Begin Time: 10:54 AM
End Time: 11:57 AM

Additional Information

FEMALES 350
MALES 350

CENSUS 700

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
OUT 2. Playground, Equip & Athletic Fields*	OUT 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	IN 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
OUT 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Other conditions satisfactory
Ceiling issues in 704 and 530 were noted on the last inspection

Email Address(es): Allyn.Crooms@myoneclay.net

Violations Comments

Violation #2. Playground, Equipment & Athletic Fields

The table (Where staff sit) on the yellow playground has some sharp edges

CODE REFERENCE: 2. Playgrounds, Equipment and Athletic Fields. 5(2)(k) SREF. Playgrounds, equipment, and athletic fields where provided, shall be maintained in a safe and acceptable condition for the intended function. 5(2)(k)1 SREF. Play areas and athletic fields where fencing is provided shall comply with SREF, Section 5(2)(d). 5(2)(k)2 SREF. Pre-K, kindergarten, or day-care play areas, where provided, shall have direct access to and from their related classrooms or to a corridor providing immediate and safe access to the play area. 5(2)(k)3 SREF. Play areas and athletic fields, where provided, shall have either direct access from the facility without crossing roads, traffic lanes, drives, or parking lots, or have appropriate safety devices provided where access crosses parking areas or drives. 5(2)(a)8 SREF. The playground shall be graded and drained to prevent an unintentional accumulation of standing surface water and debris. 468.2.2 FBC. Playground and equipment shall be safe, structurally sound, vermin proof, and shall not have jagged or sharp projections. Playground equipment shall be anchored to prevent toppling or dislodgement. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.

Violation #5. Maintenance & Repair

There are stained ceiling tiles in 530 and 704 -noted on previous inspection

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

A light is out in Boys RR 403

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Violation #13. Handwashing Facilities

One sink out of service in Girls restroom 822

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Allyn Crooms
Date: 8/21/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00673
Name of Facility: Fleming Island High School
Address: 2233 Village Square Parkway
City, Zip: Fleming Island 32003

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: General Forman (Ken Keller) Phone: (904) 541-2100
PIC Email: General.Forman@myoneclay.net

Inspection Information

Purpose: Reinspection
Inspection Date: 2/24/2025

Begin Time: 09:15 AM
End Time: 09:51 AM

Additional Information

FEMALES 916
MALES 963

CENSUS 1879

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	OUT 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	IN 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Remaining issues: (floor tile, hand sink (s), drain covers) to be corrected for next inspection.
Conditions satisfactory

Email Address(es): General.Forman@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

All noted ceiling tiles have been replaced

There is a missing floor tile near the toilet in boys RR208 (Unable to access this area at present due to student use)-Staff say work in progress

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair. th

Violation #13. Handwashing Facilities

Many of the hand sinks cut off too quickly to allow handwashing -follow up as needed

The sink in the handicap stall in male restroom 208 doesn't work

Unable to verify repair due to student use

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #15. Shower Facilities

Drain covers are missing in Girls locker room showers. -Noted on the last inspection- measurements have been taken, staff say in process of repair

CODE REFERENCE: 15. Shower Facilities. 5(16)(b)10 SREF. Shower facilities, where provided, shall be maintained in a clean and sanitary condition at all times. 5(16)(b)11 SREF. Foot baths shall not be provided unless they are required by a Board-approved educational program. 468.3.5.5 FBC. Walls. Walls in toilet rooms shall be impervious to a height of at least 4 ft. above the floor. Walls in can wash areas, & shower rooms shall be impervious to a height of at least 6 ft. above the floor. Toilet and shower partitions shall be impervious. 468.3.5.8.1 FBC. Shower heads shall be based on the peak load, provided at the ratio of one shower head for each five students, and located at least of 30 inches apart.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: General Forman
Date: 2/24/2025

Inspector Signature:

A handwritten signature in cursive script, likely belonging to Henry Klesh.

Client Signature:

A handwritten signature in cursive script, likely belonging to General Forman.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
FOOD SERVICE
INSPECTION REPORT



Facility Information

RESULT: Satisfactory

Permit Number: 10-48-00235
Name of Facility: Green Cove Springs JHS - Band
Address: 1220 Bonventure Avenue
City, Zip: Green Cove Springs 32043

Type: School (9 months or less)
Owner: Green Cove Springs Junior High School
Person In Charge: Kamesha Cooper Phone: 904-336-5175
PIC Email: Kamesha.Cooper@myoneclay.net

Inspection Information

Purpose: Reinspection
Inspection Date: 8/21/2024
Correct By: None
Re-Inspection Date: None

Number of Risk Factors (Items 1-29): 0
Number of Repeat Violations (1-57 R): 0
Facility Grade: N/A
Stop Sale: No

Begin Time: 10:05 AM
End Time: 10:20 AM

Marking Key: IN=the act or item was observed to be in compliance; OUT=the act or item was observed to be out of compliance; NO=the act or item was not observed to be occurring at the time of inspection; NA=the act or item is not performed by the facility; COS=violation corrected on site; R=repeat violation from previous inspection

FoodBorne Illness Risk Factors And Public Health Interventions

SUPERVISION

- IN 1. Demonstration of Knowledge/Training
- IN 2. Certified Manager/Person in charge present

EMPLOYEE HEALTH

- IN 3. Knowledge, responsibilities and reporting
- IN 4. Proper use of restriction and exclusion
- IN 5. Responding to vomiting & diarrheal events

GOOD HYGIENIC PRACTICES

- IN 6. Proper eating, tasting, drinking, or tobacco use
- IN 7. No discharge from eyes, nose, and mouth

PREVENTING CONTAMINATION BY HANDS

- IN 8. Hands clean & properly washed
- IN 9. No bare hand contact with RTE food
- IN 10. Handwashing sinks, accessible & supplies

APPROVED SOURCE

- IN 11. Food obtained from approved source
- NO 12. Food received at proper temperature
- IN 13. Food in good condition, safe, & unadulterated
- NA 14. Shellstock tags & parasite destruction

PROTECTION FROM CONTAMINATION

- IN 15. Food separated & protected; Single-use gloves

- IN 16. Food-contact surfaces; cleaned & sanitized

- NO 17. Proper disposal of unsafe food

TIME/TEMPERATURE CONTROL FOR SAFETY

- NO 18. Cooking time & temperatures

- NO 19. Reheating procedures for hot holding

- NO 20. Cooling time and temperature

- NO 21. Hot holding temperatures

- IN 22. Cold holding temperatures

- IN 23. Date marking and disposition

- NA 24. Time as PHC; procedures & records

CONSUMER ADVISORY

- NA 25. Advisory for raw/undercooked food

HIGHLY SUSCEPTIBLE POPULATIONS

- IN 26. Pasteurized foods used; No prohibited foods

ADDITIVES AND TOXIC SUBSTANCES

- NA 27. Food additives: approved & properly used

- IN 28. Toxic substances identified, stored, & used

APPROVED PROCEDURES

- NA 29. Variance/specialized process/HACCP

Inspector Signature:

Client Signature:

Form Number: DH 4023 03/18

10-48-00235 Green Cove Springs JHS - Band

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
FOOD SERVICE
INSPECTION REPORT



Good Retail Practices

SAFE FOOD AND WATER

- NA 30. Pasteurized eggs used where required
IN 31. Water & ice from approved source
NA 32. Variance obtained for special processing

FOOD TEMPERATURE CONTROL

- IN 33. Proper cooling methods; adequate equipment
IN 34. Plant food properly cooked for hot holding
IN 35. Approved thawing methods
IN 36. Thermometers provided & accurate

FOOD IDENTIFICATION

- IN 37. Food properly labeled; original container

PREVENTION OF FOOD CONTAMINATION

- IN 38. Insects, rodents, & animals not present
IN 39. No Contamination (preparation, storage, display)
IN 40. Personal cleanliness
IN 41. Wiping cloths: properly used & stored
IN 42. Washing fruits & vegetables

PROPER USE OF UTENSILS

- IN 43. In-use utensils: properly stored
IN 44. Equipment & linens: stored, dried, & handled
IN 45. Single-use/single-service articles: stored & used

- IN 46. Slash resistant/cloth gloves used properly

UTENSILS, EQUIPMENT AND VENDING

- IN 47. Food & non-food contact surfaces
IN 48. Ware washing: installed, maintained, & used; test strips
IN 49. Non-food contact surfaces clean

PHYSICAL FACILITIES

- IN 50. Hot & cold water available; adequate pressure
IN 51. Plumbing installed; proper backflow devices
IN 52. Sewage & waste water properly disposed
IN 53. Toilet facilities: supplied, & cleaned
IN 54. Garbage & refuse disposal
IN 55. Facilities installed, maintained, & clean
IN 56. Ventilation & lighting
IN 57. Permit; Fees; Application; Plans

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked as "out" violate one or more of the requirements of Chapter 64E-11, the Florida Administrative Code or Chapter 381.0072, Florida Statutes. Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violations Comments

No Violation Comments Available

General Comments

The water issue has been resolved, Facility now has water

Email Address(es): Kamesha.Cooper@myoneclay.net

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Kamesha Cooper
Date: 8/21/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 4

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00039
Name of Facility: Grove Park Elementary
Address: 1643 Miller Street
City, Zip: Orange Park 32073

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Melissa Spurrier Phone: (904) 284-6500
PIC Email: Melissa.Spurrier@MyOneClay.net

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 4/25/2025

Begin Time: 12:14 PM
End Time: 01:21 PM

Additional Information

FEMALES 210
MALES 247

CENSUS 457

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	OUT 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
OUT 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Melissa Spurrier

Client Signature:

Melissa Spurrier

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 4

General Comments

Email Melissa.Johnson@FLHealth.gov when the violations listed within have been corrected.

Temperatures:

Fridges: 40 F; 39 F

Freezers: 2 F; 9 F

Email Address(es): Melissa.Spurrier@MyOneClay.net;
Mark.Thomas@MyOneClay.net

Inspector Signature:

A handwritten signature in cursive script, appearing to read "Melissa Johnson", is written below the "Inspector Signature:" label.

Client Signature:

A handwritten signature in cursive script, appearing to read "Melissa Spurrier", is written below the "Client Signature:" label.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 4

Violations Comments

Violation #5. Maintenance & Repair

CORRECT PRIOR TO NEXT INSPECTION: The light is out within the girls' restroom, 605.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #9. Mechanical Ventilation

CORRECT PRIOR TO NEXT INSPECTION: The exhaust fans within the restrooms within building 600 and 700 are missing. REPEAT.

CODE REFERENCE: 9. Mechanical Ventilation. 5(16)(a)2 SREF. Mechanical ventilation systems shall be maintained in an operable condition at all times. 5(16)(a)4 SREF. Exhaust systems from toilet rooms, custodial closets, shower and locker rooms, athletic equipment rooms, etc., shall be maintained in an operable condition at all times. 5(13)(g)1.d SREF. Toilet rooms shall have exhaust fans vented to the exterior. 5(16)(a)10 SREF. Stationary local sources producing air-borne particulates, heat, odors, fumes, spray, vapors, smoke or gases in such quantities as to be irritating or injurious to human health shall have an exhaust system to collect and remove the contaminants. Such exhaust shall discharge directly to the exterior of the building. 468.3.6.2 FBC and 468.3.6.3 FBC. Kiln rooms and areas shall be provided with adequate exhaust to dispel emitted heat to the exterior, and they shall not be connected to any other exhaust system. 5(16)(a)5 SREF. Science laboratory fume hoods and laboratory emergency fans shall be maintained in an operable condition. 468.3.6.4 FBC. HVAC systems in chemistry labs and science classrooms shall be designed and installed to ensure that chemicals originating from the space are not recirculated. 468.3.6.5 SREF. Rooms used for the storage, handling, and disposal of chemicals used in school, college, and university laboratories shall be vented to the exterior. The ventilation system shall not be connected to the air conditioning return air system.

Violation #12. Toilet Facilities

CORRECT PRIOR TO NEXT INSPECTION: The toilet within the music portable and a toilet within the girls' restroom, 612 is inoperable. A workorder has been created to address this.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #13. Handwashing Facilities

CORRECT PRIOR TO NEXT INSPECTION: The middle faucet within the boys' restroom, 611 is loose.

CORRECT PRIOR TO NEXT INSPECTION: There are two loose faucets at the handwashing sinks within the boys' restroom, 136. A workorder has been created to address this.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

CORRECT PRIOR TO NEXT INSPECTION: The water fountain within the cafeteria and within room 708 is inoperable. A workorder has been created to address this.

CORRECT PRIOR TO NEXT INSPECTION: Three water fountains adjacent to the playground are clogged and one of the water fountains has low water pressure. A workorder has been created to address this.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Michael John

Client Signature:

Michelle Burrier

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



4 of 4

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Melissa Spurrier
Date: 4/25/2025

Inspector Signature:

Melissa Johnson

Client Signature:

Melissa Spurrier

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/20/2024 11:47:34 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00043
Name of Facility: Keystone Heights Elementary
Address: 365 SW Pecan Street
City, Zip: Keystone Heights 32656

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Elizabeth Turbeville
PIC Email: Phone: (904) 336-1398

Inspection Information

Purpose: Routine
Inspection Date: 11/19/2024

Begin Time: 11:30 AM
End Time: 12:30 PM

Additional Information

FEMALES 395
MALES 415

CENSUS 810

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	OUT 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	OUT 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

Continue to monitor, repair, replace lighting in classrooms, follow up on existing work orders.

Email Address(es): No Email Addresses Available

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/20/2024 11:47:34 AM ****

2 of 2

Violations Comments

Violation #12. Toilet Facilities

5th and 6th Grade restrooms areas need sanitary napkins boxes installed, or self closing trash cans.
CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #29. Other

Keep cleaning produces out of reach of children. Several lower grade classrooms had cleaning products under sinks.
CODE REFERENCE: 29. Other. This applies to any other applicable state or local standards.

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 11/19/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 3/19/2025 8:19:16 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00044
Name of Facility: KEYSTONE HEIGHTS JR/SR HIGH
Address: 900 Orchid Avenue
City, Zip: Keystone Heights 32656

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Clay County School Board Phone: (904) 336-7775
PIC Email:

Inspection Information

Purpose: Routine
Inspection Date: 3/18/2025

Begin Time: 11:30 AM
End Time: 12:30 PM

Additional Information

FEMALES 561
MALES 649

CENSUS 1210

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	OUT 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

No General Comments Available

Email Address(es): herbert.walls@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 3/19/2025 8:19:16 AM ****

2 of 2

Violations Comments

Violation #5. Maintenance & Repair

replace carpet in portable 23, repair replace carpet in 58. open seams.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #11. Group Toilet Rooms

repair floor in boy side, gang bathroom portable 76. previous repair failing sinking in.

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 3/18/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00045
Name of Facility: Lake Asbury Elementary
Address: 2904 Sandridge Road
City, Zip: Green Cove Springs 32043

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Heather Roche - Principal (Gwen McMullen) Phone: (904) 282-2994
PIC Email: Heather.Roche@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 9/13/2024

Begin Time: 09:06 AM
End Time: 10:49 AM

Additional Information

FEMALES 450
MALES 450

CENSUS 900

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	IN 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Check pressure on fountains near 638
Other conditions satisfactory
All issues from previous inspection have been corrected
Gwen.Mcmullen@myoneclay.net

Email Address(es): Heather.Roche@myoneclay.net;
Gwen.Mcmullen@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

There is some rotten wood on the exterior 21

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #18. Drinking Fountains

Fnear ountain not working Portable 87 , Also the faucet in portable 84 wobbly

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Heather Roche
Date: 9/13/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00729
Name of Facility: Lake Asbury Junior High
Address: 2851 Sandridge Road
City, Zip: Green Cove Springs 32043

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Lisa Wright Phone: 904-284-6500
PIC Email: Lisa.wright@myoneclay.net

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 2/5/2025

Begin Time: 11:35 AM
End Time: 12:35 PM

Additional Information

FEMALES 475
MALES 475

CENSUS 950

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	OUT 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

J. J. Kim

Client Signature:

Lisa Wright

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Other conditions satisfactory

Note: Fence near ag building needs reattached to post to prevent possibility of arms getting scraped

Email Address(es): Lisa.wright@myoneclay.net

Violations Comments

Violation #20. Solid Waste

One dumpster is missing a plug, dumpsters should be leakproof -Previously noted

CODE REFERENCE: 20. Solid Waste. 5.(1)(e)8.e SREF. Trash and waste containers shall be provided in all areas, sufficient in number and emptied daily. Trash shall be stored in bins or containers in a central waste disposal area until removed. 5(1)(e)8.f SREF. Garbage, trash, & rubbish shall be collected, stored, and disposed of at a frequency and manner that prevents a sanitary nuisance. 5(11)(c)(d) SREF. Waste containers, including dumpsters, shall be accessible for maintenance and sanitation. Collectors and dumpsters shall be located on a concrete slab. Wet garbage shall be stored in impermeable, leak-proof, fly-tight containers. 468.2.3 FBC. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Lisa Wright
Date: 2/5/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00046
Name of Facility: Lakeside Elementary School
Address: 2752 Moody Avenue
City, Zip: Orange Park 32073

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Amanda Gladue Phone: (904) 284-6500
PIC Email: Amanda.Gladue@MyOneClay.net

Inspection Information

Purpose: Routine
Inspection Date: 5/20/2025

Begin Time: 11:46 AM
End Time: 12:38 PM

Additional Information

FEMALES 351
MALES 404

CENSUS 755

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	OUT 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Janitorial closets locked at all times.
No animals observed on-site.
All offices are clean and in good repair.
All group care spaces are clean and in good repair.
Lunch tables are clean and in good repair.

Temperatures:

Refrigerator: 40 F
Freezer: 2 F; all products within freezer are frozen.

Satisfactory conditions at time of inspection.

Email Address(es): Amanda.Gladue@MyOneClay.net;
Mark.Thomas@MyOneClay.net

Violations Comments

Violation #5. Maintenance & Repair
CORRECT PRIOR TO NEXT INSPECTION: Room 605 has one water damaged ceiling tile.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #11. Group Toilet Rooms
CORRECT PRIOR TO NEXT INSPECTION: One inoperable toilet within the girls' portables restroom. A workorder was created to address this prior to the inspector's arrival.

CORRECT PRIOR TO NEXT INSPECTION: The toilet within room 604 is leaking at the flusher valve. A workorder was created to address this prior to the inspector's arrival.

CORRECT PRIOR TO NEXT INSPECTION: The stalls within the girls' restroom, 710 are missing covered trash cans.

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Violation #13. Handwashing Facilities
CORRECT PRIOR TO NEXT INSPECTION: There is a loose faucet within portable 55.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains
CORRECT PRIOR TO NEXT INSPECTION: The water fountain within room 604 has low water pressure.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Melissa Johnson

Client Signature:

[Signature]

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Amanda Gladue
Date: 5/20/2025

Inspector Signature:

Melissa Johnson

Client Signature:

Amanda Gladue

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00047
Name of Facility: Lakeside Jr High School
Address: 2750 Moody Avenue
City, Zip: Orange Park 32073

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Brian Lanoux Phone: (904) 284-6500
PIC Email: Brian.Lanoux@MyOneClay.net

Inspection Information

Purpose: Routine
Inspection Date: 5/21/2025

Begin Time: 12:06 PM
End Time: 01:24 PM

Additional Information

FEMALES 437
MALES 485

CENSUS 922

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	OUT	11. Group Toilet Rooms	IN	21. Pest Control
IN 1. School Site	IN	12. Toilet Facilities	IN	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN	13. Handwashing Facilities	IN	22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN	14. Soap Dispensers	IN	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN	15. Shower Facilities	NA	23. Sanitizers
IN 4. Construction	IN	16. Showers Water Temperatures	NA	24. Changing Station & Mats
OUT 5. Maintenance & Repair	IN	WATER SUPPLY	NA	25. Hand Sink
IN 6. Lighting Standards	IN	17. Approved Source	NA	26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT	18. Drinking Fountains	NA	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	OUT	LIQUID WASTE & WASTE WATER	NA	27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN	19. Sewage Disposal	NA	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN	20. Solid Waste	NA	28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	IN	PEST CONTROL	NA	29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Melvin Johnson

Client Signature:

R K J...

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Janitorial closets locked at all times.
No animals observed on-site.
All offices are clean and in good repair.
All group care spaces are clean and in good repair.
Lunch tables are clean and in good repair.

Fridge: 39 F
Freezer: 2 F

Satisfactory conditions at time of inspection.

Email Address(es): Mark.Thomas@MyOneClay.net;
Brian.Lanoux@MyOneClay.net;
Dustin.James@MyOneClay.net

Violations Comments

Violation #5. Maintenance & Repair

CORRECT PRIOR TO NEXT INSPECTION: Water damaged tiles within Building 1's hallways, Building 2's hallways, Building 3's hallways, and within the supply storage in the kitchen of the cafeteria. REPEAT.

CORRECT PRIOR TO NEXT INSPECTION: Hole in the wall of Building 2's hallway.

CORRECT PRIOR TO NEXT INSPECTION: One missing ceiling tile within Building 3's hallway.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #11. Group Toilet Rooms

CORRECT PRIOR TO NEXT INSPECTION: One toilet is out of order as it is leaking within the girl's restroom 924. A workorder has been created to address this.

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Violation #18. Drinking Fountains

CORRECT PRIOR TO NEXT INSPECTION: The water fountains are missing near the basketball court. Maintenance is aware of this and the water fountains have been ordered and just need to be installed.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Melvin Johnson

Client Signature:

R. K. Jones

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Brian Lanoux
Date: 5/21/2025

Inspector Signature:

Melissa Johnson

Client Signature:

R. K. Jones

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/15/2024 9:42:17 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00048
Name of Facility: McRae Elementary
Address: 6770 County Road 315 C
City, Zip: Keystone Heights 32656

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Mrs Winkler Phone: 904-336-2125
PIC Email:

Inspection Information

Purpose: Routine
Inspection Date: 11/14/2024

Begin Time: 10:20 AM
End Time: 11:15 AM

Additional Information

FEMALES 253
MALES 305

CENSUS 558

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	IN 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
OUT 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

No General Comments Available

Email Address(es): teresa.barfield@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/15/2024 9:42:17 AM ****

2 of 2

Violations Comments

Violation #6. Lighting Standards

Replace burned out lights in classrooms as needed. a few were out in classrooms.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Violation #18. Drinking Fountains

Check water levels at water fountains, some were to low to prevent contamination.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 11/14/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/20/2024 11:46:54 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00066
Name of Facility: Middleburg Elementary
Address: 3958 Main Street
City, Zip: Middleburg 32068

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Becky Wilkerson Phone: 904 336 1875
PIC Email:

Inspection Information

Purpose: Routine
Inspection Date: 11/18/2024

Begin Time: 10:35 AM
End Time: 11:25 AM

Additional Information

FEMALES 276
MALES 298

CENSUS 574

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	OUT 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	IN 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

No General Comments Available

Email Address(es): mark.osborne@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/20/2024 11:46:54 AM ****

2 of 2

Violations Comments

Violation #12. Toilet Facilities

Provide soap and papertowels to kindergarden and first grade bathrooms. Paper towels may be placed out side door of restrooms.
CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 11/18/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00067
Name of Facility: Middleburg High School
Address: 3750 County Road 220
City, Zip: Middleburg 32068

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Manuel Gonzalez Phone: (904) 282-9325
PIC Email: Manuel.Gonzalez@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 4/11/2025

Begin Time: 09:30 AM
End Time: 11:10 AM

Additional Information

FEMALES 925
MALES 925

CENSUS 1850

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	OUT 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

Satisfactory
Inspection included child care area - spoke to staff, this area does not fall under DCF as children are at least 3 or above

Email Address(es): Manuel.Gonzalez@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair

There are stained ceiling tiles in room 136

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #17. Approved Source

Backflow preventer needed in handwash sink in automotive area

CODE REFERENCE: 17. Approved Source. 5.(2)(j)1 SREF. An on-site potable water system provided shall be in proper working order and comply with the Florida Safe Drinking Water Act. 5.(2)(j)2 SREF. Samples of on-site treated and raw water shall be taken monthly and tested (bacteriological test), the water supply determined to be safe, and the certificate be on file and available for inspection.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Manuel Gonzalez
Date: 4/11/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00068
Name of Facility: Montclair Elementary
Address: 2398 Moody Avenue
City, Zip: Orange Park 32073

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Michael Smith Phone: 904-336-1975
PIC Email: Michael.smith@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 9/16/2024

Begin Time: 12:20 PM
End Time: 01:28 PM

Additional Information

FEMALES 250
MALES 250

CENSUS 500

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
OUT 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Other conditions appear satisfactory

Note: the broken slide is a repeat issue and the roof leak should be addressed as soon as possible to prevent mold or mildew issues

Email Address(es): Michael.smith@myoneclay.net

Violations Comments

Violation #2. Playground, Equipment & Athletic Fields

There is a cracked and broken slide on the third grade playground (Not in use at this time)

This was noted on the previous inspection (Last September)- A board has been placed to prevent the children from using the slide

CODE REFERENCE: 2. Playgrounds, Equipment and Athletic Fields. 5(2)(k) SREF. Playgrounds, equipment, and athletic fields where provided, shall be maintained in a safe and acceptable condition for the intended function. 5(2)(k)1 SREF. Play areas and athletic fields where fencing is provided shall comply with SREF, Section 5(2)(d). 5(2)(k)2 SREF. Pre-K, kindergarten, or day-care play areas, where provided, shall have direct access to and from their related classrooms or to a corridor providing immediate and safe access to the play area. 5 (2)(k)3 SREF. Play areas and athletic fields, where provided, shall have either direct access from the facility without crossing roads, traffic lanes, drives, or parking lots, or have appropriate safety devices provided where access crosses parking areas or drives. 5(2)(a)8 SREF. The playground shall be graded and drained to prevent an unintentional accumulation of standing surface water and debris. 468.2.2 FBC. Playground and equipment shall be safe, structurally sound, vermin proof, and shall not have jagged or sharp projections. Playground equipment shall be anchored to prevent toppling or dislodgement. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.

Violation #5. Maintenance & Repair

There appears to be significant roof leaks in portable 32, staining is evident and teacher reports roof is actively leaking when it rains

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Henry Klesh (5622)

Inspector Contact Number: Work: (904) 278-3786 ex.

Print Client Name: Michael Smith

Date: 9/16/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-1288429
Name of Facility: Oakleaf High School
Address: 4035 Plantation Oaks Boulevard
City, Zip: Orange Park 32065

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Stacy Jackson Phone: 904-336-8375
PIC Email: Stacy.Jackson@myoneclay.net

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 10/14/2024

Begin Time: 10:25 AM
End Time: 11:58 AM

Additional Information

FEMALES 1250
MALES 1250

CENSUS 2500

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>OUT</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>OUT</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>IN</u> 15. Shower Facilities	<u>NA</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>IN</u> 16. Showers Water Temperatures	<u>NA</u> 24. Changing Station & Mats
<u>IN</u> 5. Maintenance & Repair	WATER SUPPLY	<u>NA</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>NA</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>NA</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>IN</u> 20. Solid Waste	<u>NA</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>NA</u> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Conditions Satisfactory except as noted
Recommmend thermometers for refrigerators in ESE classrooms where milk or perishable items are stored and temperatures should be monitored to ensure items are maintained cold

Email Address(es): Stacy.Jackson@myoneclay.net

Violations Comments

Violation #12. Toilet Facilities

In the portable area male restroom a urinal has been repaired using untreated wood, It should be made waterproof
CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #13. Handwashing Facilities

One hand sink turned off in portable area male restroom -sink doesnt turn off
CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Stacy Jackson
Date: 10/14/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 3/3/2025 3:10:31 PM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00768
Name of Facility: Oakleaf Junior High School
Address: 4085 Plantation Oaks Boulevard
City, Zip: Orange Park 32065

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Marvin Banks Phone: 904-336-5821
PIC Email: Marvin.Banks@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 2/25/2025

Begin Time: 10:45 AM
End Time: 11:55 AM

Additional Information

FEMALES 597
MALES 640

CENSUS 1237

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	OUT 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	IN 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 3/3/2025 3:10:31 PM ****

2 of 2

General Comments

Adding new building for 6th grade
Other conditions were satisfactory

Marvin.banks@myoneclay.net
Wilnitra.Dixon@myoneclay.net

Email Address(es): Marvin.banks@myoneclay.net;
Wilnitra.Dixon@myoneclay.net;

Violations Comments

Violation #5. Maintenance & Repair

Several lights out in girls restroom 432

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

one sink and one toilet out of service (Boys) and one sink and handicap stall toilet (girls) out of service in the 600s portable restroom

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Marvin Banks
Date: 2/25/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 3/3/2025 3:07:25 PM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00835
Name of Facility: Oakleaf Village Elementary School
Address: 410 Oakleaf Village Parkway
City, Zip: Orange Park 32065

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Gary Dudney Phone: 904-336-2433
PIC Email: Vincent.Dudney@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 2/14/2025

Begin Time: 12:27 PM
End Time: 01:45 PM

Additional Information

FEMALES 550
MALES 550

CENSUS 1100

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION		
<u>IN</u> 1. School Site	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
BUILDING CONST/MAINT.	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
<u>IN</u> 4. Construction	<u>IN</u> 15. Shower Facilities	<u>IN</u> 23. Sanitizers
<u>OUT</u> 5. Maintenance & Repair	<u>IN</u> 16. Showers Water Temperatures	<u>IN</u> 24. Changing Station & Mats
<u>IN</u> 6. Lighting Standards	WATER SUPPLY	<u>IN</u> 25. Hand Sink
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 17. Approved Source	<u>IN</u> 26. Garbage Can
<u>IN</u> 8. Natural Ventilation	<u>OUT</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 9. Mechanical Ventilation	LIQUID WASTE & WASTE WATER	<u>IN</u> 27. Animal Maintenance/Aggressive
SANITARY FACILITIES	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
<u>IN</u> 10. Provided/Accessible/Separation	<u>OUT</u> 20. Solid Waste	<u>IN</u> 28. Maintenance/Complaint
	PEST CONTROL	<u>IN</u> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 3/3/2025 3:07:25 PM ****

2 of 2

General Comments

Note : Inside restrooms appear to have poor ventilation- check this issue-Several restrooms had rusty grab bars and appeared humid
Other conditions satisfactory

Email Address(es): Vincent.Dudney@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

There is a stained ceiling tile in room 300- noted on last inspection - Mr. Dudney states this is a new issue, not the same from previous inspection

There is a badly stained carpet in portable 907

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #18. Drinking Fountains

There are several fountains not working: Near portable 906, Near kindergarden playground, Near 5th/6th grade playground

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Violation #20. Solid Waste

One of the dumpsters needs a plug to prevent leakage/vermin entry

CODE REFERENCE: 20. Solid Waste. 5.(1)(e)8.e SREF. Trash and waste containers shall be provided in all areas, sufficient in number and emptied daily. Trash shall be stored in bins or containers in a central waste disposal area until removed. 5(1)(e)8.f SREF. Garbage, trash, & rubbish shall be collected, stored, and disposed of at a frequency and manner that prevents a sanitary nuisance. 5(11)(c)(d) SREF. Waste containers, including dumpsters, shall be accessible for maintenance and sanitation. Collectors and dumpsters shall be located on a concrete slab. Wet garbage shall be stored in impermeable, leak-proof, fly-tight containers. 468.2.3 FBC. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Gary Dudney
Date: 2/14/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00070
Name of Facility: Orange Park Elementary School
Address: 1401 Plainfield Avenue
City, Zip: Orange Park 32073

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: John Carignan Phone: (904) 284-6500
PIC Email: John.Carignan@MyOneClay.net

Inspection Information

Purpose: Routine
Inspection Date: 5/21/2025

Begin Time: 11:21 AM
End Time: 11:54 AM

Additional Information

FEMALES 240
MALES 244

CENSUS 484

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	IN 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

No animals observed on-site.
All group care spaces are clean and in good repair.
Lunch tables are clean and in good repair.

Satisfactory conditions at time of inspection.

Email Address(es): Mark.Thomas@MyOneClay.net;
John.Carignan@MyOneClay.net;
Tyler.Wood@MyOneClay.net

Violations Comments

Violation #18. Drinking Fountains
CORRECT PRIOR TO NEXT INSPECTION: One inoperable water fountain within room 18.

CORRECT PRIOR TO NEXT INSPECTION: One water fountain has low water pressure. This water fountain is outside of the cafeteria.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Tyler Wood
Date: 5/21/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00071
Name of Facility: Orange Park High School
Address: 2300 Kingsley Avenue
City, Zip: Orange Park 32073

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Daniel Allen Phone: (904) 891-0655
PIC Email: Daniel.Allen@myoneclay.net

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 4/14/2025

Begin Time: 08:33 AM
End Time: 09:34 AM

Additional Information

FEMALES 836
MALES 968

CENSUS 1804

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	IN 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Other conditions satisfactory
Inspection included child care area - spoke to staff, this area does not fall under DCF as children are at least 3 or above
Note : There was a fire extinguisher dated 2021 in the male locker room

Email Address(es): Daniel.Allen@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair
There were stained ceiling tiles noted :
Hall outside V157

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Daniel Allen
Date: 4/14/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00072
Name of Facility: Orange Park Jr. High
Address: 1500 Gano Avenue
City, Zip: Orange Park 32073

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Tania Auguste Phone: (904) 284-6500
PIC Email: Tania.Auguste@MyOneClay.net

Inspection Information

Purpose: Routine
Inspection Date: 4/17/2025

Begin Time: 11:50 AM
End Time: 12:57 PM

Additional Information

FEMALES 382
MALES 416

CENSUS 923

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	OUT	11. Group Toilet Rooms	IN	21. Pest Control
IN 1. School Site	IN	12. Toilet Facilities	IN	SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT	13. Handwashing Facilities	IN	22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN	14. Soap Dispensers		DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA	15. Shower Facilities	NA	23. Sanitizers
IN 4. Construction	NA	16. Showers Water Temperatures	NA	24. Changing Station & Mats
OUT 5. Maintenance & Repair		WATER SUPPLY	NA	25. Hand Sink
IN 6. Lighting Standards	IN	17. Approved Source	NA	26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT	18. Drinking Fountains		ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation		LIQUID WASTE & WASTE WATER	NA	27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN	19. Sewage Disposal		DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN	20. Solid Waste	NA	28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation		PEST CONTROL	NA	29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

No pests observed at time of inspection.

Temperatures:

Refrigerators: 38 F and 30 F

Freezers: - 10 F and -10 F

Satisfactory conditions at time of inspection.

Email Address(es): Tania.Auguste@MyOneClay.net;
Arthur.Allison@MyOneClay.net;
Mark.Thomas@MyOneClay.net

Violations Comments

Violation #5. Maintenance & Repair

CORRECT PRIOR TO NEXT INSPECTION: Many ceiling tiles throughout the school with water damage. In particular, the library and classroom 302 have many ceiling tiles with water damage. REPEAT.

WORK ORDER: Loose light cover within the art classroom. A workorder has been created to address this prior to inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #11. Group Toilet Rooms

CORRECT PRIOR TO NEXT INSPECTION: One stall door within the restroom 522 is stuck.

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Violation #13. Handwashing Facilities

CORRECT PRIOR TO NEXT INSPECTION: One faucet within the restroom 522 is inoperable.

WORK ORDER: The boys restroom within Building 3 has an inoperable faucet. A work order has been created prior to inspection.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

CORRECT PRIOR TO NEXT INSPECTION: Three water fountains outside the portables and the left water fountain within the gym near the boys' locker room are inoperable. REPEAT.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Melanie Johnson

Client Signature:

Donna Anderson

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Tania Auguste
Date: 4/17/2025

Inspector Signature:

Melissa Johnson

Client Signature:

Tania Auguste

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00072
Name of Facility: Orange Park Jr. High
Address: 1500 Gano Avenue
City, Zip: Orange Park 32073

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Tania Auguste Phone: (904) 284-6500
PIC Email: Tania.Auguste@MyOneClay.net

Inspection Information

Purpose: Routine
Inspection Date: 4/17/2025

Begin Time: 11:50 AM
End Time: 12:57 PM

Additional Information

FEMALES 382
MALES 416

CENSUS 923

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	OUT	11. Group Toilet Rooms	IN	21. Pest Control
IN 1. School Site	IN	12. Toilet Facilities	SAFETY	
IN 2. Playground, Equip & Athletic Fields*	OUT	13. Handwashing Facilities	IN	22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN	14. Soap Dispensers	DIAPER CHANGING STATION	
BUILDING CONST/MAINT.	NA	15. Shower Facilities	NA	23. Sanitizers
IN 4. Construction	NA	16. Showers Water Temperatures	NA	24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY		NA	25. Hand Sink
IN 6. Lighting Standards	IN	17. Approved Source	NA	26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT	18. Drinking Fountains	ANIMAL HEALTH & SAFETY	
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER		NA	27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN	19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES	
SANITARY FACILITIES	IN	20. Solid Waste	NA	28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL		NA	29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

No pests observed at time of inspection.

Temperatures:

Refrigerators: 38 F and 30 F

Freezers: - 10 F and -10 F

Satisfactory conditions at time of inspection.

Email Address(es): Tania.Auguste@MyOneClay.net;
Arthur.Allison@MyOneClay.net;
Mark.Thomas@MyOneClay.net

Violations Comments

Violation #5. Maintenance & Repair

CORRECT PRIOR TO NEXT INSPECTION: Many ceiling tiles throughout the school with water damage. In particular, the library and classroom 302 have many ceiling tiles with water damage. REPEAT.

WORK ORDER: Loose light cover within the art classroom. A workorder has been created to address this prior to inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #11. Group Toilet Rooms

CORRECT PRIOR TO NEXT INSPECTION: One stall door within the restroom 522 is stuck.

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Violation #13. Handwashing Facilities

CORRECT PRIOR TO NEXT INSPECTION: One faucet within the restroom 522 is inoperable.

WORK ORDER: The boys restroom within Building 3 has an inoperable faucet. A work order has been created prior to inspection.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

CORRECT PRIOR TO NEXT INSPECTION: Three water fountains outside the portables and the left water fountain within the gym near the boys' locker room are inoperable. REPEAT.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Melanie Johnson

Client Signature:

Donna Anderson

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Tania Auguste
Date: 4/17/2025

Inspector Signature:

Handwritten signature of Melissa Johnson in cursive script.

Client Signature:

Handwritten signature of Tania Auguste in cursive script.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00073
Name of Facility: R M Paterson Elementary School
Address: 5400 Pine Avenue
City, Zip: Fleming Island 32003

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Tracy Hampshire Phone: (904) 336-2575
PIC Email: Tracy.Hampshire@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 2/6/2025

Begin Time: 11:50 AM
End Time: 01:13 PM

Additional Information

FEMALES 357
MALES 329

CENSUS 686

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	OUT 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
OUT 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	IN 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

Other conditions satisfactory

Email Address(es): Tracy.hampshire@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #3. Athletic & Playground Equipment

There are unconnected ropes as part of the rock wall climber on upper grade playground

CODE REFERENCE: 3. Athletic and Playground Equipment. 5(2)(k)4 SREF. Athletic and playground equipment, where provided, shall be structurally sound, maintained firm and stable, vermin-proof, free of pockets or crevices where water will collect or vermin and pests may hide, and free from jagged or sharp projections, edges, or corners. Playground equipment includes the equipment itself (backstops, swings, slides, etc.) and its structural components (foundations, supporting members, exposed fasteners, etc.).

Violation #5. Maintenance & Repair

There is a leak from the water heater in the custodial office resulting in water on the floor

Also there are two small areas of damage to the sidewalks which may be a trip hazard (At cafeteria west door and near P 51

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

There is a toilet out of order in island restroom 4th-6th grade (Female)

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Tracy Hampshire
Date: 2/6/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00876
Name of Facility: Plantation Oaks Elementary
Address: 4150 Plantation Oaks Boulevard
City, Zip: Orange Park 32065

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Doris Ford Phone: 904-336-2775
PIC Email: Doris.ford@myoneclay.net

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 11/5/2024

Begin Time: 12:55 PM
End Time: 01:55 PM

Additional Information

FEMALES 475
MALES 475

CENSUS 950

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
OUT 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

Conditions satisfactory except for playground issue . Ms. Ford is aware of the specific item.

Email Address(es): Doris.ford@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #3. Athletic & Playground Equipment

There is a spinning gadget on the Big kids playground where the rubber is beginning to deteriorate and may result in sharp edges being exposed - see attached picture

CODE REFERENCE: 3. Athletic and Playground Equipment. 5(2)(k)4 SREF. Athletic and playground equipment, where provided, shall be structurally sound, maintained firm and stable, vermin-proof, free of pockets or crevices where water will collect or vermin and pests may hide, and free from jagged or sharp projections, edges, or corners. Playground equipment includes the equipment itself (backstops, swings, slides, etc.) and its structural components (foundations, supporting members, exposed fasteners, etc.).

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Doris Ford
Date: 11/5/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00592
Name of Facility: RideOut Elementary School
Address: 3065 Apalachicola Boulevard
City, Zip: Middleburg 32068

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Trish Stuart (Karen Herko) Phone: 904-504-1463
PIC Email: Karen.herko@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 5/19/2025

Begin Time: 12:20 PM
End Time: 01:59 PM

Additional Information

FEMALES 400
MALES 400

CENSUS 800

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	IN 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	OUT 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	OUT 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Check fountains near portables
Thermometer recommended for ESE refrigerators

Conditions satisfactory
Trish.Stuart@myoneclay.net

Email Address(es): Trish.Stuart@myoneclay.net;
Karen.herko@myoneclay.net;

Violations Comments

Violation #5. Maintenance & Repair

There is a stained ceiling tile in 141

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #17. Approved Source

Outside hose on bldg 20 needs backflow preventer

CODE REFERENCE: 17. Approved Source. 5.(2)(j)1 SREF. An on-site potable water system provided shall be in proper working order and comply with the Florida Safe Drinking Water Act. 5.(2)(j)2 SREF. Samples of on-site treated and raw water shall be taken monthly and tested (bacteriological test), the water supply determined to be safe, and the certificate be on file and available for inspection.

Violation #20. Solid Waste

Dumpster is missing a lid

CODE REFERENCE: 20. Solid Waste. 5.(1)(e)8.e SREF. Trash and waste containers shall be provided in all areas, sufficient in number and emptied daily. Trash shall be stored in bins or containers in a central waste disposal area until removed. 5(1)(e)8.f SREF. Garbage, trash, & rubbish shall be collected, stored, and disposed of at a frequency and manner that prevents a sanitary nuisance. 5(11)(c)(d) SREF. Waste containers, including dumpsters, shall be accessible for maintenance and sanitation. Collectors and dumpsters shall be located on a concrete slab. Wet garbage shall be stored in impermeable, leak-proof, fly-tight containers. 468.2.3 FBC. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Trish Stuart
Date: 5/19/2025

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00074
Name of Facility: Ridgeview Elementary
Address: 421 Jefferson Avenue
City, Zip: Orange Park 32065

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Ryan Rodgers Phone: (904) 284-6500
PIC Email: Ryan.Rodgers@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 8/26/2024

Begin Time: 11:09 AM
End Time: 12:35 PM

Additional Information

FEMALES 271
MALES 320

CENSUS 591

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION			IN 11. Group Toilet Rooms	IN 21. Pest Control
OUT 1. School Site		IN 12. Toilet Facilities		SAFETY
IN 2. Playground, Equip & Athletic Fields*		IN 13. Handwashing Facilities		IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment		IN 14. Soap Dispensers		DIAPER CHANGING STATION
BUILDING CONST/MAINT.		NA 15. Shower Facilities		IN 23. Sanitizers
IN 4. Construction		NA 16. Showers Water Temperatures		IN 24. Changing Station & Mats
OUT 5. Maintenance & Repair		WATER SUPPLY		IN 25. Hand Sink
IN 6. Lighting Standards		IN 17. Approved Source		IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains			ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER			NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal			DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	OUT 20. Solid Waste			NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL			IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Playground equipment in good repair except rope ladder beginning to fray, the wires are exposed- They are intact at this time- this should be monitored (Primary playground)
Some areas inaccessible due to testing
Recommend thermometers in IND refrigerators (Ensure milk is not out of date)
Other conditions satisfactory

Email Address(es): Ryan.Rodgers@myoneclay.net

Violations Comments

Violation #1. School Site

There is a large depression near the storm drain near 729

CODE REFERENCE: 1. School Site. 5(2)(a)7 SREF. The site shall be free of broken glass, metal, trash, undergrowth, and any debris that constitutes a hazard or that encourages the harborage and concealment of pests.

Violation #5. Maintenance & Repair

Loose faucet in Boys Gang restroom 747

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #18. Drinking Fountains

Loose fountain spigot in 759

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Violation #20. Solid Waste

Both dumpsters are rusted out and not leak-proof -previously noted

CODE REFERENCE: 20. Solid Waste. 5.(1)(e)8.e SREF. Trash and waste containers shall be provided in all areas, sufficient in number and emptied daily. Trash shall be stored in bins or containers in a central waste disposal area until removed. 5(1)(e)8.f SREF. Garbage, trash, & rubbish shall be collected, stored, and disposed of at a frequency and manner that prevents a sanitary nuisance. 5(11)(c)(d) SREF. Waste containers, including dumpsters, shall be accessible for maintenance and sanitation. Collectors and dumpsters shall be located on a concrete slab. Wet garbage shall be stored in impermeable, leak-proof, fly-tight containers. 468.2.3 FBC. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Ryan Rodgers
Date: 8/26/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/31/2025 10:06:44 AM ****

1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00075
Name of Facility: Ridgeview High School
Address: 466 Madison Avenue
City, Zip: Orange Park 32065

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Donald Speights Phone: (904) 284-6500
PIC Email: George.Speights@MyOneClay.net

Inspection Information

Purpose: Routine
Inspection Date: 1/29/2025

Begin Time: 12:18 PM
End Time: 01:33 PM

Additional Information

FEMALES 942
MALES 922

CENSUS 1864

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	OUT 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Melina Johnson

Client Signature:

Emilio

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/31/2025 10:06:44 AM ****

2 of 3

General Comments

Email Melissa.Johnson@FLHealth.gov if you have any questions or concerns.

Satisfactory conditions at time of inspection.

Email Address(es): George.Speights@MyOneClay.net;
Mark.Thomas@MyOneClay.net

Violations Comments

Violation #5. Maintenance & Repair

CORRECT PRIOR TO NEXT INSPECTION: Building 7 has multiple water damaged tiles.

CORRECT PRIOR TO NEXT INSPECTION: The HVAC classroom has multiple damaged tiles.

CORRECT PRIOR TO NEXT INSPECTION: Portable 62 and Portable 34 have water damage on the ceiling.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #11. Group Toilet Rooms

CORRECT PRIOR TO NEXT INSPECTION: The girl's group restroom in the front lobby of the gym is missing some sanitary boxes. REPEAT.

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Violation #13. Handwashing Facilities

CORRECT PRIOR TO NEXT INSPECTION: One loose and inoperable faucet within the boy's group restroom in front lobby of gym.

CORRECT PRIOR TO NEXT INSPECTION: One inoperable faucet within the boy's group restroom at the portables.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

CORRECT PRIOR TO NEXT INSPECTION: Low water pressure at water fountain in front of the boy's group restroom in front lobby of gym. REPEAT.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Melissa Johnson

Client Signature:

Emailed

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 1/31/2025 10:06:44 AM ****

3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Emailed
Date: 1/29/2025

Inspector Signature:

Melissa Johnson

Client Signature:

Emailed

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00076
Name of Facility: S Bryan Jennings Elementary
Address: 215 Corona Drive
City, Zip: Orange Park 32073

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Misty Obrien Phone: 904-284-6500
PIC Email: Misty.Obrien@myoneclay.net

Correct By: None
Re-Inspection Date: None

Inspection Information

Purpose: Reinspection
Inspection Date: 4/21/2025

Begin Time: 10:25 AM
End Time: 10:57 AM

Additional Information

FEMALES
MALES

CENSUS 510

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>IN</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>NA</u> 15. Shower Facilities	<u>IN</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>NA</u> 16. Showers Water Temperatures	<u>IN</u> 24. Changing Station & Mats
<u>IN</u> 5. Maintenance & Repair	WATER SUPPLY	<u>IN</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>IN</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>IN</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>IN</u> 20. Solid Waste	<u>IN</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>IN</u> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Re-inspection for sewage issue noted on 4/17:
Problem appears to be resolved at present, Area should be monitored to ensure issue does not re-occur.
It was noted that the restrooms in 11B and 12B are still out of order

Email Address(es): Misty.Obrien@myoneclay.net;
Eileen.pierson@myoneclay.net;
Jocelyn.Farber@myoneclay.net

Violations Comments

No Violation Comments Available

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Misty Obrien
Date: 4/21/2025

Inspector Signature:

Handwritten signature of Henry Klesh.

Client Signature:

Handwritten signature of Misty Obrien.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00836
Name of Facility: Shadowlawn Elementary School
Address: 2945 County Road 218
City, Zip: Green Cove Springs 32043

Correct By: None
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Whitney Johnson Phone: (904) 336-3375
PIC Email: Whitney.Johnson@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 10/29/2024

Begin Time: 11:20 AM
End Time: 12:20 PM

Additional Information

FEMALES 400
MALES 400

CENSUS 800

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Conditions satisfactory
Accompanied by School Guardian Michael Cunningham

Email Address(es): Whitney.Johnson@myoneclay.net

Violations Comments

No Violation Comments Available

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Whitney Johnson
Date: 10/29/2024

Inspector Signature:

A handwritten signature in black ink, appearing to be "H. Klesh".

Client Signature:

A handwritten signature in black ink, appearing to be "Whitney Johnson".

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-2767228
Name of Facility: Spring Park School #0671
Address: 3530 CR 315
City, Zip: Green Cove Springs 32043

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Tiffany Outman- Principal
PIC Email: Tiffany.outman@myoneclay.net
Phone: 904-336-6375

Inspection Information

Purpose: Routine
Inspection Date: 8/19/2024

Begin Time: 10:56 AM
End Time: 12:10 PM

Additional Information

FEMALES 350
MALES 349

CENSUS 699

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory
Check Dumpster, it may be rusted out and leaking, there is also a small amount of debris in the dumpster area
Accompanied by School guardian Chris Castelli

Mark.thomas@myoneclay.net- Building official

Email Address(es): Tiffany.outman@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair

There is a bench at the front of the school that wobbles ,missing bolts, it is taped off

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Tiffany Outman
Date: 8/19/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00708
Name of Facility: Swimming Pen Elementary School
Address: 1630 Woodpecker Lane
City, Zip: Middleburg 32068

Correct By: None
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Valerie Prioleau Phone: 904-336-3475
PIC Email: Valerie.Prioleau@myoneclay.net

Inspection Information

Purpose: Routine
Inspection Date: 5/8/2025

Begin Time: 12:05 PM
End Time: 01:15 PM

Additional Information

FEMALES 250
MALES 250

CENSUS 500

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>IN</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>NA</u> 15. Shower Facilities	<u>NA</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>NA</u> 16. Showers Water Temperatures	<u>NA</u> 24. Changing Station & Mats
<u>IN</u> 5. Maintenance & Repair	WATER SUPPLY	<u>NA</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>NA</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>NA</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>IN</u> 20. Solid Waste	<u>NA</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>NA</u> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Condition Satisfactory
No violations observed

Email Address(es): Valerie.Prioleau@myoneclay.net

Violations Comments

No Violation Comments Available

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Cheryl Larson
Date: 5/8/2025

Inspector Signature:

Handwritten signature of Henry Klesh.

Client Signature:

Handwritten signature of Valerie Prioleau.

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00530
Name of Facility: Thunderbolt Elementary School
Address: 2020 Thunderbolt Road
City, Zip: Fleming Island 32003

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Jessica Eckels Phone: 904-336-3675
PIC Email: Jessica.Eckels@myoneclay.net

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 10/7/2024

Begin Time: 10:43 AM
End Time: 12:15 PM

Additional Information

FEMALES 393
MALES 407

CENSUS 800

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	NA 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	OUT 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	NA 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Recommmend thermometer for refrigerator in 306 ESE room to ensure milk is maintained cold
Check drainage near portable 702 , water standing on sidewalk
Recommmend water be supplied to portables 704 and 706 to provide for fountains and handwashing
Other conditions satisfactory

Email Address(es): Jessica.Eckels@myoneclay.net

Violations Comments

Violation #18. Drinking Fountains
Fountains not working in 111 and 304
CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Jessica Eckels
Date: 10/7/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 3

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00079
Name of Facility: Tynes Elementary School
Address: 1550 Tynes Boulevard
City, Zip: Middleburg 32068

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Robert Johnson Phone: (904) 284-6500
PIC Email: Robert.Johnson1@MyOneClay.net

Inspection Information

Purpose: Routine
Inspection Date: 5/22/2025

Begin Time: 12:09 PM
End Time: 01:10 PM

Additional Information

FEMALES 471
MALES 596

CENSUS 1067

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 1. School Site	<u>IN</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>OUT</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<u>NA</u> 15. Shower Facilities	<u>NA</u> 23. Sanitizers
<u>IN</u> 4. Construction	<u>NA</u> 16. Showers Water Temperatures	<u>NA</u> 24. Changing Station & Mats
<u>OUT</u> 5. Maintenance & Repair	WATER SUPPLY	<u>NA</u> 25. Hand Sink
<u>IN</u> 6. Lighting Standards	<u>IN</u> 17. Approved Source	<u>NA</u> 26. Garbage Can
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>OUT</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<u>NA</u> 27. Animal Maintenance/Aggressive
<u>IN</u> 9. Mechanical Ventilation	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<u>IN</u> 20. Solid Waste	<u>NA</u> 28. Maintenance/Complaint
<u>IN</u> 10. Provided/Accessible/Separation	PEST CONTROL	<u>NA</u> 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Observations:

Staff bathrooms are designated and in good condition.
All restrooms are clean and supplied with soap and paper towels.
All classrooms are clean and in good repair.
All equipment is in good repair.
All drinking fountains are clean.
No pests observed at time of inspection.
No animals observed on-site.
All group care spaces are clean.
Lunch tables/multipurpose rooms are clean and in good repair.

Temperatures:

Reach-in Fridges: 36 F; 36 F; 37 F
Freezers: All TCS foods appear frozen.
Satisfactory conditions at time of inspection.

Email Address(es): Robert.Johnson1@MyOneClay.net;
Mark.Thomas@MyOneClay.net

Violations Comments

Violation #5. Maintenance & Repair

CORRECT PRIOR TO NEXT INSPECTION: There are cracked tiles within the bathroom of 431. These are not sharp but are causing a slight tripping-hazard as they are uneven.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #13. Handwashing Facilities

CORRECT PRIOR TO NEXT INSPECTION: Portable 68's restroom sink is inoperable. A workorder has been created to address this prior to the inspector's arrival.

CORRECT PRIOR TO NEXT INSPECTION: One faucet within the boys' restroom, 73 is inoperable and loose. A workorder has been created to address this prior to the inspector's arrival.

CORRECT PRIOR TO NEXT INSPECTION: The sink within 716's restroom has a loose faucet. A workorder has been created to address this prior to the inspector's arrival.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

CORRECT PRIOR TO NEXT INSPECTION: Two drinking fountains located at the playgrounds are inoperable. REPEAT.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Melissa Johnson

Client Signature:

Mark Thomas

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 278-4761 ex.
Print Client Name: Robert Johnson
Date: 5/22/2025

Inspector Signature:

Melissa Johnson

Client Signature:

Robert Johnson

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00080
Name of Facility: W. E. Cherry Elementary School
Address: 420 Edson Drive
City, Zip: Orange Park 32073

Type: Public Schools
Owner: CLAY COUNTY SCHOOL BOARD
Person In Charge: Matt Pierce Phone: 904-336-3975
PIC Email: Matthew.pierce@myoneclay.net

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 11/18/2024

Begin Time: 11:15 AM
End Time: 12:32 PM

Additional Information

FEMALES 310
MALES 310

CENSUS 620

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	OUT 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	IN 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

Other conditions satisfactory
Note : A plumbing issue in the kitchen regarding the hand sinks resulted in an unsatisfactory inspection for the kitchen

Email Address(es): Matthew.pierce@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair

Girls restroom #63 and boys restroom #61 are out of service due to leak from above

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

There is a leak from the toilet in girls restroom #66 causing the restrooms below to be out of service

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Matt Pierce
Date: 11/18/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/25/2024 9:57:48 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00041
Name of Facility: Wilkinson Elementary
Address: 4965 County Road 218 W
City, Zip: Middleburg 32068

Correct By: None
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Ms. Hayward
PIC Email: Phone: (904) 336-4098

Inspection Information

Purpose: Routine
Inspection Date: 11/20/2024

Begin Time: 10:20 AM
End Time: 11:25 AM

Additional Information

FEMALES 344
MALES 361

CENSUS 705

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	NA 15. Shower Facilities	IN 23. Sanitizers
IN 4. Construction	NA 16. Showers Water Temperatures	IN 24. Changing Station & Mats
IN 5. Maintenance & Repair	WATER SUPPLY	IN 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	IN 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	NA 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	NA 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

No violations observed

Email Address(es): Thomas.hash@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 11/25/2024 9:57:48 AM ****

2 of 2

Violations Comments

No Violation Comments Available

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 11/20/2024

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 10/28/2024 8:42:23 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 10-51-00042
Name of Facility: Wilkinson Jr High
Address: 5025 County Road 218
City, Zip: Middleburg 32068

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: Clay County School Board
Person In Charge: Mr. Warmouth
PIC Email: Phone: 904336-6175

Inspection Information

Purpose: Routine
Inspection Date: 10/23/2024

Begin Time: 10:45 AM
End Time: 11:45 AM

Additional Information

FEMALES 342
MALES 371

CENSUS 713

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN 11. Group Toilet Rooms	IN 21. Pest Control
IN 1. School Site	IN 12. Toilet Facilities	SAFETY
IN 2. Playground, Equip & Athletic Fields*	IN 13. Handwashing Facilities	IN 22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN 15. Shower Facilities	NA 23. Sanitizers
IN 4. Construction	IN 16. Showers Water Temperatures	NA 24. Changing Station & Mats
OUT 5. Maintenance & Repair	WATER SUPPLY	NA 25. Hand Sink
IN 6. Lighting Standards	IN 17. Approved Source	NA 26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	IN 27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN 20. Solid Waste	IN 28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation	PEST CONTROL	IN 29. Other

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

No General Comments Available

Email Address(es): calvin.dell@myoneclay.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 10/28/2024 8:42:23 AM ****

2 of 2

Violations Comments

Violation #5. Maintenance & Repair

Monitor portable siding, one had siding bulging out below a window and several need repaired at base of doors at ramps.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 10/23/2024

Inspector Signature:

Client Signature: