

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



Facility Information

RESULT: Satisfactory

| | |
|--|---|
| Permit Number: 10-51-00045 Name of Facility: Lake Asbury Elementary Address: 2904 Sandridge Road City, Zip: Green Cove Springs 32043 Type: Public Schools Owner: Clay County School Board Person In Charge: Heather Roche - Principal (Chris Silcox) Phone: (904) 282-2994 PIC Email: Heather.Roche@myclay.net | Correct By: Next Inspection Re-Inspection Date: None |
|--|---|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 9/19/2023 | Begin Time: 01:12 PM End Time: 01:26 PM |
|--|--|

Additional Information

| | |
|--------------------------------------|------------------|
| FEMALES 450 MALES 450 | CENSUS 900 |
|--------------------------------------|------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|--|--|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* OUT 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms OUT 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal OUT 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION IN 23. Sanitizers IN 24. Changing Station & Mats IN 25. Hand Sink IN 26. Garbage Can ANIMAL HEALTH & SAFETY IN 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES IN 28. Maintenance/Complaint IN 29. Other |
|--|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Other conditions satisfactory
Accompanied by Chris Silcox

Email Address(es): Heather.Roche@myclay.net

Violations Comments

Violation #3. Athletic & Playground Equipment

One of the railings on the rock climbing set on the big kids playground is rusty and could present sharp edges for fingers
CODE REFERENCE: 3. Athletic and Playground Equipment. 5(2)(k)4 SREF. Athletic and playground equipment, where provided, shall be structurally sound, maintained firm and stable, vermin-proof, free of pockets or crevices where water will collect or vermin and pests may hide, and free from jagged or sharp projections, edges, or corners. Playground equipment includes the equipment itself (backstops, swings, slides, etc.) and its structural components (foundations, supporting members, exposed fasteners, etc.).

Violation #5. Maintenance & Repair

There is a roof leak (AC) in the 2nd grade bldg (Bldg 7)
CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

The 6th grade boys gang restroom is out of service due to urinal being broken off from the wall
CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #20. Solid Waste

One of the dumpsters is badly rusted out at the bottom
CODE REFERENCE: 20. Solid Waste. 5.(1)(e)8.e SREF. Trash and waste containers shall be provided in all areas, sufficient in number and emptied daily. Trash shall be stored in bins or containers in a central waste disposal area until removed. 5(1)(e)8.f SREF. Garbage, trash, & rubbish shall be collected, stored, and disposed of at a frequency and manner that prevents a sanitary nuisance. 5(11)(c)(d) SREF. Waste containers, including dumpsters, shall be accessible for maintenance and sanitation. Collectors and dumpsters shall be located on a concrete slab. Wet garbage shall be stored in impermeable, leak-proof, fly-tight containers. 468.2.3 FBC. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name:
Date: 9/19/2023

Inspector Signature:

Handwritten signature of Henry Klesh.

Client Signature:

Handwritten signature of Rashell P.

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



Facility Information

RESULT: Satisfactory

| | |
|---|---|
| Permit Number: 10-51-00729 Name of Facility: Lake Asbury Junior High Address: 2851 Sandridge Road City, Zip: Green Cove Springs 32043 Type: Public Schools Owner: Clay County School Board Person In Charge: Lisa Wright Phone: 904-284-6500 PIC Email: Lisa.wright@Myoneclay.net | Correct By: Next Inspection Re-Inspection Date: None |
|---|---|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 1/29/2024 | Begin Time: 11:18 AM End Time: 12:20 PM |
|--|--|

Additional Information

| | |
|--------------------------------------|------------------|
| FEMALES 475 MALES 475 | CENSUS 950 |
|--------------------------------------|------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|--|---|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction IN 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers NA 15. Shower Facilities NA 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal OUT 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY IN 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES IN 28. Maintenance/Complaint IN 29. Other |
|--|---|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

| |
|--|
| Other conditions satisfactory |
| Email Address(es): Lisa.wright@Myoneclay.net |

Inspector Signature:

Client Signature:

Handwritten signature

Handwritten signature: Lisa Wright

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #20. Solid Waste

One dumpster is missing a plug, dumpsters should be leakproof

CODE REFERENCE: 20. Solid Waste. 5.(1)(e)8.e SREF. Trash and waste containers shall be provided in all areas, sufficient in number and emptied daily. Trash shall be stored in bins or containers in a central waste disposal area until removed. 5(1)(e)8.f SREF. Garbage, trash, & rubbish shall be collected, stored, and disposed of at a frequency and manner that prevents a sanitary nuisance. 5(11)(c)(d) SREF. Waste containers, including dumpsters, shall be accessible for maintenance and sanitation. Collectors and dumpsters shall be located on a concrete slab. Wet garbage shall be stored in impermeable, leak-proof, fly-tight containers. 468.2.3 FBC. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Lisa Wright
Date: 1/29/2024

Inspector Signature:

H Klesh

Client Signature:

Lisa Wright

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



1 of 3

Facility Information

RESULT: Satisfactory

| | |
|--|---|
| Permit Number: 10-51-00046 Name of Facility: Lakeside Elementary School Address: 2752 Moody Avenue City, Zip: Orange Park 32073 Type: Public Schools Owner: Clay County School Board Person In Charge: Jeremey Strickland Phone: (904) 284-6500 PIC Email: Jeremy.Strickland@MyOneClay.net | Correct By: Next Inspection Re-Inspection Date: None |
|--|---|

Inspection Information

| | |
|---|--|
| Purpose: Routine Inspection Date: 10/18/2023 | Begin Time: 10:55 AM End Time: 11:48 AM |
|---|--|

Additional Information

| | | |
|--------------------------------------|--------------|-----|
| FEMALES 354 MALES 369 | CENSUS | 723 |
|--------------------------------------|--------------|-----|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|--|--|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* OUT 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms IN 12. Toilet Facilities OUT 13. Handwashing Facilities IN 14. Soap Dispensers NA 15. Shower Facilities NA 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source OUT 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other |
|--|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Satisfactory conditions overall.

One of the sinks within the boys restroom - 709 - is inoperable. A workorder has been created to address this.

Multiple lights are out within the library. A workorder has been created to address this.

One light is out within room 701. A workorder has been created to address this.

The water fountain near the field restrooms is inoperable. A workorder has been created to address this.

Nine light covers are missing within P51. A workorder has been created to address this.

Email Address(es): Jeremy.Strickland@MyOneClay.net;
Stephanie.Raucci@MyOneClay.net

Violations Comments

Violation #3. Athletic & Playground Equipment

Two of the swings at the playground used for the lower grades are inoperable. Correct prior to next inspection.

CODE REFERENCE: 3. Athletic and Playground Equipment. 5(2)(k)4 SREF. Athletic and playground equipment, where provided, shall be structurally sound, maintained firm and stable, vermin-proof, free of pockets or crevices where water will collect or vermin and pests may hide, and free from jagged or sharp projections, edges, or corners. Playground equipment includes the equipment itself (backstops, swings, slides, etc.) and its structural components (foundations, supporting members, exposed fasteners, etc.).

Violation #5. Maintenance & Repair

Room 802 has one ceiling tile with water damage. Repair/replace prior to next inspection.

The art room has one light that is missing one light cover. Correct prior to next inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #13. Handwashing Facilities

The handwashing sink within the handicap stall of the girls' restroom - 710 - has an inoperable sink that is missing its push-in cap.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

The water fountain within room 808 has low water pressure. Correct prior to next inspection.

The right water fountain near P51 is inoperable. Correct prior to next inspection.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Jeremey Strickland
Date: 10/18/2023

Inspector Signature:

Handwritten signature of Melissa Johnson in blue ink.

Client Signature:

Handwritten signature of Jeremey Strickland in blue ink.

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



1 of 3

Facility Information

RESULT: Satisfactory

| | |
|---|---|
| Permit Number: 10-51-00047 Name of Facility: Lakeside Jr High School Address: 2750 Moody Avenue City, Zip: Orange Park 32073 Type: Public Schools Owner: Clay County School Board Person In Charge: Calvin Dell Phone: (904) 284-6500 PIC Email: Calvin.Dell@MyOneClay.net | Correct By: Next Inspection Re-Inspection Date: None |
|---|---|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 3/19/2024 | Begin Time: 12:04 PM End Time: 01:10 PM |
|--|--|

Additional Information

| | |
|--------------------------------------|------------------|
| FEMALES 437 MALES 485 | CENSUS 922 |
|--------------------------------------|------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|---|--|---|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | OUT 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source OUT 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | OUT 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other |
|---|--|---|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

Melvin Johnson

Calvin Dell

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Janitorial closets locked at all times.
No animals observed on-site.
All offices are clean and in good repair.
All group care spaces are clean and in good repair.
Lunch tables are clean and in good repair.

Satisfactory conditions at time of inspection.

Email Address(es): Calvin.Dell@MyOneClay.net

Inspector Signature:

Melvin Johnson

Client Signature:

Calvin Dell

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Violations Comments

Violation #5. Maintenance & Repair

Water damaged tiles within Room 54, Building 2's 1st floor and 2nd floor hallways and within the supply storage in the kitchen of the cafeteria. Correct prior to next inspection.

Two missing ceiling tiles in Building 2's 1st floor hallway. Correct prior to next inspection.

One missing ceiling tile within Building 2's 2nd floor hallway. Correct prior to next inspection.

Multiple lights are out within the cafeteria, within the Building 1 and Building 2 hallways, Room 40 within Building 2, and within Portables 705, 732, and 737. Correct prior to next inspection.

One light is out within Room 30 in Building 1. Correct prior to next inspection.

Portables 702 and 732 are missing one light cover. Correct prior to next inspection.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #11. Group Toilet Rooms

The girls' cafeteria restroom has one stall that is missing one sanitary box. Correct prior to next inspection.

CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.

Violation #18. Drinking Fountains

The drinking fountain near Room 54 has low water pressure. Correct prior to next inspection.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Violation #21. Pest Control

Wasp nest outside of Building 2's 2nd floor exit door. Correct prior to next inspection.

CODE REFERENCE: 21. Pest Control. 5(1)(e)5 SREF. Operating pest management programs in accordance with the EPA's IPM in Schools guidelines (<http://schoolipm.ifas.ufl.edu/>), requiring use of effective measures to prevent harborage, propagation, or infestations of rodents, flies, cockroaches, & other insects on school premises. 5(10)(h) SREF. Pest control and termite protection of buildings and grounds shall be provided in accordance with FDACS regulations, and certificates shall be on file and available for inspection. 468.3.1 FBC. Buildings for occupancies shall be rodent proofed.

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Calvin Dell
Date: 3/19/2024

Inspector Signature:

Melissa Johnson

Client Signature:

Calvin Dell

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



**** BarnettP 10/6/2023 1:25:19 PM ****

1 of 2

Facility Information

RESULT: Satisfactory

| | |
|---|--|
| Permit Number: 10-51-00048 Name of Facility: McRae Elementary Address: 6770 County Road 315 C City, Zip: Keystone Heights 32656 Type: Public Schools Owner: Clay County School Board Person In Charge: Mrs Winkler Phone: 904-336-2125 PIC Email: | Correct By: None Re-Inspection Date: None |
|---|--|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 10/5/2023 | Begin Time: 11:15 AM End Time: 12:05 PM |
|--|--|

Additional Information

| | | |
|--------------------------------------|------------------|--|
| FEMALES 239 MALES 311 | CENSUS 550 | |
|--------------------------------------|------------------|--|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|--|--|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction IN 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers NA 15. Shower Facilities NA 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION IN 23. Sanitizers IN 24. Changing Station & Mats IN 25. Hand Sink IN 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES IN 28. Maintenance/Complaint IN 29. Other |
|--|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

| |
|---|
| Remind teachers to keep cleaning products out of reach of students. |
| Email Address(es): teresa.barfield@myoneclay.net |

Inspector Signature:

Client Signature:

Alan Davis

J. Barfield

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 10/6/2023 1:25:19 PM ****

2 of 2

Violations Comments

No Violation Comments Available

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 10/5/2023

Inspector Signature:

Alan Davis

Client Signature:

J. Barnett

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



**** Barnettp 10/25/2023 1:02:27 PM ****

1 of 2

Facility Information

RESULT: Satisfactory

| | |
|--|--|
| Permit Number: 10-51-00066 Name of Facility: Middleburg Elementary Address: 3958 Main Street City, Zip: Middleburg 32068 Type: Public Schools Owner: Clay County School Board Person In Charge: Becky Wilkerson Phone: 904 336 1875 PIC Email: | Correct By: None Re-Inspection Date: None |
|--|--|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 10/9/2023 | Begin Time: 10:50 AM End Time: 11:40 AM |
|--|--|

Additional Information

| | |
|--------------------------------------|------------------|
| FEMALES 265 MALES 283 | CENSUS 548 |
|--------------------------------------|------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|--|--|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction IN 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION IN 23. Sanitizers IN 24. Changing Station & Mats IN 25. Hand Sink IN 26. Garbage Can ANIMAL HEALTH & SAFETY IN 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES IN 28. Maintenance/Complaint IN 29. Other |
|--|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

| |
|---|
| No violations observed |
| Email Address(es): mark.osborne@myoneclay.net |

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** Barnettp 10/25/2023 1:02:27 PM ****

2 of 2

Violations Comments

No Violation Comments Available

Inspection Conducted By: Alan Davis (080243)
Inspector Contact Number: Work: (904) 278-3787 ex.
Print Client Name:
Date: 10/9/2023

Inspector Signature:

Handwritten signature of Alan Davis in blue ink.

Client Signature:

Handwritten signature of Mark DeBonne in blue ink.

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



1 of 3

Facility Information

RESULT: Satisfactory

| | |
|--|---|
| Permit Number: 10-51-00067 Name of Facility: Middleburg High School Address: 3802 County Road 220 City, Zip: Middleburg 32068 Type: Public Schools Owner: Clay County School Board Person In Charge: Buddy Gonzales Phone: (904) 284-6500 PIC Email: Manuel.Gonzales@myoneclay.net | Correct By: Next Inspection Re-Inspection Date: None |
|--|---|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 3/11/2024 | Begin Time: 08:42 AM End Time: 10:01 AM |
|--|--|

Additional Information

| | |
|--------------------------------------|-------------------|
| FEMALES 925 MALES 925 | CENSUS 1850 |
|--------------------------------------|-------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|---|--|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms OUT 12. Toilet Facilities OUT 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other |
|---|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 3

General Comments

Email Melissa.Johnson@FLHealth.gov when the violations listed within have been corrected.

Satisfactory conditions noted during this routine inspection.

Email Address(es): Manuel.Gonzales@myoneclay.net;
Stephanie.Raucci@MyOneClay.net

Violations Comments

Violation #5. Maintenance & Repair

One light is out within the hallway in front of the girls' restroom - 73 - and within room 137. Correct prior to next inspection.

The hallway within the girls' locker room has many inoperable lights. Correct prior to next inspection.

Multiple lights are out within the chorus room, the band room, within rooms 54, 72, 74, 93, 96, 189, 221, 226, 251, 351 and within the 92 - 96 hallway, the 300 hallway, and the library. Correct prior to next inspection.

One ceiling tile has water damage in hallway in front of room 316. Correct prior to next inspection.

Two ceiling tiles have water damage within room 62. Correct prior to next inspection.

Multiple ceiling tiles have water damage within room 181 and within the 114 -129 hallway. Correct prior to next inspection.

Multiple lights are out within P61. A workorder has been created to correct this.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

The boys' restroom - 353 - is missing soap. Correct prior to next inspection.

The boys' restroom - 74 - has one stall that is missing toilet paper. Correct prior to next inspection.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #13. Handwashing Facilities

The boys' restroom - 353 - has two inoperable faucets. Correct prior to next inspection.

The boys' restroom - 74 - has an inoperable faucet. Correct prior to next inspection.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



3 of 3

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Manuel Gonzales
Date: 3/11/2024

Inspector Signature:

Handwritten signature of Melissa Johnson in blue ink.

Client Signature:

Handwritten signature of Manuel Gonzales in blue ink.

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



Facility Information

RESULT: Satisfactory

| | |
|---|---|
| Permit Number: 10-51-00068 Name of Facility: Montclair Elementary Address: 2398 Moody Avenue City, Zip: Orange Park 32073 Type: Public Schools Owner: Clay County School Board Person In Charge: Michael Smith Phone: 904-336-1975 PIC Email: Michael.smith@myoneclay.net | Correct By: Next Inspection Re-Inspection Date: None |
|---|---|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 9/25/2023 | Begin Time: 12:47 PM End Time: 01:57 PM |
|--|--|

Additional Information

| | |
|--------------------------------------|------------------|
| FEMALES 250 MALES 250 | CENSUS 500 |
|--------------------------------------|------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|---|--|--|
| SCHOOL SANITATION IN 1. School Site OUT 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction IN 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers NA 15. Shower Facilities NA 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other |
|---|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

| |
|--|
| Other conditions appear satisfactory |
| Email Address(es): Michael.smith@myoneclay.net |

Inspector Signature:

Client Signature:

[Handwritten Signature]

[Handwritten Signature]

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #2. Playground, Equipment & Athletic Fields

There is a cracked and broken slide on the third grade playground (Not in use at this time)

CODE REFERENCE: 2. Playgrounds, Equipment and Athletic Fields. 5(2)(k) SREF. Playgrounds, equipment, and athletic fields where provided, shall be maintained in a safe and acceptable condition for the intended function. 5(2)(k)1 SREF. Play areas and athletic fields where fencing is provided shall comply with SREF, Section 5(2)(d). 5(2)(k)2 SREF. Pre-K, kindergarten, or day-care play areas, where provided, shall have direct access to and from their related classrooms or to a corridor providing immediate and safe access to the play area. 5 (2)(k)3 SREF. Play areas and athletic fields, where provided, shall have either direct access from the facility without crossing roads, traffic lanes, drives, or parking lots, or have appropriate safety devices provided where access crosses parking areas or drives. 5(2)(a)8 SREF. The playground shall be graded and drained to prevent an unintentional accumulation of standing surface water and debris. 468.2.2 FBC. Playground and equipment shall be safe, structurally sound, vermin proof, and shall not have jagged or sharp projections. Playground equipment shall be anchored to prevent toppling or dislodgement. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Michael Smith
Date: 9/25/2023

Inspector Signature:

Handwritten signature of Henry Klesh.

Client Signature:

Handwritten signature of Michael Smith.

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



**** BarnettP 4/29/2024 8:45:07 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

| | |
|---|---|
| Permit Number: 10-51-00835 Name of Facility: Oakleaf Village Elementary School Address: 410 Oakleaf Village Parkway City, Zip: Orange Park 32065 Type: Public Schools Owner: Clay County School Board Person In Charge: Jason Martin (Erin McDavid) Phone: 904-336-2433 PIC Email: Jason.martin@myoneclay.net | Correct By: Next Inspection Re-Inspection Date: None |
|---|---|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 4/26/2024 | Begin Time: 11:01 AM End Time: 12:06 PM |
|--|--|

Additional Information

| | |
|--------------------------------------|-------------------|
| FEMALES 550 MALES 550 | CENSUS 1100 |
|--------------------------------------|-------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|---|---|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source OUT 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION IN 23. Sanitizers IN 24. Changing Station & Mats IN 25. Hand Sink IN 26. Garbage Can ANIMAL HEALTH & SAFETY IN 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES IN 28. Maintenance/Complaint IN 29. Other |
|---|---|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

General Comments

| |
|---|
| Otherc conditions satisfactory Email Address(es): Jason.martin@myoneclay.net |
|---|

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 4/29/2024 8:45:07 AM ****

2 of 2

Violations Comments

Violation #5. Maintenance & Repair

There was a stained ceiling tile in room 300- noted on last inspection

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #18. Drinking Fountains

Two of the outside fountains were clogged with sand

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Jason Martin (Erin McDaid)
Date: 4/26/2024

Inspector Signature:

Client Signature:

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



1 of 2

Facility Information

RESULT: Satisfactory

| | |
|---|--|
| Permit Number: 10-51-1288429 Name of Facility: Oakleaf High School Address: 4035 Plantation Oaks Boulevard City, Zip: Orange Park 32065 Type: Public Schools Owner: Clay County School Board Person In Charge: Stacy Jackson Phone: 904-336-8375 PIC Email: Stacy.Jackson@myoneclay.net | Correct By: None Re-Inspection Date: None |
|---|--|

Inspection Information

| | |
|---|--|
| Purpose: Routine Inspection Date: 11/13/2023 | Begin Time: 11:35 AM End Time: 01:22 PM |
|---|--|

Additional Information

| | |
|--|-------------------|
| FEMALES 1250 MALES 1250 | CENSUS 2500 |
|--|-------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|--|--|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction IN 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other |
|--|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

[Handwritten Signature]

Client Signature:

[Handwritten Signature]

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Conditions Satisfactory- No violations noted
Recommen thermometers for refrigerators in ESE classrooms where milk or perishable items are stored and temperatures should be monitored to ensure items are maintained cold

Email Address(es): Stacy.Jackson@myoneclay.net

Violations Comments

No Violation Comments Available

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Stacy Jackson
Date: 11/13/2023

Inspector Signature:

Handwritten signature of Henry Klesh.

Client Signature:

Handwritten signature of Stacy Jackson.

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



**** BarnettP 4/22/2024 10:45:35 AM ****

1 of 2

Facility Information

RESULT: Satisfactory

| | |
|--|---|
| Permit Number: 10-51-00768 Name of Facility: Oakleaf Junior High School Address: 4085 Plantation Oaks Boulevard City, Zip: Orange Park 32065 Type: Public Schools Owner: Clay County School Board Person In Charge: Marvin Banks Phone: 904-336-5821 PIC Email: Marvin.Banks@myoneclay.net | Correct By: Next Inspection Re-Inspection Date: None |
|--|---|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 4/19/2024 | Begin Time: 12:42 PM End Time: 01:46 PM |
|--|--|

Additional Information

| | |
|--------------------------------------|-------------------|
| FEMALES 597 MALES 640 | CENSUS 1237 |
|--------------------------------------|-------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|--|--|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction IN 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms OUT 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal OUT 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION IN 23. Sanitizers IN 24. Changing Station & Mats IN 25. Hand Sink IN 26. Garbage Can ANIMAL HEALTH & SAFETY IN 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES IN 28. Maintenance/Complaint IN 29. Other |
|--|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

J. Gu

Marvin Banks

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



**** BarnettP 4/22/2024 10:45:35 AM ****

2 of 2

General Comments

Recommend Ice scoop with handle for teachers lounge (Using a bowl)
It was noted that the restrooms and sinks in the portables are not working- If they are connected to the sewer system - They need routine flushing

Other conditions were satisfactory

Marvin.banks@myoneclay.net
Wilnitra.Dixon@myoneclay.net

Email Address(es): Marvin.banks@myoneclay.net;
; Wilnitra.Dixon@myoneclay.net;

Violations Comments

Violation #12. Toilet Facilities

One toilet out of order -Bldg 400 boys restroom

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #20. Solid Waste

One of the dumpsters needs a plug to prevent leakage or vermin entry (Drain plug missing)

CODE REFERENCE: 20. Solid Waste. 5.(1)(e)8.e SREF. Trash and waste containers shall be provided in all areas, sufficient in number and emptied daily. Trash shall be stored in bins or containers in a central waste disposal area until removed. 5(1)(e)8.f SREF. Garbage, trash, & rubbish shall be collected, stored, and disposed of at a frequency and manner that prevents a sanitary nuisance. 5(1)(c)(d) SREF. Waste containers, including dumpsters, shall be accessible for maintenance and sanitation. Collectors and dumpsters shall be located on a concrete slab. Wet garbage shall be stored in impermeable, leak-proof, fly-tight containers. 468.2.3 FBC. A smooth nonabsorbent surface shall be provided for outdoor waste containers.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Marvin Banks
Date: 4/19/2024

Inspector Signature:

Client Signature:

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



1 of 2

Facility Information

RESULT: Satisfactory

| | |
|---|--|
| Permit Number: 10-51-00070 Name of Facility: Orange Park Elementary School Address: 1401 Plainfield Avenue City, Zip: Orange Park 32073 Type: Public Schools Owner: Clay County School Board Person In Charge: Tyler Wood Phone: (904) 278-2040 PIC Email: Tyler.wood@myoneclay.net | Correct By: None Re-Inspection Date: None |
|---|--|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 6/17/2024 | Begin Time: 12:25 PM End Time: 01:55 PM |
|--|--|

Additional Information

| | |
|------------------------------|----------------|
| FEMALES MALES | CENSUS 0 |
|------------------------------|----------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|--|--|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction IN 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers NA 15. Shower Facilities NA 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers IN 24. Changing Station & Mats IN 25. Hand Sink IN 26. Garbage Can ANIMAL HEALTH & SAFETY IN 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES IN 28. Maintenance/Complaint IN 29. Other |
|--|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

[Handwritten Signature]

Client Signature:

Mark - Thomas

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Inspection conducted with Building Official Mark Thomas
School is undergoing renovations in many restrooms
Some areas were inaccessible due to renovations.flooring work
Conditions satisfactory
Check for Vacuum breakers on outside hose bibbs

Email Address(es): Mark.thomas@myoneclay.net;
Tyler.wood@myoneclay.net

Violations Comments

No Violation Comments Available

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Tyler Wood
Date: 6/17/2024

Inspector Signature:

Handwritten signature of Henry Klesh.

Client Signature:

Handwritten signature of Mark Thomas.

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



1 of 2

Facility Information

RESULT: Satisfactory

| | |
|---|---|
| Permit Number: 10-51-00071 Name of Facility: Orange Park High School Address: 2300 Kingsley Avenue City, Zip: Orange Park 32073 Type: Public Schools Owner: Clay County School Board Person In Charge: Daniel Allen Phone: (904) 891-0655 PIC Email: Daniel.Allen@myoneclay.net | Correct By: Next Inspection Re-Inspection Date: None |
|---|---|

Inspection Information

| | |
|--|--|
| Purpose: Routine Inspection Date: 3/14/2024 | Begin Time: 08:35 AM End Time: 10:15 AM |
|--|--|

Additional Information

| | |
|--------------------------------------|-------------------|
| FEMALES 836 MALES 968 | CENSUS 1804 |
|--------------------------------------|-------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|--|--|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair OUT 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms IN 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers IN 15. Shower Facilities IN 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source IN 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION IN 23. Sanitizers IN 24. Changing Station & Mats IN 25. Hand Sink IN 26. Garbage Can ANIMAL HEALTH & SAFETY IN 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES IN 28. Maintenance/Complaint IN 29. Other |
|--|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Other conditions satisfactory
Note : There was a fire extinguisher dated 2021 in the male locker room

Email Address(es): Daniel.Allen@myoneclay.net

Violations Comments

Violation #5. Maintenance & Repair
There were stained ceiling tiles noted :
V102, Hall outside V157, Restroom ceiling In portable 63
The cafeteria wall near the credit union appears to have evidence of a leak
Also There is a possible leak from the Hydro Blast (Parts washer)- there was a puddle of water near the unit

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards
The light is out in room 159 Ceramics
CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Henry Klesh (5622)
Inspector Contact Number: Work: (904) 278-3786 ex.
Print Client Name: Daniel Allen
Date: 3/14/2024

Inspector Signature:

Handwritten signature of Henry Klesh.

Client Signature:

Handwritten signature of Daniel Allen.

**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT**



Facility Information

RESULT: Satisfactory

| | |
|---|---|
| Permit Number: 10-51-00072 Name of Facility: Orange Park Jr High Address: 1500 Gano Avenue City, Zip: Orange Park 32073 Type: Public Schools Owner: Clay County School Board Person In Charge: Arthur Allison Phone: (904) 284-6500 PIC Email: Arthur.Allison@MyOneClay.net | Correct By: Next Inspection Re-Inspection Date: None |
|---|---|

Inspection Information

| | |
|---|--|
| Purpose: Routine Inspection Date: 10/23/2023 | Begin Time: 12:33 PM End Time: 01:52 PM |
|---|--|

Additional Information

| | |
|--------------------------------------|------------------|
| FEMALES 392 MALES 421 | CENSUS 813 |
|--------------------------------------|------------------|

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

| | | |
|---|--|--|
| SCHOOL SANITATION IN 1. School Site IN 2. Playground, Equip & Athletic Fields* IN 3. Athletic & Playground Equipment BUILDING CONST/MAINT. IN 4. Construction OUT 5. Maintenance & Repair IN 6. Lighting Standards IN 7. Heating, Ventilation, A/C Standards IN 8. Natural Ventilation IN 9. Mechanical Ventilation SANITARY FACILITIES IN 10. Provided/Accessible/Separation | IN 11. Group Toilet Rooms OUT 12. Toilet Facilities IN 13. Handwashing Facilities IN 14. Soap Dispensers NA 15. Shower Facilities NA 16. Showers Water Temperatures WATER SUPPLY IN 17. Approved Source OUT 18. Drinking Fountains LIQUID WASTE & WASTE WATER IN 19. Sewage Disposal IN 20. Solid Waste PEST CONTROL | IN 21. Pest Control SAFETY IN 22. First Aid Kit DIAPER CHANGING STATION NA 23. Sanitizers NA 24. Changing Station & Mats NA 25. Hand Sink NA 26. Garbage Can ANIMAL HEALTH & SAFETY NA 27. Animal Maintenance/Aggressive DORM/RESIDENTIAL FACILITIES NA 28. Maintenance/Complaint NA 29. Other |
|---|--|--|

Marking Key: IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation

*Violation Key: * = 2. Playground, Equipment & Athletic Fields*

Inspector Signature:

Melissa Johnson

Client Signature:

Arthur Allison

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory conditions at time of inspection.

No pests observed at time of inspection.

Email Address(es): Arthur.Allison@MyOneClay.net;
Stephanie.Raucci@MyOneClay.net

Violations Comments

Violation #5. Maintenance & Repair

Many ceiling tiles throughout the school with water damage. In particular, the library has many ceiling tiles with water damage.

ISS is missing three ceiling tiles.

365 is missing two light covers.

516 is missing multiple light covers. A workorder was created previously to address this.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

The middle toilet within the girls' locker room is inoperable. A workorder has been created to address this.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Violation #18. Drinking Fountains

The water fountains outside the portables are inoperable.

The left water fountain within the gym near the boys' locker room is inoperable.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Melissa Johnson (67067)
Inspector Contact Number: Work: (904) 529-4761 ex.
Print Client Name: Arthur Allison
Date: 10/23/2023

Inspector Signature:

Client Signature: