

2024 - 2025 ARGYLE ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	701	ILB	010884	No evacuation map
	701A	ILB	010884	
2	702	ILB	010933	
	702A	ILB	010933	
3	703	MB E	001942	
4	704	MB E	001946	
5	705	MB E	001952	
6	706	MB E	001950	
	706A	MB E	001950	
7	707	MB E	002333	
	707A	MB E	002333	
8	708	MB E	002332	Emergency light does not work
9	710	MB E	002266	
	710A	MB E	002266	
	710B	MB E	002266	
10	711	MB E	001999	
	711A	MB E	001999	
11	713	MB E	002619	
	713A	MB E	002619	
	713B	MB E	002619	
	713C	MB E	002619	
	713D	MB E	002619	
	713E	MB E	002619	
12	714	MB E	002022	Exhaust fan is not working in restroom. Emergency lights don't work
	714A	MB E	002022	
13	801	ILB	010918	
	801A	ILB	010918	
14	802	ILB	010960	
	802A	ILB	010960	
15	803	ILB	010926	

2024 - 2025 ARGYLE ELEMENTARY SCHOOL CORRECTION LIST

	803A	IL-B	010926	
16	804	IL-B	010867	
	804A	IL-B	010867	
17	805	IL-B	010905	
	805A	IL-B	010905	
18	806	IL-B	010925	
	806A	IL-B	010925	
19	807	IL-B	010924	
	807A	IL-B	010924	
20	808	IL-B	010858	No evacuation map
	808A	IL-B	010858	
	901	IL-B	010950	The front and back exit door are blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36").
21				
	901A	IL-B	010950	
22	902	IL-B	010881	Fire extinguisher is not mounted within 5 feet of door
	902A	IL-B	010881	
23	903	N-E	010882	
	903A	N-E	010882	
24	904	IL-B	010992	
	904A	IL-B	010992	
25	905	MB E	002651	
	905A	MB E	002651	
26	906	MB E	002399	No evacuation map. Electrical panel is blocked by teacher decorations.
	906A	MB E	2399	
27	907	MB E	002366	No evacuation map
28	908	MB E	002258	No evacuation map
	908A	MB E	002258	

TOTAL 28

2024-2025 BANNERMAN LEARNING RESOURCE CENTER CORRECTION LIST

	056A	II-B	010932	
	58	IV-E	010932	
29	058A	IV-E	010932	
	011	MB E	001891	
31	011A	MB E	001891	
	014	MB E	001890	
32	014A	MB E	001890	No evacuation map
	014B	MB E	001890	
	031	MB E	001885	
33	031A	MB E	001885	
	031B	MB E	001885	
	031C	MB E	001885	
	050	MB E	001887	
34	050A	MB E	001887	This portable is the teachers lounge
	050B	MB E	001887	
	050C	MB E	001887	
	052	MB E	001892	
35	052A	MB E	001892	No evacuation map
	052B	MB E	001892	
	060A	IV-E	009019	THIS PORTABLE IS A RESTROOM
	060B	MB E	009019	DID NOT INSPECT
	061A	IV-E	009023	THIS PORTABLE IS A RESTROOM
	061B	MB E	009019	DID NOT INSPECT

TOTAL 33

2024-2025 BANNERMAN LEARNING RESOURCE CENTER CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
	016	MB E	002406	ITEMS THAT NEED TO BE CORRECTED
	062	MB E	002406	This is a portable shed did not inspect
2	001	MB E	001886	No evacuation map
3				PORTABLE IS BEING USED FOR A WEIGHT ROOM. There is a light fixture hanging from the ceiling in the storage room.
	001A	MB E	001886	
	001B	MB E	001886	
4	002	MB E	001880	
	002A	MB E	001880	
5	003	MB E	001879	
	003A	MB E	001879	
	004	MB E	001878	
6	004A	MB E	001878	
	005	MB E	001869	
7	005A	MB E	001869	
	006A	MB E	001877	
8	006B	MB E	001877	
	006C	MB E	001877	
9	007	MB E	001867	No evacuation map
	007A	MB E	001867	
10	008	MB E	001876	
	008A	MB E	001866	
11	009	MB E	002365	
	009A	MB E	002365	
12	010	MB E	001872	
	010A	MB E	001872	
13	012	MB E	001884	
	012A	MB E	001884	
14	013	E	001868	The electrical panel is covered by a poster. There is no evacuation map.
15	030	MB E	002559	No evacuation map
	030A	MB E	002559	

2024-2025 BANNERMAN LEARNING RESOURCE CENTER CORRECTION LIST

	030B	MB E	002559	
	030C	MB E	002559	
16	032	MB E	001870	No evacuation map
17	033	MB E	001881	
	033A	MB E	001881	
18	034	MB E	001873	
	034A	MB E	001873	
19	035	MB E	001882	Non approved rug at both exits
	035A	MB E	001882	
20	036	MB E	001889	
	036A	MB E	001889	Non-approved rug by the door
	036B	MB E	001889	
21	037	MB E	001874	
	037A	MB E	001874	
22	038	MB E	001875	Emergency light does not work
	038A	MB E	001875	
23	039	MB E	001883	
	039A	MB E	001883	No evacuation map
	039B	MB E	001883	
	039C	MB E	001883	
	039D	MB E	001883	
	039E	MB E	001883	
24	040	MB E	001871	
	040A	MB E	001871	
25	042	MB E	001888	
	042A	MB E	001888	
	042B	MB E	001888	
26	043	MB E	001830	No evacuation map
	043A	MB E	001830	
27	044	MB E	001847	
	044A	MB E	001847	
28	056	Il-B	010932	Bathroom light does not work

2024-2025 CHARLES E BENNETT ELEMENTARY CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	040	II-B	004972	Electrical panel blocked by clock
	040A	II-B	004972	
2	041	II-B	004887	
	041A	II-B	004887	
3	042	II-B	004974	This portable is being used for storage.
	042A	II-B	004974	
4	043	MB E	001844	
5	045	II-B	004971	No evacuation map
	045A	II-B	004971	
6	046	MB E	001848	
7	047	MB E	001849	
	047A	MB E	001849	
8	048	MB E	001852	
	048A	MB E	001852	
9	049	MB E	001858	
	049A	MB E	001858	
10	050	MB E	001853	
	050A	MB E	001853	
11	051	MB E	001857	Book stoarge
	051A	MB E	001857	
12	052	MB E	001851	No evacuation map
	052A	MB E	001851	
13	053	MB E	001854	
	053A	MB E	001854	
14	054	MB E	001841	
15	055	MB E	001862	No evacuation map
	055A	MB E	001862	
	055B	MB E	001862	
16	056	MB E	001861	Emergency light does not work
	056A	MB E	001861	
	056B	MB E	001861	

2024-2025 CHARLES E BENNETT ELEMENTARY CORRECTION LIST

17	057	MB E	001860	Receptacle by wash out sink in art room is not GFCL. No evacuation map.
	057A	MB E	001860	
	057B	MB E	001860	
18	501	MB E	001846	
19	502	MB E	001842	This is a custodial office
20	602A	MB E	001859	This is a cloths closet portable
	602B	MB E	001859	
21	603A	MB E	001839	
	603B	MB	001839	
22	604	MB E	001865	No evacuation map
	604A	MB E	001865	
	604B	MB E	001865	
23	605	LB	007804	Portable has moved
	605A	LB	007804	
24	702	MB E	001856	
	702A	MB E	001856	
25	703	MB E	001864	
	703A	MB E	001864	
	703B	MB E	001864	
26	57	MB E	1860	
29	803	MB E	1863	

TOTAL PORTABLES 27

2024-2025 CLAY HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	007	MB E	002157	
	007A	MB E	002157	
	007B	MB E	002157	
2	017	MB E	002144	no evacuation map
3	018	MB E	001855	No evacuation map
	018A	MB E	001855	
4	019	MB E	002596	
	020	MB E	002281	
5				
6	032	IL-B	005866	
	032A	IL-B	005866	
	033	MB E	002158	
7				
	033A	MB E	002158	
	033B	MB E	002158	
8	040	MB E	002220	
9	041	MB E	002223	
	041A	MB E	002223	
10	042	MB E	001840	
	042A	MB E	001840	
11	043	MB E	002214	No evacuation map
	043A	MB E	002214	
	043B	MB E	002214	
12	044	MB E	002652	
	044A	MB E	002652	
13	045	MB E	002653	
	045A	MB E	002653	

2024-2025 CLAY HIGH SCHOOL CORRECTION LIST

14	046	II-B	004975	
	046A	II-B	004975	
	046B	II-B	004975	
15	047	MB E	002649	
	047A	MB E	002649	
16	048	II-B	010902	Incorrect DCA sticker Should be MB E 010983
	048A	II-B	010902	
	049	MB E	001964	
17				No evacuation map
	049A	MB E	001964	
18	054	II-B	005277	
	054A	II-B	005277	
19	058	II-B	004260	Electrical box door has fallen off
20	005A	MB E	002037	No evacuation map
	005B	IV	002037	
21	008	MB E	002161	
	008A	MB E	002161	
	008B	MB E	002161	
	008C	MB E	002161	
22	031	MB E	002359	

2024-2025 CLAY HIGH SCHOOL CORRECTION LIST

TOTAL PORTABLES 22

2024-2025 CLAY HILL ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	682	MB E	002383	
	682A	MB E	002383	
	682B	MB E	002383	
2	701	MB E	002360	
3	703	MB E	002368	
4	704	MB E	002362	No evacuation map
5	705	MB E	002533	
	705A	MB E	002533	
6	706	MB E	002363	
7	707	MB E	002382	
	707A	MB E	002382	
	707B	MB E	002382	
8	708	MB E	002378	
	708A	MB E	002378	
9	709	MB E	002384	No evacuation map emergency light does not work
	709A	MB E	002384	
	709B	MB E	002384	
10	710	MB E	002369	
	710A	MB E	002369	
11	712	MB E	002370	No evacuation map
	712A	MB E	002370	
12	760	MB E	002373	No evacuation map
	760A	MB E	002373	
13	762	MB E	002377	No evacuation map
	762A	MB E	002377	
14	764	MB E	002371	
	764A	MB E	002371	
15	766	MB E	002379	
	766A	MB E	002379	

2024-2025 COPPERGATE ELEMENTARY CORRECTION LIST

[illegible]

2024-2025 DOCTORS INLET ELEMENTARY CORRECTION LIST

Quantity	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
	836	MB E	002017	Swing that is used for hook in ceiling is behind a cabinet. The ceiling does not have access to the trusses and cannot be reinforced.
1	836A	MB E	002017	
	837	MB E	002030	LARGE SHRUBS ALONG BUILDING MAY CAUSE DAMAGE TO BUILDING AND MAKE AN UNSAFE CAMPUS. They need to be trimmed so they are off the building or removed. Emergency light does not work.
2				
3	838	MB E	002019	
	838A	MB E	002019	
4	839	MB E	002003	
5	840	MB E	002001	
	842A	MB E	002036	Bushes are overgrown around portable and handicap ramp. They need to be trimmed so they are off the building or removed.
6				
7	843	MB E	002002	
	844	MB E	002009	BACK DOOR EXIT IS BLOCKED BY TREES AND SHRUBS MUST MOVE ASAP. 2023 back door still blocked.
8				
9	845	MB E	002031	
	845A	MB E	002031	
10	847	II-B	005499	
	847A	II-B	005499	
11	849	II-B	005498	
	849A	II-B	005498	
12	869	MB E	002033	
	869A	MB E	002033	
	869B	MB E	002033	
13	870	MB E	002545	
	870A	MB E	002545	

2024-2025 DOCTORS INLET ELEMENTARY CORRECTION LIST

	870B	MB E	002545	
	871	MB E	002034	
14	871A	MB E	002034	
	871B	MB E	002034	
15	872	MB E	002029	
	872A	MB E	002029	
16	873	MB E	002000	
17	874	MB E	002004	No DCA sticker and no documentation
18	876	MB E	002005	
19	888	II-B	005500	
	888A	II-B	005500	
20	889	MB E	002024	
	889A	MB E	002024	
21	890	MB E	002028	portable was removed
	890A	MB E	002028	
	890B	MB E	002028	
22	891	MB E	002021	blackberry bushes growing over ramp need to be trimmed
	891A	MB E	002021	
23	893	MB E	002027	
	893A	MB E	002027	
24	894	MB E	002016	
25	895	MB E	002032	
	895A	MB E	002032	
	895B	MB E	002032	
26	896	MB E	002018	
	896A	MB E	002018	
27	897	MB E	002020	
	897A	MB E	002020	
28	899	MB E	002026	Need to trim bushes going up ramp
	899A	MB E	002026	
	899B	MB	002026	

2024-2025 DOCTORS INLET ELEMENTARY CORRECTION LIST

29	921	MB E	002011	
	921A	MB E	002011	
	923	II-B	005501	Portable is being used as a weight room
30				with heavy weights
	923A	II-B	005501	
TOTAL PORTABLES = 30				

2024-2025 FLEMING ISLAND ELEMENTARY CORRECTION LIST

Quantity	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	601	MB E	002613	
	601A	MB E	002613	
	601B	MB E	002613	
2	602	MB E	002620	
	602A	MB E	002620	
	602B	MB E	002620	
3	603	MB E	002611	
	603C	MB E	002611	
	603D	MB E	002611	
4	604	MB E	002605	
	604A	MB E	002605	
5	605	MB E	002615	
	605A	MB E	002615	
	605B	MB E	002615	
6	606	MB E	002618	Emergency light does not work
	606A	MB E	002618	
	606B	MB E	002618	
7	607	MB E	002616	no evacuation map
	607A	MB E	002616	
	607B	MB E	002616	
8	608	MB E	002617	
	608A	MB E	002617	
	608B	MB E	002617	
9	801	MB E	002623	
	801A	MB E	002623	
	801B	MB E	002623	
	802	MB E	002624	emergency light does not work and no evacuation map
10	802A	MB E	002624	
	802B	MB E	002624	
11	803	MB E	002628	

2024-2025 FLEMING ISLAND ELEMENTARY CORRECTION LIST

	803A	MB E	002628	
	803B	MB E	002628	
12	804	MB E	002625	
	804A	MB E	002625	
	804B	MB E	002625	
13	805	MB E	002599	
	805A	MB E	002599	
14	806	MB E	002602	
	806A	MB E	002602	
15	807	MB E	002609	
	807A	MB E	002609	
	807B	MB E	002609	
16	812	MB E	002622	
	812A	MB E	002622	
	812B	MB E	002622	
17	821	MB E	002398	
18	824	MB E	002608	emergency light does not work
	824A	MB E	002608	
	824B	MB E	002608	
19	826	MB E	002610	
	826A	MB E	002610	
	826B	MB E	002610	
20	828	MB E	002598	
	828A	MB E	002634	
21	830	MB E	002634	
	830A	MB E	002634	
	830B	MB E	002634	
22	832	MB E	002635	
	832A	MB E	002635	
	832B	MB E	002635	
23	843	MB E	002607	

2024-2025 FLEMING ISLAND ELEMENTARY CORRECTION LIST

	843A	MB E	002607	
24	844	MB E	002600	no evacuation map
	844A	MB E	002600	
	846	II-B	010913	Electrical panel blocked by poster and cabinet.
25	846A	II-B	010913	
	848	MB E	002631	
26	848A	MB E	002631	
	848B	MB E	002631	
	850	MB E	002632	
27	850A	MB E	002632	
	850B	MB E	002632	
	860	MB E	002636	
28	860A	MB E	002636	
	860B	MB E	002636	
	861	MB E	002154	
29	861A	MB E	002154	
	861B	MB E	002154	
	862	II-B	010987	
30	862A	II-B	010987	
	899	IV-E	010987	
	901	II-B	010927	
31	901A	II-B	010927	
	904	MB E	002629	
32	904A	MB E	002629	
	904B	MB E	002629	
	905	II-B	010997	
33	905A	II-B	010997	
	906	MB E	002621	
34	906A	MB E	002621	
	906B	MB E	002621	
	907	MB E	002614	
35				

2024-2025 FLEMING ISLAND ELEMENTARY CORRECTION LIST

	907A	MB E	002614	
	907B	MB E	002614	
36	908	MB E	002612	
	908A	MB E	002612	
	908B	MB E	002612	
37	909	MB E	002630	THIS PORTABLE HAS BEEN MOVED!!
	909A	MB E	002630	
	909B	MB E	002630	
38	910	MB E	002626	
	910A	MB E	002626	
	910B	MB E	002626	
39	842	MB E	002637	no evacuation map
	842A	MB E	002637	
	842B	MB E	002637	
	842C	MB E	002637	
	842D	MB E	002637	
	842E	MB E	002637	
TOTAL PORTABLES = 38				
** NOTE SWING IN PORTABLE #605				

2024 - 2025 FLEMING ISLAND HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	010	MB E	002151	
	010A	MB E	002151	
2	011	MB E	002149	Floor tiles missing by the front door
	011A	MB E	002149	
3	012	MB E	002301	
	012A	MB E	002301	
4	013	Il-B	010993	
5	014	Il-B	010970	
6	015	Il-B	010951	
7	020	MB E	002143	
8	021	MB E	002300	There is no evacuation map
	022	MB E	2294	
9	022A	MB E	002294	
10	023	Il-B	010896	
	024	MB E	002299	No evacuation map and emergency light does not work
11				
12	025	Il-B	010936	
13	030	Il-B	010898	
	031	Il-B	010912	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
14				
15	032	Il-B	010897	
16	033	Il-B	010972	

2024 - 2025 FLEMING ISLAND HIGH SCHOOL CORRECTION LIST

	034	IL-B	010887	Back exit is blocked by a row of desk. Path of egress must be kept clear at all times. Relocate row of desk. Leading up to the door, there must be an egress path as wide as the door (36").
17				
18	035	IL-B	010971	
19	041	IL-B	010952	
20	042	IL-B	010860	
21	043	IL-B	010943	
22	044	IL-B	010911	
23	045	IL-B	010979	
24	046	MB E	002155	
	046A	MB E	002155	
	046B	MB E	002155	
	046C	MB E	002155	
25	047	MB E	002159	
	047A	MB E	002159	
	047B	MB E	002159	
	047C	MB E	002159	
	047D	MB E	002159	
26	049	MB E	002156	No evacuation map
27	050	IL-B	010885	No evacuation map
	050A	IL-B	010885	
28	051	IL-B	010935	No evacuation map
	051A	IL-B	010935	
	052	IL-B	010868	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
29	052A	IL-B	010868	

2024 - 2025 FLEMING ISLAND HIGH SCHOOL CORRECTION LIST

30	053	II-B	010859	
	053A	II-B	010859	
31	060	II-B	010910	
	060A	II-B	010910	
32	061	II-B	010975	
	061A	II-B	010975	
33	062	II-B	010909	
	062A	II-B	010909	
34	063	II-B	010969	
	063A	II-B	010969	
35	070	II-B	010942	
	070A	II-B	010942	
36	071	II-B	010986	
	071A	II-B	010986	
	072	II-B	010934	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
37	072A	II-B	010934	
38	073	II-B	010866	
	073A	II-B	010866	
39	080	II-B	010995	
	080A	II-B	010995	
40	081	II-B	010976	
	081A	II-B	010976	
41	082	MB E	002254	
	082A	MB E	002254	
42	083	II-B	004978	
	083A	II-B	004978	

2024 - 2025 FLEMING ISLAND HIGH SCHOOL CORRECTION LIST

	084	II-B	005000	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
43				
	084A	II-B	005000	
	085	II-B	007734	
44				
	085A	II-B	007734	
	086	II-B	007735	
45				
	086A	II-B	007735	
	087	II-B	007736	Back exit is blocked by a row of desk. Path of egress must be kept clear at all times. Relocate row of desk. Emergency light does not. 2023 violations still exist. 2024 violation still exists.
46				
	087A	II-B	007736	
	090	MB E	002147	
47				
	090A	MB E	002147	
	091	MB E	002253	The back exit door was blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36"). 2024 violation still exists and emergency light does not work.
48				
	092	MB E	002252	This portable is being used for storage
49				
	093	II-B	004977	
50				
	093A	II-B	004977	
	094	II-B	004980	
51				
	094A	II-B	004980	
	095	II-B	004976	
52				
	095A	II-B	004976	
	096	II-B	004981	
53				

2024 - 2025 FLEMING ISLAND HIGH SCHOOL CORRECTION LIST

	096A	I-B	004981	
	097	I-B	004979	
54	097A	I-B	004979	
	040	MB E	001837	
55	048	MB E	002160	Emergency light does not work no evacuation map
56	027A	I-B	006841	RESTROOMS-DID NOT INSPECT
	027B	I-B	006841	
	064A	I-B	005664	RESTROOMS- DID NOT INSPECT
	064B	I-B	005664	

TOTAL PORTABLES 51

2024-2025 GREEN COVE SPGS JUNIOR HIGH CORRECTION LIST

Quantity	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	070	1L-B	011075	Emergency light does not work
	070A	1L-B	011075	
2	071	1L-B	004973	Back exit is blocked by desks
	071A	1L-B	004973	
3	074	MB E	001995	Emergency light does not work
4	075	MB E	002467	
	075A	MB E	002467	
5	076	MB E	001996	
6	104	MB E	1829	
7	105	MB E	001831	
	105A	MB E	001831	
8	106	MB E	001836	
	106A	MB E	001836	
	106B	MB E	001836	
	106C	MB E	001836	
9	107	MB E	001835	Emergency light does not work
	107A	MB E	001835	
	107B	MB E	001835	
	107C	MB E	001835	
10	112	MB E	001834	
11	113	MB E	001838	Emergency light does not work
	113A	MB E	001838	
	113B	MB E	001838	
15	114	MB E	10978	New portable from Lake Asbury junior high drop ceiling broken several tiles missing
TOTAL PORTABLES = 12				

2024 - 2025 GROVE PARK ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	009	MB E	001929	
	009A	MB E	001929	
2	010	MB E	001928	
	010A	MB E	001928	
	010B	MB E	001928	
3	027	MB E	001917	
4	029	MB E	001934	
	029A	MB E	001934	
	029B	MB E	001934	
5	030	MB E	001933	Emergency light does not work
	030A	MB E	001933	
	030B	MB E	001933	
6	031	MB E	001932	No evacuation map.
	031A	MB E	001932	
	031B	MB E	001932	
7	043	MB E	001930	
	043A	MB E	001930	
	043B	MB E	001930	
8	044	MB E	001931	
	044A	MB E	001931	
	044B	MB E	001931	
9	071	MB E	001924	
	071A	MB E	001924	
10	500	MB E	001925	
	500A	MB E	001925	
11	501	MB E	001935	
	501A	MB E	001935	
	501B	MB E	001935	
12	504	MB E	002280	
13	505	MB E	002279	
14	506	MB E	002633	

2024 - 2025 GROVE PARK ELEMENTARY SCHOOL CORRECTION LIST

	506A	MB E	002633	
	506B	MB E	002633	
15	507	MB E	002557	
	507A	MB E	002657	
16	522	MB E	001911	
17	523	MB E	001912	No evacuation map
18	524	MB E	001922	
19	525	I-B	010984	
	525A	I-B	010984	
20	005	MB E	001921	
	005A	MB E	001921	
	005B	MB E	001921	
	005C	MB E	001921	
21	006	MB E	001939	
	006A	MB E	001939	
	006B	MB E	001939	
	006C	MB E	0019369	
	006D	MB E	001939	
	006E	MB E	001939	
22	007	MB E	001938	No evacuation map
	007A	MB E	001938	
	007B	MB E	001938	
	007C	MB E	001938	
	007D	MB E	001938	
23	520A	MB E	001937	
	520B	MB E	001937	
24	521A	MB E	001936	
	521B	MB E	001936	
25	008	MB E	001940	
	008A	MB E	001940	
	008B	MB E	001940	

2024 - 2025 GROVE PARK ELEMENTARY SCHOOL CORRECTION LIST

	008C	MB E	001940	
	008D	MB E	001940	
	008E	MB E	001940	
	008F	MB E	001940	
	008G	MB E	001940	
	008H	MB E	001940	
	008J	MB E	001940	
	008K	MB E	001940	
	008L	MB E	001940	
	008M	MB E	001940	

TOTAL 25

2024 - 2025 KEYSTONE HEIGHTS ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	701	MB E	002060	
2	702	MB E	002055	
	702A	MB E	002055	
3	703	MB E	002056	
	703A	MB E	002056	
4	704	MB E	002062	
	704A	MB E	002062	
5	705A	MB E	002057	No evacuation map
	705B	MB E	002057	
6	706	MB E	002387	non approved rugs by both doors
	706A	MB E	002387	
7	707	MB E	002066	
	707A	MB E	002066	
	707B	MB E	002066	
8	708	MB E	002067	
	708A	MB E	002067	
	708B	MB E	002067	
9	709	MB E	002575	Emergency light does not work
	709A	MB E	002575	
10	710	MB E	002335	No evacuation map
	710A	MB E	002335	
MOVED	712	MB E	002648	This portable has been moved off campus.
	712A	MB E	002648	
12	713	l-B	010878	
	713A	l-B	010878	
13	714	MB E	002069	No evacuation map
	714A	MB E	002069	
	714B	MB E	002069	
14	715	MB E	002058	
15	716A	MB E	002065	

2024 - 2025 KEYSTONE HEIGHTS ELEMENTARY SCHOOL CORRECTION LIST

	716B	MB E	002065	
	716C	MB E	002065	
MOVED	717	IL-B	010944	This portable has been moved off campus.
	717A	IL-B	010944	
17	718	IL-B	010982	
	718A	IL-B	010982	
18	719	IL-B	010919	
	719A	IL-B	010919	
19	720	IL-B	010879	
	720A	IL-B	010879	
20	721	MB E	002059	
21	724	MB E	002064	Emergency light does not work. No evacuation map.
	724A	MB E	002064	
MOVED	750	MB E	002063	This portable has been moved off campus.
	750A	MB E	002063	
23	751	MB E	002643	Back door is stuck and will not open.
	751A	MB E	002643	
	751B	MB E	002643	
	751C	MB E	002643	
MOVED	760	MB E	002061	This portable has been moved off campus
	760A	MB E	002061	
25	770	IL-B	005954	Electrical panel blocked by teacher decorations. No evacuation map.
	770A	IL-B	005954	
MOVED	771	IL-B	005951	This portable has been moved off campus
	771A	IL-B	005951	
27	772	IL-B	005952	This portable has been moved off campus
	772A	IL-B	005952	
MOVED	773	IL-B	005953	This portable has been moved off campus
	773A	IL-B	005953	
29	774	MB E	002405	Swing hanging from ceiling in classroom check with building department no evacuation map

2024 - 2025 KEYSTONE HEIGHTS ELEMENTARY SCHOOL CORRECTION LIST

	774A	MB E	002405	
	722	MB E	002070	
30	722A	MB E	002070	
	722B	MB E	002070	
	722C	MB E	002070	
	722D	MB E	002070	
	001A	Il-B	005773	This portable is a restroom. Did not inspect.
	001B	Il-B	005773	

TOTAL 24

2024 - 2025 KEYSTONE HEIGHTS JUNIOR SENIOR HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	001	MB E	002079	
2	002	MB E	002080	
3	004	MB E	002084	
4	006	MB E	002086	
	006A	MB E	002086	
	006B	MB E	002086	
5	011	MB E	002078	
6	012	MB E	002087	
	012A	MB E	002087	
7	013	MB E	002085	Emergency light is not on wall. No sticker on electrical panel.
8	014	MB E	002081	
9	015	MB E	002077	
10	016	MB E	002082	
11	017	MB E	002101	
	017A	MB E	002101	
	017B	MB E	002101	
12	018	MB E	002097	
	018A	MB E	002097	
13	019	MB E	002100	
	019A	MB E	002100	
	019B	MB E	002100	
14	020	MB E	002105	
	020A	MB E	002105	
	020B	MB E	002105	
15	021	MB E	002096	Missing floor tiles by door
	021A	MB E	002096	
16	022	MB E	002098	
	022A	MB E	002098	
17	023	MB E	002090	

2024 - 2025 KEYSTONE HEIGHTS JUNIOR SENIOR HIGH SCHOOL CORRECTION LIST

	023A	MB E	002090	
18	024	MB E	002093	
	024A	MB E	002093	
19	025	MB E	002094	
	025A	MB E	002094	
20	026	MB E	002092	
	026A	MB E	002092	
21	027	MB E	002095	
	027A	MB E	002095	
22	028	MB E	002106	
	028A	MB E	002106	
	028B	MB E	002106	
23	050	IL-B	005547	
	050A	IL-B	005547	
24	051	IL-B	010941	
	051A	IL-B	010941	
25	052	MB E	002071	
	052A	MB E	002071	
26	053	IL-B	010895	
	053A	IL-B	010895	
27	054	MB E	002089	Emergency light did not work
	054A	MB E	002089	
28	055	IL-B	010877	
	055A	IL-B	010877	
29	056	MB E	002099	
	056A	MB E	002099	
30	057	IL-B	010948	
	057A	IL-B	010948	
31	058	MB E	002103	
	058A	MB E	002103	
	058B	MB E	002103	

2024 - 2025 KEYSTONE HEIGHTS JUNIOR SENIOR HIGH SCHOOL CORRECTION LIST

32	059	MB E	002075	
33	060	MB E	002108	
	060A	MB E	002108	
	060B	MB E	002108	
34	061	MB E	002074	
35	062	MB E	002104	
	062A	MB E	002104	
	062B	MB E	002104	
36	063	MB E	002076	This portable is being used for book storage. IT cabinet is hanging from wall.
	063A	MB E	002076	
37	064	MB E	002088	
	064A	MB E	002088	
38	065	MB E	002073	Light switch by back door is missing cover. No evacuation map.
39	072	IL-B	007738	
	072A	IL-B	007738	
40	074	IL-B	007737	
	074A	IL-B	007737	
41	078	MB E	002456	Electrical panel is blocked by storage
	078A	MB E	002456	
42	080	MB E	002287	
43	082	IL-B	007740	Emergency Light does not work.
	082A	IL-B	007740	
44	084	IL-B	005365	
	084A	IL-B	005365	
45	090	MB E	002107	
	090A	MB E	002107	
	090B	MB E	002107	
46	091	MB E	002102	
	091A	MB E	002102	
	091B	MB E	002102	

2024 - 2025 KEYSTONE HEIGHTS JUNIOR SENIOR HIGH SCHOOL CORRECTION LIST

47	029	MB E	002109	
	029A	MB E	002109	
	029B	MB E	002109	
	029C	MB E	002109	
	056A	IV	069458	Restrooms - did not inspect
	056B	IV	069458	
	076A	II-B	006936	Restrooms - did not inspect
50	909	V	002630	

TOTAL 48

2023- 2024 LAKE ASBURY ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	009	MB E	002462	Both doors have non approved rugs.
	009A	MB E	002462	
2	010	MB E	002473	
	010A	MB E	002473	
	010B	MB E	002473	
	011	MB E	002451	The back exit door was blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36").
3	011A	MB E	002461	
	012	MB E	002461	Restroom has storage with no heat detector.
4	012A	MB E	002461	
	013	MB E	002476	
5	013A	MB E	002476	
	013B	MB E	002476	
6	014	MB E	002469	
	014A	MB E	002469	
	015	MB E	002479	The front door is partially blocked by a cabinet.
7	015A	N	002479	
	015B	N	002479	
	016	MB E	002490	The back exit door was blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36").An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
8	016A	MB E	002490	

2023- 2024 LAKE ASBURY ELEMENTARY SCHOOL CORRECTION LIST

9	018	MB E	001833	
	018A	MB E	001833	
	018B	MB E	001833	
10	039A	MB E	002454	Emergency light does not work in back room and swing is hanging from cieling. Check with building department to see if approved.
	039B	MB E	002454	
	039C	MB E	002454	
11	040	MB E	002463	Emergency light does not work
	040A	MB E	002463	
	041	MB E	002650	Need to repair electrical box beside microwave it is pulled out of the wall.
12	041A	MB E	002650	
	042	MB E	002466	Emergency light doesn't work. An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
	043	MB E	002465	Emergency light does not work
13	043A	MB E	002465	
	044	MB E	002468	Unapproved rug in front of door and emergency light does not work.
	044A	MB E	002468	
14	045	MB E	001976	Portable has no DCA sticker
	046	MB E	002474	Popcorn is falling out ceiling in bathroom.
	046A	MB E	002474	
15	046B	MB E	002474	
	048	MB E	002475	Storage in restroom with no heat detector
	048A	MB E	002475	
16	048B	MB E	002475	
	048B	MB E	002475	
	048B	MB E	002475	

2023- 2024 LAKE ASBURY ELEMENTARY SCHOOL CORRECTION LIST

19	069	MB E	002453	
	069A	MB E	002453	
20	071	MB E	002478	front door porch light is missing and the box is open with wires.
	071A	MB E	002478	
	071B	MB E	002478	
	072	MB E	002455	Back door was locked by a non-conforming device. This device is only to be used during an emergency situation. This is a major violation. This will be reported to the Fire Marshall. The back exit door was blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36").
21	072A	MB E	002455	
	073	MB E	002452	
22	073A	MB E	002452	
	074	MB E	002450	
23	075	MB E	002477	
24	075A	MB E	002477	
	075B	MB E	002477	
25	076	IV-E	009466	
	076A	IV-E	009466	
26	077	II-B	023247	Restroom with storage and no heat detector
	077A	II-B	023247	
27	079	MB E	002421	
	079A	MB E	002421	
	079B	MB E	002421	
	079C	MB E	002421	
28	080	II-B	005482	Restroom with storage and no heat detector
	080A	IV-E	005482	
29	081	II-B	002540	

2023- 2024 LAKE ASBURY ELEMENTARY SCHOOL CORRECTION LIST

	081A	Il-B	002540	
30	082	Il-B	002541	Restroom with storage and no heat detector
	082A	Il-B	002541	
31	084	Il-B	005480	Restroom with storage and no heat detector
	084A	Il-B	005480	
32	086	N-E	009475	Restroom with storage and no heat detector
	086A	N-E	009475	
33	087	MB E	002457	DCA STICKER IS MISSING
	087A	MB E	002457	
34	088	Il-B	000752	DCA STICKER MISSING. HAS DOCUMENTATION FOR STICKER
	088A	Il-B	000752	
35	089	MB E	002458	Restroom with storage and no heat detector
	089A	MB E	002458	
	090	Il-B	000861	DCA STICKER MISSING. HAS DCA DOCUMENTATIONAn object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
36	090A	Il-B	000861	
37	091	MB E	002460	Storage in restroom with no heat detector
	091A	MB E	002460	
38	093	MB E	002381	
	093A	MB E	002381	

2023- 2024 LAKE ASBURY ELEMENTARY SCHOOL CORRECTION LIST

	094	MB E	002480	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
39				
	094A	MB E	002480	
	094B	MB E	002480	
40	095	IL-B	005366	Storage in restroom with no heat detector
	095A	IL-B	005366	
41	096	IL-B	005368	Storage in restroom with no heat detector
	096A	IL-B	005368	
	085	MB E	002448	This portable is the clinic. All GFCI breakers or receptacles labeled as GFCI are not protected. Bathroom fan does not work
42				
	085A	MB E	002448	
	085B	MB E	002448	
	085C	MB E	002448	

2024 - 2025 LAKE ASBURY JUNIOR HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	390	IL-B	010893	
	390A	IL-B	010893	
2	391	IL-B	010966	
	391A	IL-B	010966	
3	392	IL-B	005481	
	392A	IL-B	005481	
5	393	IL-B	010949	
	393A	IL-B	010949	
6	394	MB E	002148	
	394A	MB E	002148	
7	401	IL-B	010892	Not approved rug outside back door
	401A	IL-B	010892	
8	402	IL-B	010915	Tiles from drop ceiling missing by back exit
	402A	IL-B	010915	
9	403	IL-B	010989	
	403A	IL-B	010989	
10	404	IL-B	010890	
	404A	IL-B	010890	
11	405	IL-B	010921	
	405A	IL-B	010921	
12	406	IL-B	005503	
	406A	IL-B	005503	
13	407	IL-B	010938	Back door is blocked by group of desks
	407A	IL-B	010938	
14	408	IL-B	005502	
	408A	IL-B	005502	
15	409	IL-B	010888	
	409A	IL-B	010888	
16	410	IL-B	007733	
	410A	IL-B	007733	
17	421	MB E	002169	Electrical panel was missing sticker
	421A	MB E	002169	
18	422	MB E	002364	

2024 - 2025 LAKE ASBURY JUNIOR HIGH SCHOOL CORRECTION LIST

19	423	MB E	002170	
	423A	MB E	002170	NO EVACUATION MAP BY DOOR
20	424	MB E	002262	
21	425	II-B	010974	
	425A	II-B	010974	
22	426	II-B	010978	This portable has been moved
	426A	II-B	010978	
23	427	II-B	10930	
	427A	II-B	10930	
24	428	II-B	007726	
	428A	II-B	007726	
25	430	II-B	005367	This portable is being used for storage and has no DCA sticker
	430	II-B	005367	
27	423	II-B	10894	

2024 - 2025 LAKESIDE JUNIOR HIGH CORRECTION LIST

13	732	MB E	002025	
	732A	MB E	002025	
14	733	MB E	002168	
	733A	MB E	002168	
15	734	MB E	002006	
16	735	MB E	002167	
17	791	MB E	002162	
	791A	MB E	002162	
	791B	MB E	002162	
	791C	MB E	002162	
18	793	MB E	002201	
	793A	MB E	002201	
19	794	MB E	002176	No evacuation map
	794A	MB E	002176	
	794B	MB E	002176	
	794C	MB E	002176	
20	710	MB E	002180	No evacuation map
	710A	MB E	002180	
	710B	MB E	002180	
21	737	MB E	002179	
	737A	MB E	002179	
	737B	MB E	002179	
	745	MB E	002181	THIS PORTABLE IS BEING USED FOR A LOCKER ROOM
22				
	745A	MB E	002181	
	745B	MB E	002181	
	745C	LB	002181	

TOTAL 22

2024-2025 LAKESIDE ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	010	MB E	002192	
2	011	MB E	002196	
3	012	MB E	002205	
	012A	MB E	002205	
4	013	MB E	002195	
5	014	MB E	002193	
6	015	MB E	002194	
7	016	MB E	002199	
8	017	MB E	002200	No evacuation map
9	018	Il-B	005484	
	018A	Il-B	005484	
10	019	Il-B	007525	
	019A	Il-B	007525	
11	020	MB E	002203	No evacuation map
12	021	Il-B	007526	GFCI outlet in bathroom does not work. Fire extinguisher was covered by jacket
	021A	Il-B	007526	
13	022	MB E	002188	No evacuation map
14	023	MB E	002189	No evacuation map
15	024	MB E	002187	
16	025	MB E	002190	
17	026	MB E	002186	
18	027	MB E	002191	No evacuation map
19	042A	MB E	002185	
	042B	MB E	002185	
20	044	Il-B	005092	
	044A	Il-B	005092	
21	045	MB E	002208	
	045A	MB E	002208	
22	046	MB E	002207	
	046A	MB E	002207	

2024-2025 LAKESIDE ELEMENTARY SCHOOL CORRECTION LIST

23	047	MB E	002209	No evacuation map
	047A	MB E	002209	
	047B	MB E	002209	
	047C	MB E	002209	
	048	Il-B	005797	
24				
	048A	Il-B	005797	
25	051A	MB E	002184	
	051B	MB E	002184	
	051C	MB E	002184	
26	052	Il-B	007527	
	052A	Il-B	007527	
27	053	Il-B	007583	
	053A	Il-B	007583	
28	054	Il-B	007584	
	054A	Il-B	007584	
29	055	Il-B	007585	
	055A	Il-B	007585	
30	056	Il-B	007717	
	056A	Il-B	007717	
	060	MB E	002481	
31				Portable is being used as storage and custodial office gasoline is being stored in the portable
	060A	N	002481	
32	061	Il-B	007694	No evacuation map
	061A	Il-B	007694	
33	062	Il-B	007693	
	062A	Il-B	007693	
34	063	Il-B	007604	

2024-2025 LAKESIDE ELEMENTARY SCHOOL CORRECTION LIST

	063A	II-B	007604	
35	043	MB E	002278	No evacuation map
36	57	IV-E	7076	

TOTAL 36

2024 - 2025 LAKESIDE JUNIOR HIGH CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	701	MB E	002177	
	701A	MB E	002177	
	701B	MB E	002177	
2	702	MB E	002173	fire extinguisher bracket pulled out of wall needs to be replaced
	702A	MB E	002173	
3	703	MB E	002178	
	703A	MB E	002178	
	703B	MB E	002178	
4	704	MB E	002172	
	704A	MB E	002172	
5	705	MB E	002174	
	705A	MB E	002174	
	705B	MB E	002174	
	705C	MB E	002174	
6	706	MB E	002171	
	706A	MB E	002171	
7	707	II-B	010962	
	707A	II-B	010962	
8	708	MB E	002165	
	708A	MB E	002165	
	708B	MB E	002165	
	721	MB E	002388	
9				
10	722	MB E	002164	
11	723	N-E	002542	
	723A	N-E	002542	
12	731	MB E	002166	
	731A	MB E	002166	

2023 - 2024 MCRAE ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	401	MB E	002592	
	401A	MB E	002592	
	401B	MB E	002592	
2	402	MB E	002586	
	402A	MB E	002586	
3	403	MB E	002593	
	403A	MB E	002593	
	403B	MB E	002593	
4	404	MB E	002580	No evacuation map
5	405	MB E	002577	
6	406	MB E	002587	
	406A	MB E	002587	
7	407	MB E	002585	
	407A	MB E	002585	
8	408	MB E	002583	
	408A	MB E	002583	
9	701	MB E	002576	
10	702	MB E	002591	
	702A	MB E	002591	
11	703	MB E	002584	
	703A	MB E	002584	
12	704	MB E	002590	
	704A	MB E	002590	
13	705	MB E	002578	
14	706	MB E	002581	
15	707	MB E	002579	
16	708	Il-B	010906	
	708A	Il-B	010906	
17	801	Il-B	010937	
	801A	Il-B	010937	
18	802	Il-B	010914	

2023 - 2024 MCRAE ELEMENTARY SCHOOL CORRECTION LIST

	802A	IL-B	010914	
	803	IL-B	010961	
19	803A	IL-B	010961	
	804	IL-B	010870	
20	804A	IL-B	010870	
	806	MB E	002049	
21	806A	MB E	002049	
	821	MB E	002595	
22	821A	MB E	002595	
	821B	MB E	002595	
	823	MB E	002594	swing hanging from ceiling check with building department
23	823A	MB E	002594	
	823B	MB E	002594	
	824	MB E	002571	swing hanging from ceiling check with building department
24	825	MB E	002588	swing hanging from ceiling check with building department
25	825A	MB E	002588	
	826	MB E	002572	swing hanging from ceiling check with building department
26	827	MB E	002582	
27	828A	MB E	002573	
28	828B	MB	002573	
	842	MB E	002656	
29	842A	MB E	002656	

TOTAL 29

2024 - 2025 MIDDLEBURG ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	023	MB E	002051	No evacuation map
	023A	MB E	002051	
	024	MB E	002040	
2	024A	MB E	002040	
3	025	MB E	002041	Storage room
	025A	MB E	002041	
4	035	MB E	002044	
5	037	MB E	002043	
	037A	MB E	002043	
6	038	MB E	002039	
7	039	MB E	002047	
8	040	MB E	002052	
	040A	MB E	002052	
9	041	MB E	002042	
	041A	MB E	002042	
10	043	MB E	002050	
	043A	MB E	002050	
11	055	MB E	002038	
	055A	MB E	002038	
12	057	ILB	005570	
	057A	ILB	005570	
13	059	ILB	010923	
	059A	ILB	010923	
14	064	ILB	010856	
	064A	ILB	010856	
15	065A	MB E	002114	
	065B	IL-E	002114	
16	068	ILB	010864	
	068A	ILB	010864	
17	069	MB E	002046	
	069A	MB E	002046	

2024 - 2025 MIDDLEBURG ELEMENTARY SCHOOL CORRECTION LIST

18	026A	MB E	002054	
	026B	MB E	002054	
19	029A	MB E	002053	
	029B	MB E	002053	

2024-2025 MIDDLEBURG HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	001	ILB	004261	
2	007	MB E	002302	
3	009	MB E	002296	Electrical panel is blocked by decoration, no evacuation map
	009A	MB E	002296	
4	031	MB E	002308	
	031A	MB E	002308	
	031B	MB E	002308	
5	032	MB E	002305	
	032A	MB E	002305	
	032B	MB E	002305	
6	033	MB E	002303	
	033A	MB E	002303	
7	034	MB E	002297	
8	035	MB E	002295	
9	036	MB E	002309	
	036A	MB E	002309	
	036B	MB E	002309	
10	041	MB E	002310	
	041A	MB E	002310	
	041B	MB E	002310	
11	042	MB E	002311	
	042A	MB E	002311	
	042B	MB E	002311	
12	043	MB E	002312	
13	044	MB E	002313	
	044A	MB E	002313	
	044B	MB E	002313	
14	045	MB E	002314	
	045A	MB E	002314	
	045B	MB E	002314	
15	046	MB E	002315	

2024-2025 MIDDLEBURG HIGH SCHOOL CORRECTION LIST

	046A	MB E	002315	
	046B	MB E	002315	
16	051	MB E	002317	Electrical panel covered by decoration emergency light does not work
	051A	MB E	002317	
	051B	MB E	002317	
17	052	MB E	002318	Emergency light does not work
	052A	MB E	002318	
	052B	MB E	002318	
18	053	MB E	002319	
	053A	MB E	002319	
	053B	MB E	002319	
19	055	MB E	002304	
	055A	MB E	002304	
20	060	MB E	001962	
21	061	IL-B	005087	
	061A	IL-B	005087	
22	062	IL-B	005003	
	062A	IL-B	005003	
23	063	IL-B	005088	panel have been changed out and DCA sticker missing
	063A	IL-B	005088	
24	064	IL-B	005002	
	064A	IL-B	005002	
25	065	IL-B	005001	Emergency light does not work
	065A	IL-B	005001	
26	066	IL-B	005089	
	066A	IL-B	005089	
27	067	IL-B	005004	
	067A	IL-B	005004	
28	070	IL-B	010876	Fire extinguisher is blocked by storage.
29	071	MB E	002150	
	071A	MB E	002150	

2024-2025 MIDDLEBURG HIGH SCHOOL CORRECTION LIST

30	072	II-B	010940	
31	073	MB E	002298	This portable is being used for Custodial office
	073A	MB E	002298	
	073B	MB E	002298	
32	074	MB E	002306	Emergency light does not work
	074A	MB E	002306	
	074B	MB E	002306	
33	075	II-B	010955	
	075A	II-B	010955	
34	076	MB E	002307	
	076A	MB E	002307	
	076B	MB E	002307	
35	077	N-E	001975	
	077A	N-E	001975	
	077B	N-E	001975	
	077C	N-E	001975	
	077D	N-E	001975	
36	078	MB E	001973	
	078A	II-B	001973	
37	079	MB E	001974	Fire extinguisher is blocked by storage
	079A	MB E	001974	
	079B	MB E	001974	
	079C	MB E	001974	
38	080	II-B	007805	
	080A	II-B	007805	
39	081	MB E	001941	
40	082	MB E	002218	No evacuation map
41	084	MB E	002401	
	084A	MB E	002401	
42	086	MB E	002367	
43	088	MB E	002404	

2024-2025 MIDDLEBURG HIGH SCHOOL CORRECTION LIST

44	005	MB E	002322	
	005A	MB E	002322	
	005B	MB E	002322	
	005C	MB E	002322	
45	054A	MB E	002321	
	054B	MB E	002321	
	054C	MB E	002321	
	054D	MB E	002321	

2024-2025 MONTCLAIR ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	021	MB E	002197	
2	022	MB E	002183	
3	023	N-E	009474	
	023A	N-E	009474	
4	024	MB E	002597	
	024A	MB E	002597	
5	025A	MB E	002277	
	025B	MB E	002277	
6	26	MB E	002284	The wood ramp does not have the correct handrail. Install correct handrail to meet ADA.
7	027	MB E	002283	Electrical panel is blocked by cabinet
8	028	IL-B	000860	
	028A	IL-B	000860	
9	029	MB E	002601	
	029A	MB E	002601	
10	030	IL-B	005094	
	030A	IL-B	005094	
11	031	MB E	002272	
12	032	MB E	002288	No emergency map
	032A	MB E	002288	
13	033	MB E	002290	
	033A	MB E	002290	
14	034	MB E	002289	
15	035	MB E	002274	
16	036	MB E	002292	
	036A	MB E	002292	
	036B	MB E	002292	
17	037	MB E	002291	
	037A	MB E	002291	
18	038	MB E	002286	Emergency light does not work

2024-2025 MONTCLAIR ELEMENTARY SCHOOL CORRECTION LIST

19	039	MB E	002293	
	039A	MB E	002293	
	039B	MB E	002293	
20	040	MB E	002276	Emergency light did not work. Electrical outlet by door has busted face plate.
21	041	MB E	002275	
22	042	MB E	002268	
23	043	MB E	002238	
24	044	MB E	002273	
25	045	MB E	002198	
26	046A	MB E	002285	
	046B	MB E	002285	
27	047	MB E	002486	

TOTAL 27

2024 - 2025 OAKLEAF VILLAGE ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	901	II-B	007448	Electrical panel is blocked by shelves.
	901A	II-B	007448	
	903	II-B	010894	non-approve rug by both doors. Electrical panel is blocked by magnetic decoration outlet next to classroom sink does not work.
2	903A	II-B	010894	
	905	MB E	002324	The bathroom is being used as storage without a smoke detector. non approved rugs by door. no evacuation map.
3	905A	MB E	002324	
	906	MB E	001920	
4	906A	MB E	001920	
	907	MB E	002120	
5	907A	MB E	002120	
	908	II-B	010983	DCA sticker should be MB E 010902
6	908A	II-B	010983	
	909	II-B	005483	
7	909A	II-B	005483	
	910	II-B	007741	
8	910A	II-B	007741	
	911	II-B	005332	
9	911A	II-B	005332	
	912	II-B	005091	
10	912A	II-B	005091	
	913	IV-E	009469	
11	913A	IV-E	009469	
	914	II-B	005093	
12	914A	II-B	005093	
	916	II-B	010956	
13	916A	II-B	010956	
	902	II-B	7446	No evacuation map
14	904	II-B	10862	
15				

TOTAL 15

2024 - 2025 OAKLEAF JUNIOR HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	601	IL-B	005364	Non-approved rug at back door
	601A	IL-B	005364	
2	602	IL-B	005335	
	602A	IL-B	005335	
3	603	IL-B	005363	Non-approved rugs by both doors
	603A	IL-B	005363	
4	604	IL-B	005545	
	604A	IL-B	005545	
5	605	IL-B	005283	
	605A	IL-B	005283	
6	606	IL-B	005331	Exhaust fan in bathroom does not work
	606A	IL-B	005331	
7	607	IL-B	005284	
	607A	IL-B	005284	
8	608	IL-B	005285	
	608A	IL-B	005285	
9	609	IL-B	005274	Electrical outlet behind teachers desk is missing face plate.
	609A	IL-B	005274	
10	610	IL-B	005282	
	610A	IL-B	005282	
11	611	IL-B	005330	Insignia sticker is missing from electrical box. There is a hole in the floor by the back door.
	611A	IL-B	005330	
12	612	IL-B	005141	
	612A	IL-B	005141	
13	613	IL-B	005149	The bathroom is being used as storage without a smoke detector.
	613A	IL-B	005149	
14	614	IV-E	005145	
	614A	IV-E	005145	
15	615	IL-B	005143	The bathroom is being used as storage without a smoke detector
	615A	IL-B	005143	

2024 - 2025 OAKLEAF HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	010	MB E	001990	
	010A	MB E	001990	
2	011	MB E	001993	
	011A	MB E	001993	
3	15	MB E	002228	
	015A	MB E	002228	
	015B	MB E	002228	
	015C	MB E	002228	
	015D	MB E	002228	
4	016	MB E	002224	
	016A	MB E	002224	
5	021	LB B	010883	
	021A	LB B	010883	
	022	LB B	010985	Back exit is blocked by a row of desk. Path of egress must be kept clear at all times. Relocate row of desk. Leading up to the door, there must be an egress path as wide as the door (36"). No DCA insignia.
6	022A	LB B	010985	
7	023	MB E	002459	
	023A	MB E	002459	
8	024	MB E	002449	Heat detector is hanging from ceiling in closet no evacuation map
	024A	MB E	002449	
9	025	LB B	010865	
	025A	LB B	010865	
10	026	LB B	010908	
	026A	LB B	010908	
	030	IV-E	010891	Back exit is blocked by a row of desk. Path of egress must be kept clear at all times. Relocate row of desk. Leading up to the door, there must be an egress path as wide as the door (36"). Emergency light does not work.
11	030A	IV-E	010891	
12	31	MB E	001945	No evacuation map
13	032	MB E	001970	No evacuation map

2024 - 2025 OAKLEAF HIGH SCHOOL CORRECTION LIST

14	033	MB E	001843	
15	034	ILB	010991	
	034A	ILB	010991	
16	035	MB E	001916	
17	036	MB E	002323	
18	040	MB E	001987	
19	041	ILB	010869	Emergency light does not work
	041A	ILB	010869	
	042	ILB	010857	Back exit is blocked by a row of desk. Path of egress must be kept clear at all times. Relocate row of desk. Leading up to the door, there must be an egress path as wide as the door (36").
20				Emergency light does not work.
	042A	ILB	010857	
21	043	MB E	002141	
	043A	MB E	002141	
22	044	MB E	001845	
23	045	MB E	002325	
24	046	MB E	002012	
	046A	N	002012	
25	050	MB E	002163	
26	051	MB E	002083	
	051A	MB E	002083	
	052	MB E	002226	Back exit is blocked by a row of desk. Path of egress must be kept clear at all times. Relocate row of desk. Leading up to the door, there must be an egress path as wide as the door (36"). No DCA insignia.
27				
28	053	MB E	002264	
	053A	MB E	002264	
	053B	MB E	002264	
29	054	ILB	007453	
	054A	ILB	007453	
	055	MB E	002250	An object is blocking access to the electrical panel, or the electrical panel was covered by an object. Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide. Back door is blocked by clothing storage.
30				

2024 - 2025 OAKLEAF HIGH SCHOOL CORRECTION LIST

[illegible]

2024 - 2025 OAKLEAF JUNIOR HIGH SCHOOL CORRECTION LIST

16	616	IL-B	005144	
	616A	IL-B	005144	
17	617	IL-B	005148	
	617A	IL-B	005148	
18	618	IL-B	005147	
	618A	IL-B	005147	
19	619	IL-B	005152	
	619A	IL-B	005152	
20	620	IL-B	005146	
	620A	IL-B	005146	
	702	IL-B	010862	HAS BEEN MOVED
22	704	IL-B	005333	
	704A	IL-B	005333	
23	708	IL-B	005329	Non-approved rugs by both doors
	708A	IL-B	005329	
24	709	IL-B	005150	This portable has been moved
	709A	IL-B	005150	
25	710	IL-B	005151	This portable has been moved
	710A	IL-B	005151	
26	711	IL-B	005278	bathroom being used for storage with no smoke detector
	711A	IL-B	005278	
27	712	IL-B	005275	This portable has been moved
	712A	IL-B	005275	
28	713	IL-B	005281	Back door is blocked by a row of desks non-approved rug by back door.
	713A	IL-B	005281	
29	714	IL-B	005279	This portable has been moved
	714A	IL-B	005279	
	801	IL-B	007445	HAS BEEN MOVED
31	807	IL-B	005095	
	807A	IL-B	005095	
32	809	IL-B	005097	missing ceiling tile by back door

2024 - 2025 OAKLEAF JUNIOR HIGH SCHOOL CORRECTION LIST

	809A	Il-B	005097	
	810	Il-B	005142	
33	810A	Il-B	005142	treadmill in front of the back exit and weightlifting benches with stacks of weight.
	811	Il-B	005096	
34	811A	Il-B	005096	
	821	Il-B	007750	
35	821A	Il-B	007750	
	823	Il-B	007749	
36	823A	Il-B	007749	
	824	Il-B	007742	
37	824A	Il-B	007742	
	808A	Il-B	005772	
	808B	Il-B	005772	RESTROOM
TOTAL 32				

2024 - 2025 ORANGE PARK ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	021	MB E	001909	
	021A	MB E	001909	
	022A	MB E	001898	Electrical panel was blocked by teacher materials
2	022B	MB E	001898	
	023	Il-B	005334	
3	023A	Il-B	005334	
	024	MB E	001988	
4	034	MB E	1906	
5	034A	MB E	001906	
	035	MB E	001905	
6	035A	MB E	001905	
	036	MB E	001904	
7	036A	MB E	001904	
	037	MB E	001900	
8	038	MB E	001895	
9	038A	MB E	001895	
	041	MB E	001907	
10	041A	MB E	001907	
	042	MB E	001908	No evacuation map
11	042A	MB E	001908	
	043	MB E	001893	
12	044	MB E	001901	
13	044A	MB E	001901	
	045	MB E	001894	
14	050	MB E	001903	Electric panel was blocked by teacher materials. No evacuation map
15	050A	MB E	001903	
	051	MB E	001902	Electrical panel was blocked by poster and globe. No evacuation map
16	051A	MB E	001902	

2024 - 2025 ORANGE PARK ELEMENTARY SCHOOL CORRECTION LIST

17	052	MB E	001899	
	052A	MB E	001899	
18	053	MB E	001896	
19	054	MB E	002554	
	039A	MB E	001910	
20				Portable on right side emergency light does not work and no evacuation map
	039B	MB E	001910	

TOTAL 20

2024 - 2025 ORANGE PARK SENIOR HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	035	II-B	007754	
	035A	II-B	007754	
2	36	II-B	007783	No evacuation map
	036A	II-B	007783	
3	037	II-B	007753	
	037A	II-B	007753	
	038	II-B	007784	
4				
	038A	II-B	007784	
5	039	II-B	007786	
	039A	II-B	007786	
6	040	II-B	007785	No evacuation map
	040A	II-B	007785	
7	045	II-B	010922	
	045A	II-B	010922	
8	049	II-B	005801	
	049A	II-B	005801	
9	050	II-B	005799	The electrical panel is behind a TV. The TV is on a stand and is very top heavy. The stand needs to be secured to the wall so that it will not tip.
	050A	II-B	005799	
10	051	II-B	005949	More than 20% of the walls are covered in paper. The fire extinguisher is blocked. There is no evacuation map. Non approved rug by the door.
	051A	II-B	005949	
11	052	II-B	005798	Emergency light does not work
	052A	II-B	005798	
12	053	II-B	010917	
	053A	II-B	010917	
13	054	MB E	002256	
14	055	MB E	001992	
	055A	MB E	001992	
15	056	MB E	002136	

2024 - 2025 ORANGE PARK SENIOR HIGH SCHOOL CORRECTION LIST

16	059	MB E	002210	Electrical panel covered by posters. Fire alarm pull station blocked by storage No evacuation map.
17	060	MB E	001989	
18	061	MB E	002175	
	061A	MB E	002175	
	061B	MB E	002175	
	061C	MB E	002175	
19	062	IL-B	005800	
	062A	IL-B	005800	
20	063	IL-B	005950	
	063A	IL-B	005950	
21	064	IL-B	005948	The walls are more than 20% by paper.
	064A	IL-B	005948	
22	065	IL-B	007755	
	065A	IL-B	007755	
23	066	IL-B	007757	No evacuation map
	066A	IL-B	007757	
24	067	IL-B	007751	
	067A	IL-B	007751	
25	013	MB E	001991	
	013A	MB E	001991	
26	048	IV-E	002560	

2024 - 2025 ORANGE PARK JUNIOR HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	501	MB E	002212	
2	505	MB E	002225	
	505A	MB E	002225	
	505B	MB E	002225	
3	510	MB E	002219	Emergency light does not work
4	511	MB E	002216	Emergency light does not work
5	703	MB E	002211	
6	503	MB E	002234	
	503A	MB E	002234	
	503B	MB E	002234	
7	504	MB E	002221	
	504A	MB E	002221	
8	507	MB E	002230	
	507A	MB E	002230	
	507B	MB E	002230	
9	509A	MB E	002233	
	509B	MB	002233	
10	516	MB E	002229	Emergency lights did not work.
11	706	MB E	002235	
	706A	MB E	002235	
	706B	MB E	002235	
12	708	MB E	002231	No evacuation map. Emergency light does to work.
	708A	MB E	002231	
	708B	MB E	002231	
13	710	MB E	002236	
	710A	MB E	002236	
	710B	MB E	002236	
14	702	MB E	002361	
15	704	MB E	002227	
	704A	MB E	002227	
	704B	MB E	002227	

2024 - 2025 ORANGE PARK JUNIOR HIGH SCHOOL CORRECTION LIST

	704C	MB E	002227	
16	506			This is a new classroom portable. Emergency light does not work. No insignia sticker on electrical box.

TOTAL 16

2024 - 2025 ROBERT M PATERSON CORRECTION LIST

Quantity	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	001	IL-B	010875	
	001A	IL-B	010875	
2	002	IL-B	010953	
	002A	IL-B	010953	
3	003	MB-E	002498	No heat detectors in closet
	003A	MB-E	002498	Bathroom fan/light has no cover 2023 no violations have been corrected
	003B	MB-E	002498	
	004A	MB-E	002482	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
4	004B	MB	002482	
	005	MB-E	002505	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times. Emergency light does not work
5				
6	006	IL-B	010977	
	006A	IL-B	010977	
7	007	IL-B	007452	Emergency light does not work
	007A	IL-B	007452	
8	008	MB-E	002320	
9	011	IL-B	000717	
	011A	IL-B	000717	
10	013	IL-B	010931	Emergency light does not work
	013A	IL-B	010931	
11	014	MB-E	002491	
	014A	MB-E	002491	

2024 - 2025 ROBERT M PATERSON CORRECTION LIST

	014B	MB E	002491	
12	015	MB E	002497	
	015A	MB E	002497	
	015B	MB E	002497	
13	016	MB E	002502	
	016A	MB E	002502	
	016B	MB E	002502	
14	017	I-B	005863	Emergency light do not work
	017A	I-B	005863	
15	018	I-B	010947	
	018A	I-B	010947	
16	021	MB E	002494	
	021A	MB E	002494	
	022	MB E	002493	The back exit door was blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36").
17	022A	MB E	002493	
	023	MB E	002495	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
18	023A	MB E	002495	
19	024	MB E	002492	Emergency light does not work
	024A	MB E	002492	
20	025	MB E	002483	
	025A	MB E	002483	
21	026	MB E	002496	
	026A	MB E	002496	
	026B	MB E	002496	
22	027	MB E	002501	

2024 - 2025 ROBERT M PATERSON CORRECTION LIST

	027A	MB E	002501	
	027B	MB E	002501	
23	028	MB E	002500	Emergency light does not work
	028A	MB E	002500	
	028B	MB E	002500	
24	029	MB E	001927	This Portable has moved
	029A	MB E	001927	
25	030	MB E	001850	This portable has moved
	030A	MB E	001850	
26	041	MB E	002487	
	041A	MB E	002487	
27	042	MB E	010963	
	042A	MB E	010963	
28	043	MB E	002488	Emergency light does not work
	043A	MB E	002488	
29	044	MB E	002507	
	044A	MB E	002507	
	044B	MB E	002507	
30	045	MB E	002485	
	045A	MB E	002485	
	045B	MB E	002485	
31	046	MB E	002506	emergency light does not work
	046A	MB E	002506	
	046B	MB E	002506	
32	047	MB E	002484	
	047A	MB E	002484	
33	048	MB E	002503	
	048A	MB E	002503	
	048B	MB E	002503	
34	049	MB E	002489	
	049A	MB E	002489	

2024 - 2025 ROBERT M PATERSON CORRECTION LIST

[illegible]

2023 - 2024 PLANTATION OAKS ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
18	803	MB E	002267	
	802	MB E	007513	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
19				
20	801	MB E	007449	The back exit door was blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36").
21	915	MB E	002348	
22	913	MB E	001919	
24	907	MB E	002122	
25	903	MB E	002603	
26	905	MB E	002402	
	911	MB E	002563	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times. The fire extinguisher is blocked by an object.
27				
28	910	MB E	002560	The emergency light does not work

TOTAL 10

2024 - 2025 RIDEOUT ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	010	MB E	002658	
	010A	MB E	002658	
2	011	MB E	002654	
	011A	MB E	002654	
3	012	MB E	002347	
	012A	MB E	002347	
4	013	MB E	002655	
	013A	MB E	002655	
5	014	MB E	002013	
	014A	MB E	002013	
6	020	MB E	002657	
	020A	MB E	002657	
7	021	MB E	002647	no evacuation map
	021A	MB E	002647	
8	022	MB E	002646	
	022A	MB E	002646	
	022B	MB E	002646	
	022C	MB E	002646	
9	025	MB E	002645	Electrical panel is blocked by storage
	025A	MB E	002645	
	025B	MB E	002645	
10	023A	MB E	002659	
	023B	MB E	002659	
	023C	MB E	002659	
	023D	MB E	002659	
	023E	MB E	002659	
TOTAL PORTABLES 10				

2024 - 2025 RIDGEVIEW ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	711A	MB E	002340	
	711B	MB E	002340	
	711C	MB E	002340	
2	712	MB E	002343	
	712A	MB E	002343	
3	714	MB E	002350	
	714A	MB E	002350	
4	715	MB E	002349	
	715A	MB E	002349	
5	717	l-B	005504	
	717A	l-B	005504	
	718	l-B	010981	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
6	718A	l-B	010981	
7	728	MB E	002352	
	728A	MB E	002352	
8	729	MB E	002346	
	729A	MB E	002346	
9	730	MB E	002355	
	730A	MB E	002355	
	731	MB E	002357	
10	731A	MB E	002357	Emergency light does not work
11	732	MB E	002342	No evacuation map
	732A	MB E	002342	
12	733	MB E	002330	Emergency light does not work
13	734	l-B	010990	
	734A	l-B	010990	
14	735	MB E	002354	
	735A	MB E	002354	

2024 - 2025 RIDGEVIEW ELEMENTARY SCHOOL CORRECTION LIST

15	737	II-B	031225	No insignia on electrical box.
	737A	II-B	031225	
16	741	MB E	002337	
	742	MB E	002345	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
17				
	742B	MB E	002345	
18	743	MB E	002336	
19	744	MB E	002329	
20	745	MB E	002338	
21	746	MB E	002327	
22	749	MB E	002334	
23	751	MB E	002326	
24	754	MB E	002351	
	754A	MB E	002351	
25	755	II-B	010901	Outlet in bathroom is not functioning properly and needs to be replaced
	755A	II-B	010901	
26	756	II-B	010967	
	756A	II-B	010967	
27	758	MB E	002353	
	758A	MB E	002353	
28	759	II-B	005542	
	759A	II-B	005542	
29	760	MB E	002358	
	760A	MB E	002358	
	760B	MB E	002358	
30	772	MB E	002356	
	772A	MB E	002356	Emergency light does not work

2024 - 2025 RIDGEVIEW HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	4	MB E	002419	Emergency light does not work
	004A	MB E	002419	
	004B	MB E	002419	
	005	MB E	002403	
2	005A	MB E	002403	
	005B	MB E	002403	
3	006	MB E	002426	
	006A	MB E	002426	
4	007	MB E	002428	
	007A	MB E	002428	
	007B	MB E	002428	
5	008	MB E	002425	
	008A	MB E	002425	
6	009	MB E	002429	Electrical panel block by storage
	009A	MB E	002429	
	009B	MB E	002429	
	010	MB E	002424	
7	010A	MB E	002424	
8	011	MB E	002386	
9	012	MB E	002397	
	012A	MB E	002397	
10	021	MB E	002417	
	021A	MB E	002417	
11	022	MB E	002412	Portable used for storage
	022A	MB E	002412	
12	023	MB E	002418	
	023A	MB E	002418	
13	024	MB E	002411	
14	025	MB E	002430	
	025A	MB E	002430	
	025B	MB E	002430	

2024 - 2025 RIDGEVIEW HIGH SCHOOL CORRECTION LIST

15	026	MB E	002432	
	026A	MB E	002432	
	026B	MB E	002432	
16	027	MB E	002422	
	027A	MB E	002422	
	027B	MB E	002422	
17	028	MB E	002427	
	028A	MB E	002427	
18	029	MB E	002431	
	029A	MB E	002431	
	029B	MB E	002431	
	029C	MB E	002431	
19	031	MB E	002407	
	031A	MB E	002407	
20	032	MB E	002400	Front door does not have automatic closer. both bathroom exhaust fans are busted
	032A	MB E	002400	
21	033	MB E	002374	
	033A	MB E	002374	
22	034	IB	007806	Emergency light does not work
	034A	IB	007806	
23	041	MB E	002414	
	041A	MB E	002414	
24	043	MB E	002415	The back door is blocked by desk
	043A	MB E	002415	
25	044	MB E	002413	
	044A	MB E	002413	
26	045	MB E	002385	
27	046	MB E	002423	
	046A	MB E	002423	
28	047	MB E	002341	
	047A	MB E	002341	

2024 - 2025 RIDGEVIEW HIGH SCHOOL CORRECTION LIST

29	048	MB E	002409	Emergency light did not work
	048A	MB E	002409	
30	049	MB E	002008	
	049A	MB E	002008	
31	050	MB E	002471	Emergency light does not work
32	051	MB E	002007	
33	052	MB E	001897	Railing on the ramp at front door is broken
	052A	MB E	001897	
34	061	MB E	002416	
	061A	MB E	002416	
35	062	MB E	002420	no DCA insignia on electrical panel
	062A	MB E	002420	
36	064	MB E	002393	
37	065	MB E	002390	
38	066	MB E	002394	
39	067	MB E	002392	
40	069	IL-B	010899	
	069A	IL-B	010899	
41	070	MB E	002389	
42	071	IL-B	010863	
	071A	IL-B	010863	
43	072	IL-B	010954	Portable being used for storage
	072A	IL-B	010954	
44	073	IL-B	005867	
	073A	IL-B	005867	
45	081	MB E	002433	
	081A	MB E	002433	
	081B	MB E	002433	
46	082	MB E	002434	
	082A	MB E	002434	
	082B	MB E	002434	

2024 - 2025 RIDGEVIEW HIGH SCHOOL CORRECTION LIST

47	083	MB E	002435	
	083A	MB E	002435	
	083B	MB E	002435	
48	084	MB E	002436	
	084A	MB E	002436	
	084B	MB E	002436	
49	085	MB E	002437	
	085A	MB E	002437	
	085B	MB E	002437	
50	086	MB E	002438	
	086A	MB E	002438	
	086B	MB E	002438	
51	087	MB E	002439	
	087A	MB E	002439	
	087B	MB E	002439	
52	088	MB E	002440	
	088A	MB E	002440	
	088B	MB E	002440	
53	089	MB E	002441	
	089A	MB E	002441	
	089B	MB E	002441	
54	090	MB E	002442	
	090A	MB E	002442	
	090B	MB E	002442	
	090C	MB E	002442	
	090D	MB E	002442	
55	091	MB E	002443	No evacuation map. Electrical panel is blocked by trophies.
	091A	MB E	002443	
	091B	MB E	002443	
56	103	LB	007739	
	103A	LB	007739	

2024 - 2025 RIDGEVIEW HIGH SCHOOL CORRECTION LIST

57	001	MB E	002446	
	001A	MB E	002446	
	001B	MB E	002446	
	001C	MB E	002446	
	001D	MB E	002446	
	001E	MB E	002446	
	001F	MB E	002446	
	001G	MB E	002446	
	003	MB E	002445	The back exit door was blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36").
	003A	MB E	002445	Light switch in the hallway has no cover and is sticking out.
	003B	MB E	002445	
	030	MB E	002444	
	030A	MB E	002444	
	030B	MB E	002444	
	030C	MB E	002444	
	030D	MB E	002444	
	030F	MB E	002444	
	068	MB E	002410	
	092A	MB E	002447	Back door is not accessible must pass through second room into third room, but all doors were locked. Could not get to back door, latch on back door that must be removed and propane tanks stored in back room.
61	092B	MB E	002447	
	101A	MB E	002035	
	101B	MB E	002035	this room is being used for a weight room with heavy weights
62				

2024 - 2025 S BRYAN JENNINGS ELEMENTARY SCHOOL

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	026	MB E	002111	
	027	MB E	002110	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
2				
3	028A	MB E	002125	Emergency light does not work
	028B	MB E	002125	
	028C	MB E	002125	
4	029	MB E	002124	No evacuation map access to crawlspace is left open
5	029A	MB E	002124	
5	030	MB E	002112	Fire alarm pull station by back door is hanging off wall
6	032	MB E	002118	
7	033	MB E	002119	
	033A	MB E	002119	
8	035	MB E	002116	
9	036	MB E	002113	
10	037	MB E	002117	No evacuation map
	037A	MB E	002117	
11	039	MB E	002123	
	039A	MB E	002123	
12	042	MB E	002132	
	042A	MB E	002132	
	042B	MB E	002132	
13	043	MB E	002133	
	043A	MB E	002133	
	043B	MB E	002133	
14	044	MB E	002134	
	044A	MB E	002134	
	044B	MB E	002134	
15	075	MB E	002127	No evacuation map
	075A	MB E	002127	

2024 - 2025 S BRYAN JENNINGS ELEMENTARY SCHOOL

	075B	MB E	002127	
16	077	MB E	002128	
	077A	MB E	002128	
	077B	MB E	002128	
17	078	MB E	002129	
	078A	MB E	002129	
	078B	MB E	002129	
18	080A	MB E	002115	Emergency emergency light does not work
	080B	MB E	002115	
19	076	MB E	002135	outlet next to sink is not functioning properly
	076A	MB E	002135	
	076B	MB E	002135	
	076C	MB E	002135	
	076D	MB E	002135	
	076E	MB E	002135	
	076F	MB E	002135	
	076G	MB E	002135	
	076H	MB E	002135	
	076J	MB E	002135	
	076K	MB E	002135	

TOTAL 19

2024-2025 SWIMMING PEN ELEMENTARY CORRECTION LIST

Quantity	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	701	MB E	001985	
2	702	MB E	002408	
3	703	MB E	002010	No evacuation map
	703A	MB E	002010	
4	704	MB E	002045	
5	705	IL-B	10959	
	705A	IL-B	010959	
6	706A	MB E	002562	No evacuation map
	706B	MB E	002562	
	706C	MB E	002562	
	706D	MB E	002562	
	706E	MB E	002562	
	706F	MB E	002562	
7	707	IL-B	000830	GFCI outlet next to the classroom sink is not working. bathroom exhaust fan does not work.
	707A	IL-B	000830	
8	801	IL-B	005956	Handicap ramp railing is loose on ramp side of portable
	801A	IL-B	005956	
9	803	IL-B	005957	Emergency light does not work
	803A	IL-B	005957	
10	806	MB E	002204	
11	708	MB E	002574	
TOTAL = 11				

2024-2025 THUNDERBOLT ELEMENTARY CORRECTION LIST 33 PORTABLES

Quantity	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
3	721A	MB E	002068	
	721B	MB E	002068	
4	701	IL-B	010945	
	701A	IL-B	010945	
5	702	N-E	009473	
	702A	N-E	009473	
6	703	N-E	009472	
	703A	N-E	009472	
7	704	IL-B	010861	
	704A	IL-B	010861	
8	705	IL-B	000693	
	705A	IL-B	000693	
9	706	IL-B	001074	
	706A	IL-B	001074	
10	707	MB E	002375	
	707A	MB E	002375	
11	710	MB E	002182	
		MB E	002182	
12	711	IL-B	005864	
	711A	IL-B	005864	
13	713	MB E	002560	
15	722	MB E	001832	
	722A	MB E	001832	
	722B	MB E	001832	Classroom 723 has a hanging rope apparatus hanging from the ceiling . (Check with the Schools building department to see if this is allowed in a portable)
16	723	MB E	002644	
	723A	MB E	002644	
	723B	MB E	002644	
17	724A	MB E	002641	Electrical panel is blocked by hanging poster

2024-2025 THUNDERBOLT ELEMENTARY CORRECTION LIST 33 PORTABLES

	724B	MB E	002641	
	724C	MB E	002641	
18	725	MB E	002642	
	725A	MB E	002642	
	726	MB E	002638	
19	726A	MB E	002638	
20	727	MB E	002640	
	727A	MB E	002640	
21	728	MB E	002639	
	728A	MB E	002639	
22	729	MB E	002556	
23	730	MB E	002553	
24	731	IV-E	009470	This portable does not have a handicapped ramp
	731A	IV-E	009470	
25	732	IV-E	009471	
	732A	IV-E	009471	
26	733	MB E	002380	
	733A	MB E	002380	
27	734	II-B	005858	
	734A	II-B	005858	
	735	II-B	005860	
	735A	II-B	005860	
28	736	MB E	002604	
29	737	II-B	005862	
	737A	II-B	005862	
30	738	II-B	005861	
	738A	II-B	005861	
31	739	II-B	005855	
	739A	II-B	005855	
32	740	II-B	005856	
	740A	II-B	005856	

2024-2025 THUNDERBOLT ELEMENTARY CORRECTION LIST 33 PORTABLES

33	741	IL-B	5865	
	741A	IL-B	005865	
34	742	IL-B	005859	
	742A	IL-B	005859	
35	744	IL-B	005857	Light does not work in the restroom and there is no evacuation map.
	744A	IL-B	005857	
37	735A	IL-B	5860	
	735B	IL-B	5860	
38	712A	IL-B	005666	This is a stand alone portable restroom
	712B	IL-B	005666	
TOTAL 34				

2024 - 2025 TYNES ELEMENTARY SCHOOL CORRECTION LIST

	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	001	MB E	002568	
	001A	MB E	002568	
	001B	MB E	002568	
2	002	MB E	002569	
	002A	MB E	002569	
	002B	MB E	002569	
3	003	MB E	002552	Non-approved rugs by both doors
4	004	MB E	002564	Non-approved rug by the front door
	004A	MB E	002564	
5	005	IL-B	010973	
	005A	IL-B	010973	
6	006	IL-B	010988	Non-approved rug by front door rug stops front door from closing automatically
	006A	IL-B	010988	
7	007	IL-B	010994	
	007A	IL-B	010994	
8	008	IL-B	010980	
	008A	IL-B	010980	
9	009	IL-B	010939	Bathroom fan does not work
	009A	IL-B	010939	
10	010	MB E	002014	
11	022	MB E	002566	
	022A	MB E	002566	
	022B	MB E	002566	
12	023	MB E	002152	Emergency light did not work no evacuation map
	023A	MB E	002152	
	023B	MB E	002152	
13	024	MB E	002567	Heat detector in closet a is hanging by wires
	024A	MB E	002567	
	024B	MB E	002567	
14	025	MB E	002570	

2024 - 2025 TYNES ELEMENTARY SCHOOL CORRECTION LIST

	025A	MB E	002570	
	025B	MB E	002570	
15	026	MB E	002153	
	026A	MB E	002153	
	026B	MB E	002153	
16	027	Il-B	010996	
	027A	Il-B	010996	
17	028	Il-B	010886	
	028A	Il-B	010886	
18	029	Il-B	010871	
	029A	Il-B	010871	
19	030	Il-B	010929	
	030A	Il-B	010929	
20	041	MB E	002555	
21	042	Il-B	010968	
	042A	Il-B	010968	
22	043	MB E	002202	
23	044	MB E	002470	
	044A	MB E	002470	
24	045	Il-B	010930	
	045A	Il-B	010930	
25	046	MB E	002627	
	046A	MB E	002627	
	046B	MB E	002627	
26	047	MB E	002222	Fire extinguisher is not hung within 5 feet of exit door
27	048	Il-B	010928	
	048A	Il-B	010928	
28	049	Il-B	010920	Electrical panel was blocked by decorations
	049A	Il-B	010920	
29	061	MB E	002145	
	061A	MB E	002145	

2024 - 2025 TYNES ELEMENTARY SCHOOL CORRECTION LIST

30	063	MB E	002142	
	063A	MB E	002142	
31	065	MB E	002561	
	065A	MB E	002561	
32	066	II-B	010946	Electrical panel is blocked by storage and bookshelf
	066A	II-B	10946	
33	067	MB E	002565	
	067A	MB E	002565	
34	068	MB E	002558	
	068A	MB E	002558	
35	062	MB E	002140	Electrical panel is blocked by storage
	062A	MB E	002140	

2024 - 2025 W E CHERRY ELEMENTARY SCHOOL

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	027	MB E	001948	
2	029	MB E	001967	Non approved rug by the door
	029A	MB E	001967	
3	031	MB E	001968	Bathroom exhaust fan does not work
	031A	MB E	001968	
	032	MB E	001965	Non approved rug by the door An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
4				
	032A	MB E	001965	
5	033	MB E	001963	
	033A	MB E	001963	
6	034A	MB E	001966	
	034B	MB E	001966	
7	036	MB E	001957	
	036A	MB E	001957	
8	037	MB E	001958	
	037A	MB E	001958	
9	038	MB E	001956	
	038A	MB E	001956	
10	039	MB E	001959	
	039A	MB E	001959	
11	040	MB E	001955	
	040A	MB E	001955	
12	041	MB E	001954	
	041A	MB E	001954	
13	042A	MB E	001953	
	042B	MB	001953	
	042C	MB E	001953	
14	043	MB E	001960	
	043A	MB E	001960	

2024 - 2025 W E CHERRY ELEMENTARY SCHOOL

15	044	MB E	002131	
	044A	MB E	002131	
	044B	MB E	002131	
16	045	MB E	002130	
	045A	MB E	002130	
	045B	MB E	002130	

17	049	MB E	001943	Non-approved rug by door. Piece of tile missing by back door.
18	050	MB E	001969	
	050A	MB E	001969	
19	051	MB E	001971	
	051A	MB E	001971	
20	053	Il-B	005090	
	053A	Il-B	005090	
21	054	MB E	001972	
	054A	MB E	001972	
	054B	MB E	001972	
22	055	Il-B	005568	
	055A	Il-B	005568	
23	056	Il-B	007721	
	056A	Il-B	007721	
24	057	Il-B	007718	
	057A	Il-B	007718	
25	058	Il-B	005567	
	058A	Il-B	005567	
26	059	Il-B	005569	
	059A	Il-B	005569	
27	060	MB E	002126	
28	061	Il-B	005802	
	061A	Il-B	005802	
29	062	Il-B	007719	

	062A	II-B	007719	
30	063	II-B	010958	electrical panel installed with no sticker or paperwork.
	063A	II-B	010958	
31	064	II-B	010903	
	064A	II-B	010903	
	065	II-B	007725	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times. Fire pull station is blocked.
32	065A	II-B	007725	
33	066	II-B	007720	
	066A	II-B	007720	
	067	II-B	007723	An object (cabinet etc...) is blocking access to the electrical panel, or the electrical panel was covered by an object (poster etc...). Per the NEC (110.26) You must maintain a clear area in front of the electrical panel 36" deep and 30" wide and must be visible at all times.
34				
	067A	II-B	007723	
35	068	II-B	007724	
	068A	II-B	007724	
36	069	II-B	007722	
	069A	II-B	007722	
37	070	II-B	010880	
	070A	II-B	010880	
38	026A	MB E	001949	
	026B	MB E	001949	
	026C	MB E	001949	
39	030	MB E	001961	
	030A	MB E	001961	
	030B	MB E	001961	
	030C	MB E	001961	
40	048	MB E	001944	

2024 - 2025 WILKINSON ELEMENTARY SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	001	MB E	002508	
2	002	MB E	002509	
3	003	MB E	002519	
	003A	MB E	002519	
4	004	MB E	002523	
	004A	MB E	002523	
5	005	MB E	002522	
	005A	MB E	002522	
6	006	MB E	002514	
	006A	MB E	002514	
7	007	MB E	002527	
	007A	MB E	002527	
8	008	MB E	002526	
	008A	MB E	002526	
9	010	MB E	002528	
	010A	MB E	002528	
10	011	MB E	002511	
11	012	MB E	002512	
12	013	MB E	002536	Non-approved rug at front door
	013A	MB E	002536	
13	014	MB E	002534	
	014A	MB E	002534	
14	016	MB E	002520	
	016A	MB E	002520	
15	017	MB E	002548	
	017A	MB E	002548	
	017B	MB E	002548	
16	018	MB E	002328	Non-approved rug at front door
17	020	MB E	002395	
	020A	MB E	002395	
18	022	Il-B	007447	

2024 - 2025 WILKINSON ELEMENTARY SCHOOL CORRECTION LIST

19	031	MB E	002525	non-approved rug by door
	031A	MB E	002525	
20	033	MB E	002515	
	033A	MB E	002515	
21	034	MB E	002518	
	034A	MB E	002518	
22	035	MB E	002529	
	035A	MB E	002529	
	035B	MB E	002529	
23	036	MB E	002517	
	036A	MB E	002517	
24	037	MB E	002521	Non-approved rug by both doors
	037A	MB E	002521	
	038	MB E	002513	There is a apparatus hanging from the ceiling. This creates a hazard for the ceiling to collapse. This is a second year violation and will be reported to the fire marshall.
25				
	038A	MB E	002513	
26	039	MB E	002524	The back exit door was blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36").
	039A	MB E	002524	
27	040	MB E	002516	
	040A	MB E	002516	
28	041	MB E	002532	
	041A	MB E	002532	
29	042	MB E	002537	
	042A	MB E	002537	
30	043	MB E	002510	
	043A	MB E	002510	
31	044	MB E	002535	The back exit is blocked by storage
	044A	MB E	002535	
32	045	MB E	002546	
	045A	MB E	002546	
	045B	MB E	002546	

2024 - 2025 WILKINSON ELEMENTARY SCHOOL CORRECTION LIST

33	046	MB E	002540	Electrical outlet by the classroom sink is not GFI.C.
	046A	MB E	002540	
34	047	MB E	002547	Non-approved rug by both doors. Electrical panel blocked by decorations.
	047A	MB E	002547	
	047B	MB E	002547	
35	048	MB E	002542	
	048A	MB E	002542	
	048B	MB E	002542	
36	049	MB E	002543	
	049A	MB E	002543	
	049B	MB E	002543	
37	050	MB E	002544	
	050A	MB E	002544	
	050B	MB E	002544	
38	051	LB	010872	
	051A	LB	010872	
39	052	MB E	002549	
	052A	MB E	002549	
	052B	MB E	002549	
40	061	MB E	001997	Bathroom exhaust fan does not work
	061A	MB E	001997	
41	063	MB E	001998	
	063A	MB E	001997	
42	066	MB E	002541	
	066A	MB E	002541	
	066B	MB E	002541	
43	068	LB	010873	
	068A	LB	010873	
44	062	MB E	002560	
	062A	MB E	002560	
	062B	MB E	002560	

2024 - 2025 WILKINSON ELEMENTARY SCHOOL CORRECTION LIST

	062C	MB E	002550	
	064	MB E	002551	The back exit door was blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36").
45				
	064A	MB E	002551	
	064B	MB E	002551	
	064C	MB E	002551	

2024 - 2025 WILKINSON JUNIOR HIGH SCHOOL CORRECTION LIST

QUANTITY	Room Number	DCA Prefix	DCA Number	ITEMS THAT NEED TO BE CORRECTED
1	002	MB E	002244	
2	003	MB E	002249	No DCA sticker on electrical panel
3	004	MB E	002245	
4	005	MB E	002257	Emergency light does not work
	005A	MB E	002257	
5	006	MB E	002246	
6	007	MB E	002259	Unapproved rug at back door
	007A	MB E	002259	
7	008	MB E	002247	
8	009	MB E	002260	
	009A	MB E	002260	
9	010	MB E	002237	
10	011	MB E	002265	
	011A	MB E	002265	
	011B	MB E	002265	
11	021	MB E	002243	
12	022	MB E	002261	
	022A	MB E	002261	
13	023	MB E	002242	The back exit door was blocked by an object. Leading up to the door, there must be an egress path as wide as the door (36").
14	024	MB E	002240	
15	025	MB E	002241	
16	026	MB E	002239	
17	027	MB E	002251	No DCA sticker or document stating DCA number
18	040	MB E	002248	
19	041	MB E	002263	
	041A	MB E	002263	
20	043	MB E	002255	This portable is being used for a dental office
	043A	MB E	002255	
21	042	MB E	002269	Storage in closet without heat detection
	042A	MB E	002269	

2024 - 2025 WILKINSON JUNIOR HIGH SCHOOL CORRECTION LIST

	042B	MB E	002269	
	042C	MB E	002269	
22	048	MB E	002271	
	048A	MB E	002271	
	048B	MB E	002271	
23	096	MB E	002270	
	096A	MB E	002270	

TOTAL 23