

SCHOOL DISTRICT OF CLAY COUNTY
CHANGE ORDER NO. 1

SDCC PROJECT NAME: Clay High School Fire Alarm Replacement

SDCC PROJECT NO: C-16-08/09

The Owner authorized the Contractor to make the following change(s) in the contract dated **March 23, 2009.**

ORIGINAL CONTRACT AMOUNT: \$ 145,000.00
REVISED CONTRACT AMOUNT BY PREVIOUS CHANGE ORDER(S): \$ 145,000.00


Change(s) and reason(s) for this Change Order: See attached information.

Additional Time needed for this Change Order is **Zero (0)** calendar days. Contract Substantial Completion date is **August 14, 2009.** Final Completion date is **August 29, 2009.**


For these changes: Add to Deduct from the Contract in accordance with the conditions of the Contract the sum of: **Twenty-Five thousand, nine hundred seventy-five dollars and 00/100.**


CURRENT CONTRACT AMOUNT:	<u>\$145,000.00</u>
ADDITION TO CONTRACT:	<u>\$25,975.00</u>
DEDUCTION TO CONTRACT:	<u>\$0.00</u>
REVISED CONTRACT AMOUNT:	<u>\$170,975.00</u>

ARCHITECT/ENGINEER CERTIFICATION: In my considered professional opinion, as Project Architect/Engineer, the prices quoted in this Change Order are both fair and reasonable and in the proper ratio to the cost of the original work contract under benefit of competitive bidding.

Signature:  Date: 7/29/2009
Architect/Engineer

By execution of this Change Order, the Contractor acknowledges that all issues related to compensation and time have been resolved and payment recited herein is full compensation for the work identified in this Change Order.

ACCEPTED: Signature:  Date: 7/29/09
Contractor

Signature:  Date: 7-29-09
SDCC Project Manager

APPROVED: Signature: _____ Date: _____
School Board Chairman

SCHOOL DISTRICT OF CLAY COUNTY
CHANGE ORDER #1

SDCC PROJECT NAME: Clay High School Fire Alarm Replacement

SDCC PROJECT NUMBER: C-16-08/09

ADDITIONAL INFORMATION

1. 1-VIP 50 50 watt ampilifier
2. 1-5496 6 amp addressable power supply
3. 25-SPSR multi-candela speaker/strobe
4. 1-DTK-120HW 120 volt A/C surge suppressor
5. 2-DTK-2MHLP24BW NAC surge suppressor
6. 2-PS-1270 12 volt/7amp hour battery
7. 1-lot fire alarm cable
8. 1-lot electrical
9. 1-lot labor to install wire, devices, terminate panel, test and certification
10. 15-IDP-PDUCT Duct detector (9 additional found in building 7)
11. 15-ST-5 sampling tube
12. 15-IDP-Relay module
13. 15-RTS-451 remote test station
14. 9-IDP-MINIMON monitor module (fire pump in building 7)
15. 4-2MHLP SLC surge suppressor
16. 1-lot fire alarm cable
17. 1-lot electrical to provide telephone lines from building 3 to building 8. Change electrical panel feeding FACP to update to NEC standards
18. 1-lot labor to install wire, devices, terminate panel, test and certification

TOTAL CHANGE ORDER AMOUNT

\$25,975.00

Addition of zero (0) days to the Contract.

A time extension is not required for this change in work.