



BID TABULATION AND NOTICE OF AWARD RECOMMENDATION

SDCC PROJECT NO: M-1-06/07 – Clay High School
 PROJECT NAME: Building 3 HVAC and Lighting Renovation
 Kenyon & Partners, Inc. Project No.: KPI – 061066

Bids Opened By: Nancy Racine *Nancy Racine*
 Bids Tabulated By: Nila Bandy *Nila Bandy*

Bid Opening: January 25, 2007 at 2:00 P.M. in Business Affairs Conference Room, School District of Clay County, 814 Walnut Street, Green Cove Springs, FL 32043

COMPANY	BID BOND	SUB CONTR. LIST	BASE BID AMOUNT
W.W. Gay			
Hearn W. H. Mechanical Contractor, Inc.			
Hager Construction Co.	X	X	\$350,000.00
Bill Williams Heating and A/C	X	X	\$187,900.00
Able Products			
Quality Sheet Metal Service Inc.			
Air-Max	X	X	\$290,507.00

NOTE: Any actual or prospective bidder who disputes the reasonableness or competitiveness of terms and conditions of the Invitation to Bid or contract award recommendation shall file a Notice to Protest with Superintendent of Schools within 72 hours of receipt of bid solicitation or posting of the bid tabulation with recommendation and must file a formal written protest within ten (10) days following the filing of Notice to Protest. Failure to observe such timelines will constitute a waiver of proceedings and of right to protest – Chapter 120, Florida Statutes. The School Board requires a proffesor to post bond in accordance with Florida Statutes, Section 255.0516 F.S. refer to Specification Section 00100, Part 27 – Bid Protest for additional requirements.

RECOMMENDATION: Reject all bids due to a conflict between the Plans and Specification. It was not clear as to which material to use to construct the duct work; metal or phenolic foam. We will re-design and re-bid using a combination of metal duct work and phenolic foam duct.