

ELEMENTARY SCHOOLS






State Fire Marshal - Inspection Report - ARGYLE ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay						
School:	ARGYLE ELEMENTARY						
Address:	2625 SPENCER PLANTATION BOULEVARD						
Inspection Date:	April 19, 2010						
Note:	N/A						
Inspectors present							
State: No	District: Yes	Local: No					
Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0010	IMMINENT HAZARD	1-PERMANENT	1	Apr 19, 2010	1	main office smoke detector mounted on ceiling to close to wall must be atleast 12" away from wall.
N/A	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	0-Building N/A - - See notes	113	Apr 19, 2010	1	N/A
Statements acknowledged							
I hereby certify that the district has complied with section 1013.12(1)(b), F.S.							No
I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.							No
I hereby certify that the required fire drills have been completed as of this inspection date.							No
Or							
Acknowledgement N/A.							Yes
Primary inspector:	Raul Feliciano						
Additional inspector:	N/A						

Powered by [eGroupWare's CSS Design](#) and the [Bureau of Economic and Business Research](#).



State Fire Marshal - Inspection Report - BENNETT ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: CHARLES E BENNETT ELEMENTARY
 Address: 1 S OAKRIDGE AVENUE
 Inspection Date: March 23, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Citec
N/A	0203	EXIT LIGHTS INOPERABLE EMERGENCY MODE	1-PERMANENT	MainOffice	Mar 23, 2010	1
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	0-Building N/A -- See notes	102	Mar 23, 2010	1
N/A	0301	UNPROTECTED VERTICAL OPENING	0-Building N/A -- See notes	112	Mar 23, 2010	1

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector:	Raul Feliciano
Additional inspector:	N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: CLAY HILL ELEMENTARY
 Address: 6345 STATE ROAD 218
 Inspection Date: January 26, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	3-PERMANENT	125	Jan 26, 2010
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	2-PERMANENT	208	Jan 26, 2010
N/A	0806	OUTSIDE GFCI'S IMPROPERLY PROTECTED	5-PERMANENT	509	Jan 26, 2010
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	7-PERMANENT	713	Jan 26, 2010
7.1.10.2.1	0211	BLOCKED/LOCKED EXITS	7-PERMANENT	707	Jan 26, 2010
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	1-PERMANENT	104A	Mar 3, 2010
N/A	1101	COMBUSTIBLE	91-	702C	Mar 3, 2010

		MATERIAL IMPROPERLY STORED	RELOCATABLE		
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91-RELOCATABLE	704	Mar 3, 2010
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91-RELOCATABLE	706	Mar 3, 2010
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91-RELOCATABLE	708	Mar 3, 2010
N/A	0803	EXTENSION CORD NOT RATED FOR USE	91-RELOCATABLE	708	Mar 3, 2010
N/A	0211	BLOCKED/LOCKED EXITS	91-RELOCATABLE	710	Mar 3, 2010
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91-RELOCATABLE	701	Mar 3, 2010
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91-RELOCATABLE	682	Mar 3, 2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Karen Golish

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: COPPERGATE ELEMENTARY
 Address: 2250 COUNTY ROAD 209 NORTH
 Inspection Date: February 24, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0209	RATED OPENINGS NOT MAINTAINED	1-PERMANENT	325	Mar 24, 2010
N/A	0212	AREA OF REFUGE NOT MAINTAINED	1-PERMANENT	321	Mar 24, 2010
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	1-PERMANENT	209	Mar 24, 2010
N/A	1205	FIRE EVACUATION PLAN (S) NOT POSTED	1-PERMANENT	473	Mar 24, 2010
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	21-PERMANENT	21	Mar 24, 2010
N/A	1399	OUTSIDE STRUCTURE OTHER	21-PERMANENT	21	Mar 24, 2010
N/A	0802	CIRCUITS NOT	21-	242	Mar 24,

		LEGIBLE/PERMANENTLY LABELED	PERMANENT		2010
N/A	0514	STANDPIPE SYSTEM INOPERABLE	91- RELOCATABLE	00000	Mar 24, 2010
N/A	0514	STANDPIPE SYSTEM INOPERABLE	91- RELOCATABLE	0000	Mar 24, 2010
N/A	1399	OUTSIDE STRUCTURE OTHER	1-PERMANENT	302	Mar 24, 2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Stephen Arzie

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: DOCTORS INLET ELEMENTARY
 Address: 2634 STATE ROAD 220
 Inspection Date: April 12, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	4- PERMANENT	108	May 30, 2010
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	4- PERMANENT	UtilityRoom	May 30, 2010
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	4- PERMANENT	122	May 30, 2010
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	5- PERMANENT	105	May 30, 2010
N/A	0502	PORTABLE EXTINGUISHER	5- PERMANENT	112	May 30, 2010

		IMPROPERLY MOUNTED			
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	5- PERMANENT	112	May 30, 2010
N/A	0301	UNPROTECTED VERTICAL OPENING	5- PERMANENT	108	May 30, 2010
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	0-Building N/A -- See notes	601AB	May 30, 2010
N/A	0901	IMPROPER STORAGE	9- PERMANENT	915	May 30, 2010
N/A	0901	IMPROPER STORAGE	8- PERMANENT	815	May 30, 2010
N/A	0210	EXIT ACCESS NOT MAINTAINED	8- PERMANENT	815	May 30, 2010
N/A	0901	IMPROPER STORAGE	7- PERMANENT	716	May 30, 2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Jason Boree

Additional inspector: james crawford

State Fire Marshal - Inspection Report

District - Clay

School - GROVE PARK ELEMENTARY

Address - 1643 MILLER STREET

Inspection date - 2010-02-23

Notes -

Inspectors present

State No **District Yes** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
	0200 MEANS OF EGRESS	9- PERMANENT	2	2010-02-23	0	Emergency exit blocked
	0200 MEANS OF EGRESS	9- PERMANENT	3	2010-02-23	0	Emergency exit blocked by furniture
	0100 GENERAL REQUIREMENTS	7- PERMANENT	702	2010-02-23	0	No items may be hung from the ceiling ie. parachute in the above classroom.
	0100 GENERAL REQUIREMENTS	6- PERMANENT	random	2010-02-23	0	no items may be hung from ceiling this was veiwed throughout the building
	0200 MEANS OF EGRESS	90- RELOCATABLE	504	2010-02-23	0	Emergency exit blocked by furniture
	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	27	2010-03-03	0	Emergency lighting not working
	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	503	2010-03-03	0	Emergency lighting not working

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Danny, Yeager

Additional inspector

N/, A



State Fire Marshal - Inspection Report - FLEMING ISLAND EI

District: Clay
 School: FLEMING ISLAND ELEMENTARY
 Address: 4425 LAKESHORE DRIVE
 Inspection Date: March 20, 2020
 Note: fire drills in the county wide system are not monthly

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0399	PROTECTION OTHER	2-PERMANENT	204	April 3, 2007	1	remove all door stops
N/A	0399	PROTECTION OTHER	1-PERMANENT	all	April 3, 2007	1	remove all door stops
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	133	April 3, 2007	0	there are no emergency windowless and the c
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	402	April 3, 2007	0	N/A
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	407	April 3, 2007	0	N/A
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	423	April 3, 2007	0	also need inserts for p
N/A	0211	BLOCKED/LOCKED EXITS	92-RELOCATABLE	801	April 3, 2007	0	rear exit blocked
N/A	0211	BLOCKED/LOCKED EXITS	92-RELOCATABLE	824	April 3, 2007	0	rear exit blocked
N/A	0211	BLOCKED/LOCKED EXITS	92-RELOCATABLE	826	April 3, 2007	0	rear exit blocked
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	841	April 3, 2007	0	N/A
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	860	April 3, 2007	0	N/A

State Fire Marshal - Inspection Report - FLEMING ISLAND ELEMENTARY

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.	No
I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.	Yes
I hereby certify that the required fire drills have been completed as of this inspection date.	No
Or	
Acknowledgement N/A.	No

Primary Inspector: Scott Baltes

Additional inspector: N/A



State Fire Marshal - Inspection Report - HEIGHTS ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: KEYSTONE HEIGHTS ELEMENTARY
 Address: 335 S PECAN STREET
 Inspection Date: February 25, 2010
 Note: N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipa Complia Date
N/A	0210	EXIT ACCESS NOT MAINTAINED	2-PERMANENT	R213	Feb 25, 2010
N/A	0301	UNPROTECTED VERTICAL OPENING	2-PERMANENT	R213	Feb 25, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	10- PERMANENT	29	Feb 25, 2010
N/A	0209	RATED OPENINGS NOT MAINTAINED	10- PERMANENT	20A	Feb 25, 2010

N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	9-PERMANENT	R908	Feb 25, 2010
N/A	0411	HORN/STROBE DEVICE INADEQUATE/INOPERABLE	7-PERMANENT	15	Feb 25, 2010
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	12- PERMANENT	1202	Feb 25, 2010
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	12- PERMANENT	1202	Feb 25, 2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	12- PERMANENT	1201	Feb 25, 2010
N/A	0411	HORN/STROBE DEVICE INADEQUATE/INOPERABLE	12- PERMANENT	1201	Feb 25, 2010
N/A	0301	UNPROTECTED VERTICAL OPENING	12- PERMANENT	1211	Feb 25, 2010
N/A	0210	EXIT ACCESS NOT MAINTAINED	12- PERMANENT	all	Feb 25, 2010
N/A	0210	EXIT ACCESS NOT MAINTAINED	90- RELOCATABLE	CI2006	Feb 25, 2010
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	90- RELOCATABLE	CI825	Feb 25, 2010

N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	90- RELOCATABLE	CI825	Feb 25, 2010
N/A	0210	EXIT ACCESS NOT MAINTAINED	90- RELOCATABLE	CI825	Feb 25, 2010
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	90- RELOCATABLE	CI444	Feb 25, 2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Kevin Mobley

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: LAKE ASBURY ELEMENTARY
 Address: 2901 SANDRIDGE ROAD
 Inspection Date: January 26, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticip Compl Date
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	1-PERMANENT	114	Feb 28, 2010
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	1-PERMANENT	114	Feb 28, 2010
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	116	Feb 28, 2010
N/A	0209	RATED OPENINGS NOT MAINTAINED	1-PERMANENT	126Ato136	Feb 28, 2010
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	1-PERMANENT	128	Feb 28, 2010
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	313	Feb 28, 2010
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	134	Feb 28, 2010
N/A	1205	FIRE EVACUATION PLAN	1-PERMANENT	134	Feb 28,

N/A	0901	IMPROPER STORAGE	8- PERMANENT	815	Apr 5, 2010	1
-----	------	---------------------	-----------------	-----	-------------	---

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Jason Boree

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: LAKESIDE ELEMENTARY
 Address: 2752 MOODY ROAD
 Inspection Date: March 4, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cite
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1- PERMANENT	143	Apr 5, 2010	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1- PERMANENT	139	Apr 5, 2010	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	6- PERMANENT	602	Apr 5, 2010	0

		(S) NOT POSTED			2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	133	Feb 28, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	138	Feb 28, 2010
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	2-PERMANENT	225	Feb 28, 2010
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	2-PERMANENT	225	Jan 28,
N/A	0803	EXTENSION CORD NOT RATED FOR USE	7-PERMANENT	708	Feb 28, 2010
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90- RELOCATABLE	01	Jan 28,
N/A	0408	MANUAL PULL STATION MISSING/INOPERABLE	90- RELOCATABLE	R40	Feb 28, 2010
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	90- RELOCATABLE	71	Feb 28, 2010
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90- RELOCATABLE	80	Feb 28, 2010
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90- RELOCATABLE	84	Feb 28, 2010
N/A	0803	EXTENSION CORD NOT RATED FOR USE	90- RELOCATABLE	84	Feb 28, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90- RELOCATABLE	84	Feb 28, 2010
N/A	1399	OUTSIDE STRUCTURE OTHER	0-Building N/A -- See notes	00	Feb 28, 2010
N/A	1299	OPERATING FEATURES OTHER	0-Building N/A -- See notes	000	Feb 28, 2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Stephen Arzie

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: MIDDLEBURG ELEMENTARY
 Address: 3958 MAIN STREET
 Inspection Date: March 24, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	(
111.1.5.3.5	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	7-PERMANENT	49	Apr 24, 2010	1
N/A	1205	FIRE EVACUATION PLAN(S) NOT POSTED	7-PERMANENT	36	Apr 24, 2010	1
1017.10.5.1	0205	EMERG LIGHTING NOT TESTED/RECS MAINT'D	3-PERMANENT	2	Apr 24, 2010	1
N/A	1205	FIRE EVACUATION PLAN(S) NOT POSTED	3-PERMANENT	2	Apr 24, 2010	1
113.6.3	0506	EXTINGUISHER MISSING FROM LOCATION	90-RELOCATABLE	42	Apr 24, 2010	1
113.6.3	0506	EXTINGUISHER MISSING FROM LOCATION	90-RELOCATABLE	55	Apr 24, 2010	1
N/A	0299	MEANS OF EGRESS	90-	29A	Apr 24,	C

OTHER

RELOCATABLE

2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.


Or

Acknowledgement N/A.

Primary inspector: Karen Golish

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: MCRAE ELEMENTARY
 Address: 6770 COUNTY ROAD 315
 Inspection Date: April 14, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipa Complia Date
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	128	Apr 14, 2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	133CORRIDOR	Apr 14, 2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	133coridor	Apr 14, 2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	121coridor	Apr 14, 2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	102	Apr 14, 2010

N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	134	Apr 14, 2010
N/A	0899	UTILITIES OTHER	1-PERMANENT	114	Apr 14, 2010
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	2-PERMANENT	203	Apr 14, 2010
N/A	0211	BLOCKED/LOCKED EXITS	2-PERMANENT	204	Apr 14, 2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	2-PERMANENT	204	Apr 14, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	204	Apr 14, 2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	2-PERMANENT	219	Apr 14, 2010
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	2-PERMANENT	229	Apr 14, 2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	3-PERMANENT	320	Apr 14, 2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	3-PERMANENT	313	Apr 14, 2010
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	3-PERMANENT	301	Apr 14, 2010
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	91- RELOCATABLE	CI261RM701	Apr 14, 2010
N/A	0211	BLOCKED/LOCKED	91-	CI938RM823	Apr 14, 2010

EXITS

RELOCATABLE

2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Kevin Mobley

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: MONTCLAIR ELEMENTARY
 Address: 2398 MOODY ROAD
 Inspection Date: February 22, 2010
 Note: N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0407	FACP INDICATES TROUBLE CONDITION	1-PERMANENT	109	May 3, 2010
N/A	0804	IMPROPER USE OF MULTISTrip/EXTENSION CORDS	5-PERMANENT	514	Apr 5, 2010
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	2-PERMANENT	135	Apr 5, 2010
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	39	Apr 5, 2010
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	31	Apr 5, 2010
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	1-PERMANENT	1	Apr 5, 2010
N/A	1306	FIRE DEPARTMENT	1-PERMANENT	1	Apr 5, 2010

ACCESS INADEQUATE

N/A	0506	EXTINGUISHER MISSING FROM LOCATION	2-PERMANENT	Generatorarea	Apr 5, 2010
-----	------	--	-------------	---------------	-------------

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Silver Ware

Additional inspector: N/A

Powered by [eGroupWare's CSS Design](#) and the [Bureau of Economic and Business Research](#).



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: OAKLEAF VILLAGE ELEMENTARY
 Address: 410 OAKLEAF VILLAGE PARKWAY
 Inspection Date: April 14, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cite
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1- PERMANENT	206	Apr 14, 2010	1
N/A	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	1- PERMANENT	310	Apr 14, 2010	1
N/A	0301	UNPROTECTED VERTICAL OPENING	1- PERMANENT	410	Apr 14, 2010	1
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	0-Building N/A -- See notes	910	Apr 14, 2010	1
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	0-Building N/A -- See notes	909	Apr 14, 2010	1

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.
I hereby certify that the required fire drills have been completed as of this inspection date.
Or
Acknowledgement N/A.
Primary inspector: Raul Feliciano
Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report,-

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: OAKLEAF SCHOOL
 Address: 4085 PLANTATION OAKS BOULEVARD
 Inspection Date: April 14, 2010
 Note: N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	C
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTENSION CORDS	1-PERMANENT	308	Apr 14, 2010	1
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	0-Building N/A -- See notes	617	Apr 14, 2010	1
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	0-Building N/A -- See notes	611	Apr 14, 2010	1

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Raul Feliciano

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

State Fire Marshal - Inspection Report

District - Clay

School - ORANGE PARK ELEMENTARY

Address - 1401 PLAINFIELD AVENUE

Inspection date - 2010-02-24

Notes -

Inspectors present

State No **District Yes** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
	0500 EXTINGUISHMENT	2-PERMANENT	5	2010-02-24	0	portable fire extinguisher is not mounted needs to be mounted
	0600 SPECIAL PROVISIONS	5-PERMANENT	1	2010-02-24	0	items shall not be hanging from the ceiling
	0200 MEANS OF EGRESS	92-RELOCATABLE	53	2010-02-24	0	emergency exit blocked
	0200 MEANS OF EGRESS	92-RELOCATABLE	37	2010-02-24	0	emergency exit blocked
	0200 MEANS OF EGRESS	92-RELOCATABLE	44	2010-02-24	0	emergency exit blocked
	0200 MEANS OF EGRESS	92-RELOCATABLE	54	2010-02-24	0	emergency exit blocked
	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	50	2010-03-02	0	Emergency lighting needs to be repaired
	0804 IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	44	2010-03-02	0	electrical extension cord has bad spot needs to be replaced. electrical cords shall not be used permanently
	0211 BLOCKED/LOCKED EXITS	92-RELOCATABLE	21	2010-03-02	0	emergency exit blocked

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Danny, Yeager

Additional inspector

N/, A



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: PLANTATION OAKS ELEMENTARY
 Address: 4150 PLANTATION OAKS BOULEVARD
 Inspection Date: February 16, 2010
 Note: N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited
N/A	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	1- PERMANENT	R401	Feb 16, 2010	0
N/A	0209	RATED OPENINGS NOT MAINTAINED	1- PERMANENT	712719	Mar 16, 2010	0

N/A	0303	INADEQUATE FIRE RESISTANCE	1- PERMANENT	R303	Mar 16, 2010	0
-----	------	----------------------------------	-----------------	------	-----------------	---

N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	R118	Mar 16, 2010	0
-----	------	-------------------------	-----------------	------	-----------------	---

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.


Or

Acknowledgement N/A.

Primary inspector: Kevin Mobley

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - PATERSON ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: ROBERT M PATERSON ELEMENTARY
 Address: 5400 PINE AVENUE
 Inspection Date: March 23, 2010
 Note: clean school know obvious signs of defaults or violations. All record's kept accordingly with state law.

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipate Compliance Date
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	Kindergardenwing	Apr 30, 2010
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	1stgradewing	Apr 30, 2010
N/A	0100	GENERAL REQUIREMENTS	3-PERMANENT	1stgradewing	Apr 30, 2010
N/A	0200	MEANS OF EGRESS	91-RELOCATABLE	46	Apr 30, 2010

N/A	0200	MEANS OF EGRESS	92- RELOCATABLE	44	Apr 7, 2010
-----	------	--------------------	--------------------	----	-------------

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: randy brunson

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: RIDEOUT ELEMENTARY
 Address: 3065 APALACHICOLA BOULEVARD
 Inspection Date: February 22, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipa Complia Date
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	21- PERMANENT	209	Mar 22, 2010
N/A	0304	PENETRATION PROTECT MISSING/INADEQUATE	1-PERMANENT	240	Mar 22, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	407	Mar 22, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	438	Mar 22, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	457	Mar 22, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	440	Mar 22, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN	1-PERMANENT	463	Mar 22, 2010

CORDS					
N/A	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	1-PERMANENT	466	Mar 22, 2010
N/A	0410	SYSTEM NOT PROERLY INSPECTED/MAINTAINED	1-PERMANENT	00000	Mar 22, 2010
N/A	0209	RATED OPENINGS NOT MAINTAINED	1-PERMANENT	208	Mar 22, 2010
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	0-Building N/A -- See notes	602	Mar 22, 2010
N/A	0803	EXTENSION CORD NOT RATED FOR USE	0-Building N/A -- See notes	602	Mar 22, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	0-Building N/A -- See notes	602	Mar 22, 2010
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	210	Mar 22, 2010
N/A	0301	UNPROTECTED VERTICAL OPENING	1-PERMANENT	344	Mar 22, 2010
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	11	Mar 22, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92- RELOCATABLE	21	Mar 22, 2010
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- RELOCATABLE	23A	Mar 22, 2010
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	92- RELOCATABLE	23A	Mar 22, 2010

N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	22	Mar 22, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92- RELOCATABLE	24	Mar 22, 2010
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	0-Building N/A -- See notes	unkown	Mar 22, 2010
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	0-Building N/A -- See notes	generator	Mar 22, 2010
N/A	1300	OUTSIDE STRUCTURE	1-PERMANENT	1	Mar 22, 2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Stephen Arzie

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - RIDGEVIEW ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay						
School:	RIDGEVIEW ELEMENTARY						
Address:	421 JEFFERSON AVENUE						
Inspection Date:	April 23, 2010						
Note:	N/A						
Inspectors present							
State: No	District: Yes	Local: No					
Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0199	GENERAL REQUIREMENTS	31-PERMANENT	31	Apr 23, 2010	1	must obtain flame cabinet for flammable combustible liquids.
N/A	0211	BLOCKED/LOCKED EXITS	0-Building N/A - - See notes	301	Apr 23, 2010	1	N/A
N/A	0803	EXTENSION CORD NOT RATED FOR USE	0-Building N/A - - See notes	306	Apr 23, 2010	1	N/A
N/A	0211	BLOCKED/LOCKED EXITS	0-Building N/A - - See notes	611	Apr 23, 2010	1	N/A
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	0-Building N/A - - See notes	711	Apr 23, 2010	1	N/A
N/A	0803	EXTENSION CORD NOT RATED FOR USE	0-Building N/A - - See notes	730	Apr 23, 2010	1	N/A
N/A	0211	BLOCKED/LOCKED EXITS	0-Building N/A - - See notes	755	Apr 23, 2010	1	N/A
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A - - See notes	01	Apr 23, 2010	1	This Inspection was done on 4/21/2010
Statements acknowledged							
I hereby certify that the district has complied with section 1013.12(1)(b), F.S.							No
I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.							No
I hereby certify that the required fire drills have been completed as of this inspection date.							No
Or							
Acknowledgement N/A.							Yes
Primary inspector:	Raul Feliciano						
Additional inspector:	N/A						

Powered by [eGroupWare's CSS Design](#) and the [Bureau of Economic and Business Research](#).



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: S BRYAN JENNINGS ELEMENTARY
 Address: 215 CORONA DRIVE
 Inspection Date: February 11, 2010
 Note: all violations were inspected on 02/11/2010

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	C
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	1	Mar 28, 2010	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	31d	Mar 28, 2010	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	22	Mar 28, 2010	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	90- RELOCATABLE	p77	Mar 28, 2010	0

N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	p81	Feb 11, 2010	0
-----	------	---------------------------------	--------------------	-----	-----------------	---

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: james crawford

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: SHADOWLAWN ELEMENTARY
 Address: 2945 County Road 218
 Inspection Date: February 3, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipat Complian Date
N/A	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	1- PERMANENT	213	Feb 3, 201
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1- PERMANENT	300	Mar 3, 201
N/A	0304	PENETRATION PROTECT MISSING/INADEQUATE	1- PERMANENT	413	Feb 3, 201
N/A	0304	PENETRATION PROTECT MISSING/INADEQUATE	1- PERMANENT	413upperlevel	Mar 3, 201
N/A	0511	SPRINK HEAD WRENCH MISSING OR	20- PERMANENT	2001	Mar 3, 201

WRONG TYPE					
N/A	0510	SPARE HEADS MISSING OR WRONG TYPE	25- PERMANENT	2504	Mar 3, 201
N/A	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1- PERMANENT	524	Mar 3, 201

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Stephen Arzie

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - CREEK ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: SWIMMING PEN CREEK ELEMENTARY
 Address: 1630 WOODPECKER LANE
 Inspection Date: April 19, 2010
 Note: School in good shape, they have worked on problems from last year. All paper work on file

Inspectors present

State: No District: Yes Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0200	MEANS OF EGRESS	1-PERMANENT	627	Apr 19, 2010	0	No exit lights or signs, sometimes used as class room.

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: randy brunson

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: THUNDERBOLT ELEMENTARY
 Address: 2020 THUNDERBOLT ROAD
 Inspection Date: April 22, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Not
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	0- Building N/A -- See notes	101	Apr 22, 2010	1	N/A
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	0- Building N/A -- See notes	231	Apr 22, 2010	1	N/A
N/A	0210	EXIT ACCESS NOT MAINTAINED	0- Building N/A -- See notes	731	Apr 22, 2010	1	N/A
N/A	0210	EXIT ACCESS NOT MAINTAINED	0- Building N/A -- See	732	Apr 22, 2010	1	N/A

N/A	0210	EXIT ACCESS NOT MAINTAINED	notes 0- Building N/A -- See notes	733	Apr 22, 2010	1	N/A
N/A	0210	EXIT ACCESS NOT MAINTAINED	notes 0- Building N/A -- See notes	734	Apr 22, 2010	1	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Raul Feliciano

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: TYNES ELEMENTARY
 Address: 1550 TYNES BOULEVARD
 Inspection Date: February 2, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0407	FACP INDICTAES TROUBLE CONDITION	1-PERMANENT	102	Feb 5, 2010
N/A	0304	PENETRATION PROTECT MISSING/INADEQUATE	1-PERMANENT	126	Apr 5, 2010
N/A	0299	MEANS OF EGRESS OTHER	1-PERMANENT	150	Apr 5, 2010
N/A	0303	INADEQUATE FIRE RESISTANCE	2-PERMANENT	210	Apr 5, 2010
N/A	0599	SPRINKLER OTHER	2-PERMANENT	203	Apr 5, 2010

N/A	0509	SPRINK SYSTEM NEEDS INSPECT/TEST/MAINT	2-PERMANENT	203	Apr 5, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	3-PERMANENT	324	Apr 5, 2010
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	3	Apr 5, 2010
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	5	Apr 5, 2010
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	7	Apr 5, 2010
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	8	Apr 5, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92- RELOCATABLE	8	Apr 5, 2010
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	6	Apr 5, 2010
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	27	Apr 5, 2010
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	29	Apr 5, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92- RELOCATABLE	29	Apr 5, 2010
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	30	Apr 5, 2010
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	1-PERMANENT	1	Apr 5, 2010
N/A	1399	OUTSIDE STRUCTURE OTHER	1-PERMANENT	1	Apr 5, 2010

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Silver Ware

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: W E CHERRY ELEMENTARY
 Address: 420 EDSON DRIVE
 Inspection Date: February 23, 2010
 Note: N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	C
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	8	Feb 23, 2010	0
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	1-PERMANENT	4	Feb 23, 2010	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	2	Feb 23, 2010	0
N/A	0299	MEANS OF EGRESS OTHER	1-PERMANENT	2	Feb 23, 2010	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	3	Feb 23, 2010	0

N/A	0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	55	Feb 23, 2010	0
N/A	0301	UNPROTECTED VERTICAL OPENING	2-PERMANENT	55b	Feb 23, 2010	0
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	2-PERMANENT	55b	Feb 23, 2010	0
N/A	0200	MEANS OF EGRESS	1-PERMANENT	63	Feb 23, 2010	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	71	Feb 23, 2010	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	11	Feb 23, 2010	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	27	Feb 23, 2010	0
N/A	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	1-PERMANENT	52	Feb 23, 2010	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	54	Feb 23, 2010	0
N/A	0211	BLOCKED/LOCKED EXITS	2-PERMANENT	75	Feb 23, 2010	0
N/A	0901	IMPROPER STORAGE	2-PERMANENT	48	Feb 23, 2010	0
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	91- RELOCATABLE	50	Feb 23, 2010	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	39	Feb 23, 2010	0

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.


I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: james crawford
Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: J L WILKINSON ELEMENTARY
 Address: 4965 COUNTY ROAD 218
 Inspection Date: March 3, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	2	Apr 3, 2010	0
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	1-PERMANENT	140	Apr 3, 2010	0
N/A	0210	EXIT ACCESS NOT MAINTAINED	91-RELOCATABLE	14	Apr 3, 2010	0
N/A	0210	EXIT ACCESS NOT MAINTAINED	91-RELOCATABLE	13	Apr 3, 2010	0
N/A	1205	FIRE EVACUATION PLAN(S) NOT POSTED	91-RELOCATABLE	16	Apr 3, 2010	0
N/A	0210	EXIT ACCESS NOT	91-RELOCATABLE	18	Apr 3, 2010	0

N/A	1205	MAINTAINED FIRE EVACUATION PLAN(S) NOT POSTED	91- RELOCATABLE	19	Apr 3, 2010	0
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91- RELOCATABLE	53	Apr 3, 2010	0
N/A	0210	EXIT ACCESS NOT MAINTAINED	91- RELOCATABLE	40	Apr 3, 2010	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	36	Apr 3, 2010	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	33	Apr 3, 2010	0
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	4-PERMANENT	408	Apr 3, 2010	0
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	4-PERMANENT	420	Apr 3, 2010	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	4-PERMANENT	66	Apr 3, 2010	0
N/A	0199	GENERAL REQUIREMENTS	3-PERMANENT	313	Apr 3, 2010	0

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Karen Golish

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.