

ELEMENTARY SCHOOLS



ARGYLE ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - ARGYLE ELEMENTARY

Address - 2625 SPENCER PLANTATION BOULEVARD

Inspection date - 2010-11-22

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	5-PERMANENT	510	2010-12-22	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	5-PERMANENT	532	2010-12-22	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	711	2010-12-22	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

CHARLES E. BENNETT ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - CHARLES E BENNETT ELEMENTARY

Address - 1 S OAKRIDGE AVENUE

Inspection date - 2010-11-23

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	4-PERMANENT	15	2010-12-23	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	5-PERMANENT	20	2010-12-23	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	51	2010-12-23	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

CLAY HILL ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - CLAY HILL ELEMENTARY

Address - 6345 STATE ROAD 218

Inspection date - 2010-11-29

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
NFPA7099400-10	0804 IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	206	2011-01-04	0	REPLACE ELECTRICAL CORDS TO HEATERS WITH PERMANENT OUTLETS
NFPA7099400-10	0804 IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	204	2011-01-04	0	REPLACE ELECTRICAL CORDS TO HEATERS WITH PERMANENT OUTLETS

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

COPPERGATE ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - COPPERGATE ELEMENTARY

Address - 2250 COUNTY ROAD 209 NORTH

Inspection date - 2010-12-01

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
-----	----------------	------	------	-----------	-------------

No data present

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

DOCTORS INLET ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - DOCTORS INLET ELEMENTARY

Address - 2634 STATE ROAD 220

Inspection date - 2010-12-03

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	4-PERMANENT	105B	2011-01-06	0	N/A
NFPA70 0809	OPEN ELECTRICAL JUNCTION BOX	92-RELOCATABLE	874	2010-01-06	0	KNOCK-OUT MISSING IN PANEL - DUCT TAPE

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

FLEMING ISLAND ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - FLEMING ISLAND ELEMENTARY

Address - 4425 LAKESHORE DRIVE

Inspection date - 2010-12-06

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
fbc423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	7-	PERMANENT 723	2010-01-06	0	N/A
fbc423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE 601	2011-01-06	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE 604	2011-01-06	0	N/A
NFPA70	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-	RELOCATABLE 608	2011-01-06	0	N/A
NFPA10310.13.1.1	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	92-	RELOCATABLE 797	2011-01-06	0	WRONG NUMBER ON EXTERIOR BUILDING
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE 800	2011-01-06	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE 801	2011-01-06	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE 804	2011-01-06	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE 812	2011-01-06	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE 821	2011-01-06	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE 830	2011-01-06	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector
larry, swanson

Additional inspector
N/, A

GROVE PARK ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - GROVE PARK ELEMENTARY

Address - 1643 MILLER STREET

Inspection date - 2010-12-08

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	92- RELOCATABLE	9	2011- 01-08	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	30	2011- 01-08	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	507	2011- 01-08	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	526	2011- 01-08	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)
(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has
complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of
this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

KEYSTONE HEIGHTS ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - KEYSTONE HEIGHTS ELEMENTARY

Address - 335 S PECAN STREET

Inspection date - 2010-12-09

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	4-PERMANENT	26H	2011-01-21	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	5-PERMANENT	33	2011-01-21	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	7-PERMANENT	12	2011-01-21	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	7-PERMANENT	43	2011-01-21	0	N/A
FBC423.14.2.1	0211	BLOCKED/LOCKED EXITS	8-PERMANENT	7	2011-01-21	0	N/A
NFPA101	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	9-PERMANENT	924	2011-01-21	0	N/A
NFPA101	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	9-PERMANENT	913	2011-01-21	0	REMOVE STORED PAPER TO ROOM 912
NFPA70	0499	FIRE ALARM OTHER	9-PERMANENT	914	2011-01-21	0	FIRE ALARM BOX OPEN ABOVE CEILING
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	11-PERMANENT	1110	2011-01-21	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	12-PERMANENT	NA	2011-01-21	0	N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



Primary inspector
larry, swanson

Additional inspector
N/, A

LAKE ASBURY ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - LAKE ASBURY ELEMENTARY

Address - 2901 SANDRIDGE ROAD

Inspection date - 2011-01-06

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.4 1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	135	2011-02-06	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	3-PERMANENT	NA	2011-02-06	0	EMERGENCY LIGHT OUT BY MAIN SWITCH GEAR
NFPA101 0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	5-PERMANENT	514	2011-02-06	0	LARGE PAPER TREE BY DOOR - REMOVE
NFPA101 0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	5-PERMANENT	520	2011-02-06	0	LARGE PAPER TREE OUTSIDE OF DOOR - REMOVE
NFPA70 0809	OPEN ELECTRICAL JUNCTION BOX	6-PERMANENT	629	2011-02-06	0	COMPUTER PAN-DUIT OPEN FROM FLOOR TO CEILING WITH WIRES EXPOSED
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	11	2011-02-06	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	15	2011-02-06	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	16	2011-02-06	0	N/A
NFPA70 0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	92-RELOCATABLE	79AB	2011-02-06	0	KNOCK OUT MISSING IN ELECTRICAL PANEL
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	87	2011-02-06	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	94	2011-02-06	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector
larry, swanson

Additional inspector
N/, A

LAKESIDE ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - LAKESIDE ELEMENTARY

Address - 2752 MOODY ROAD

Inspection date - 2011-01-05

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	57	2011-02-05	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	54	2011-02-05	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	612	2011-02-05	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector
larry, swanson

Additional inspector
N/, A

McRAE ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - MCRAE ELEMENTARY

Address - 6770 COUNTY ROAD 315

Inspection date - 2010-12-17

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.1 0211	BLOCKED/LOCKED EXITS	5-PERMANENT	537	2011-01-17	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	5-PERMANENT	501	2011-01-17	0	N/A
FBC1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	5-PERMANENT	517	2011-01-17	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	6-PERMANENT	606	2011-01-17	0	N/A
NFPA10.4.1 0405	SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	803	2011-01-17	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

No

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

No

I hereby certify that the required fire drills have been completed as of this inspection date.

No

(Or)

Acknowledgement N/A.

No

Primary inspector

larry, swanson

Additional inspector

N/, A

MIDDLEBURG ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - MIDDLEBURG ELEMENTARY

Address - 3958 MAIN STREET

Inspection date - 2011-01-04

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.20.1 0211	BLOCKED/LOCKED EXITS	4-PERMANENT	18	2011-02-04	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	9-PERMANENT	117	2011-02-04	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	25	2011-02-04	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector
larry, swanson

Additional inspector
N/, A

MONTCLAIR ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - MONTCLAIR ELEMENTARY

Address - 2398 MOODY ROAD

Inspection date - 2011-01-05

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
fbc423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	4-PERMANENT	401	2011-02-05	0	N/A
NFPA70	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	40	2011-02-05	0	SHELF BLOCKING ELECTRICAL PANEL
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	42	2011-02-05	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	45	2011-02-05	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

OAKLEAF VILLAGE ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - OAKLEAF VILLAGE ELEMENTARY

Address - 410 OAKLEAF VILLAGE PARKWAY

Inspection date - 2011-01-07

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
69A-58-106 0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	505	2011-02-07 0	PAPER TREE IN CLASSROOM
69A-58-106 0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	518	2011-02-07 0	PAPER TREE IN CLASSROOM - REMOVE
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	0-Building N/A -- See notes	908	2011-02-07 0	THIS BUILDING IS A RELOCATABLE, BUILDING #92
FBC1003.3.4 0211	BLOCKED/LOCKED EXITS	0-Building N/A -- See notes	914	2011-02-07 0	BUILDING #92: MOVE DESK BY EXIT DOOR; THERE MUST BE A MINIMUM OF 36" CLEAR PATH

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

ORANGE PARK ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - ORANGE PARK ELEMENTARY

Address - 1401 PLAINFIELD AVENUE

Inspection date - 2011-01-11

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	24	2011-02-11	0	N/A
NFPA110.13.1.1	1308 BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	92-RELOCATABLE	37	2011-02-11	0	N/A
NFPA70	0801 INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	52	2011-02-11	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

PLANTATION OAKS ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - PLANTATION OAKS ELEMENTARY

Address - 4150 PLANTATION OAKS BOULEVARD

Inspection date - 2011-01-07

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
NFPA30 0703	LP GAS CYL INSTALLATION/PROTECTION	20- PERMANENT	2000	2011- 02-07	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

R.M. PATERSON ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - ROBERT M PATERSON ELEMENTARY

Address - 5400 PINE AVENUE

Inspection date - 2011-01-31

Notes -

Inspectors present

State No District Yes Local No

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	144	2011-03-10	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	145	2011-03-10	0	N/A
FBC1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	4-PERMANENT	401	2011-03-10	0	N/A
FBC1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	4-PERMANENT	426	2011-03-10	0	N/A
FBC1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	5-PERMANENT	515	2011-03-10	0	N/A
FBC1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	6-PERMANENT	600	2011-03-10	0	N/A
FBC1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	6-PERMANENT	615	2011-03-10	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	21	2011-03-10	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	29	2011-03-10	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

RIDEOUT ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - RIDEOUT ELEMENTARY

Address - 3065 APALACHICOLA BOULEVARD

Inspection date - 2011-01-24

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
NVO	No violations noted this date	0- Building N/A -- See notes	all	2011-01-24	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

RIDGEVIEW ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - RIDGEVIEW ELEMENTARY

Address - 421 JEFFERSON AVENUE

Inspection date - 2011-01-18

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	1-PERMANENT	121	2011-02-18	0	N/A
FBC1006.3.1	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	2-PERMANENT	209	2011-02-18	0	N/A
NFPA70	0899	UTILITIES OTHER	2-PERMANENT	204	2011-02-18	0	N/A
NFPA101	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	6-PERMANENT	603	2011-02-18	0	N/A
NFPA101	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	6-PERMANENT	607	2011-02-18	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	730	2011-02-18	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	743	2011-02-18	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN(S) NOT POSTED	92-RELOCATABLE	753	2011-02-18	0	N/A
MFPA70	0899	UTILITIES OTHER	92-RELOCATABLE	772	2011-02-18	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

S. BRYAN JENNINGS ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - S BRYAN JENNINGS ELEMENTARY

Address - 215 CORONA DRIVE

Inspection date - 2011-01-20

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.14.2.4 1205	FIRE EVACUATION PLAN(S) NOT POSTED	6-PERMANENT	11a	2011-02-20	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN(S) NOT POSTED	9-PERMANENT	22A	2011-02-20	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

SHADOWLAWN ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - SHADOWLAWN ELEMENTARY

Address - 2945 County Road 218

Inspection date - 2011-01-25

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
NFPA101	0506	EXTINGUISHER MISSING FROM LOCATION	1-PERMANENT	604	2011-02-25	0	N/A
NFPA101	0506	EXTINGUISHER MISSING FROM LOCATION	1-PERMANENT	605	2011-02-25	0	N/A
NFPA101	0506	EXTINGUISHER MISSING FROM LOCATION	1-PERMANENT	608	2011-02-25	0	N/A
NFPA101	0506	EXTINGUISHER MISSING FROM LOCATION	1-PERMANENT	609	2011-02-25	0	N/A
FAC69A-48.006	0401	ALRAM LOG NOT MAINT/PRESENT	1-PERMANENT	403	2011-02-25	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	901	2011-02-25	0	N/A
FBC423.17.1	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	902	2011-02-25	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

SWIMMING PEN CREEK ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District ~ Clay

School ~ SWIMMING PEN CREEK ELEMENTARY

Address ~ 1630 WOODPECKER LANE

Inspection date ~ 2011-01-25

Notes ~

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
NFPA13.8.5.5.3 0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	2- PERMANENT	203	2011-02-25 0	0	N/A
NFPA7099370-15 0803	EXTENSION CORD NOT RATED FOR USE	3- PERMANENT	301	2011-02-25 0	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	5- PERMANENT	502	2011-02-25 0	0	N/A
NFPA138.5.5.3 0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	6- PERMANENT	613	2011-02-25 0	0	N/A
NFPA101.7.9 0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	706	2011-02-25 0	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

THUNDERBOLT ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - THUNDERBOLT ELEMENTARY

Address - 2020 THUNDERBOLT ROAD

Inspection date - 2011-02-01

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
NFPA112-1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	1-PERMANENT	118	2011-03-01	0	N/A
NFPA112-1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	1-PERMANENT	116	2011-03-01	0	N/A
NFPA112-1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	1-PERMANENT	324	2011-03-01	0	N/A
NFPA112-1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	1-PERMANENT	234	2011-03-01	0	N/A
NFPA112-1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	1-PERMANENT	301	2011-03-01	0	N/A
NFPA112-1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	1-PERMANENT	303	2011-03-01	0	N/A
NFPA112-1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	1-PERMANENT	305	2011-03-01	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

TYNES ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - TYNES ELEMENTARY

Address - 1550 TYNES BOULEVARD

Inspection date - 2011-02-09

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
fb423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	10	2011-03-09	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

W. E. CHERRY ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - W E CHERRY ELEMENTARY

Address - 420 EDSON DRIVE

Inspection date - 2011-02-08

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1	1205 FIRE EVACUATION PLAN (S) NOT POSTED	3-PERMANENT	16	2011-03-08	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	3-PERMANENT	18	2011-03-08	0	N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN (S) NOT POSTED	4-PERMANENT	22	2011-03-08	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	4-PERMANENT	69	2011-03-08	0	N/A
NFPA70	0806 OUTSIDE GFCI'S IMPROPERLY PROTECTED	92-RELOCATABLE	48	2011-03-08	0	N/A
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	61	2011-03-08	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector
larry, swanson

Additional inspector
N/, A

WILKINSON ELEMENTARY SCHOOL



State Fire Marshal - Inspection Report

District - Clay

School - J L WILKINSON ELEMENTARY

Address - 4965 COUNTY ROAD 218

Inspection date - 2011-02-11

Notes -

Inspectors present

State No District Yes Local No

Ref	Code	Violation	Bldg	Room	Comp date	Cited	Notes
NFPA112-1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	3-PERMANENT	303	2011-03-14	0	N/A
NFPA112-1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	3-PERMANENT	313	2011-03-14	0	N/A
FBC423.20.1	0211	BLOCKED/LOCKED EXITS	4-PERMANENT	400	2011-03-14	0	N/A
FBC423.20.1	0210	EXIT ACCESS NOT MAINTAINED	5-PERMANENT	500	2011-03-14	0	N/A
FBC423.20.1	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	5-PERMANENT	521	2011-03-14	0	N/A
NFPA101.7.9	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	5	2011-03-14	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	16	2011-03-14	0	N/A
FBC423.14.2.4	1205	FIRE EVACUATION PLAN (S) NOT POSTED	92-RELOCATABLE	20	2011-03-14	0	N/A
NFPA70	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	33	2011-03-14	0	N/A
NFPA70	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	43	2011-03-14	0	N/A
NFPA1	0303	INADEQUATE FIRE RESISTANCE	92-RELOCATABLE	44	2011-03-14	0	N/A
FBC423.14.2.4	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	51	2011-03-14	0	N/A
NFPA70400.8	0211	BLOCKED/LOCKED EXITS	92-RELOCATABLE	66	2011-03-14	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S.

No

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

No

I hereby certify that the required fire drills have been completed as of this inspection date.

No

(Or)

Acknowledgement N/A.

No

Primary inspector

larry, swanson

Additional inspector

N/, A