

ANCILLARIES



ADMINISTRATIVE OFFICE ORANGE PARK ANNEX



State Fire Marshal - Inspection Report

District - Clay

School - ADMINISTRATIVE OFFICES ORANGE PARK ANNEX

Address - 2300 KINGSLEY AVENUE

Inspection date - 2010-10-26

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
	NVO No violations noted this date	16-PERMANENT	000	2010-10-26	0 ALL BUILDINGS OK
FBC423.17.1	0299 MEANS OF EGRESS OTHER	17-PERMANENT	ALL	2011-10-26	0 NO EMERGENCY LIGHTS IN WHOLE BUILDING - IMPLEMENT DURING REMODEL SCHEDULED FOR 2011
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	17-PERMANENT	4	2010-11-26	0 N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	17-PERMANENT	5	2010-11-26	0 N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	17-PERMANENT	6	2010-11-26	0 N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	17-PERMANENT	7	2010-11-26	0 N/A
FBC423.14.2.4	1205 FIRE EVACUATION PLAN(S) NOT POSTED	0-Building N/A -- See notes	2	2010-11-26	0 N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N, A

CLAY SUPERINTENDENT'S OFFICE



State Fire Marshal - Inspection Report

District - Clay

School - CLAY SUPERINTENDENT'S OFFICE

Address - 900 WALNUT STREET

Inspection date - 2011-02-25

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
NFPA72 0499	FIRE ALARM OTHER	95-RELOCATABLE	1	2011-03-25	0	N/A
NFPA1 0407	FACP INDICTAES TROUBLE CONDITION	3-PERMANENT	24	2011-03-25	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

FOOD SERVICES STORAGE



State Fire Marshal - Inspection Report

District - Clay

School - FOOD SERVICES STORAGE

Address - 720 CENTER STREET

Inspection date - 2011-02-25

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
NVO	No violations noted this date	95-RELOCATABLE	1	2011-02-25	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

HARRIS C. LONG ADMINISTRATION



State Fire Marshal - Inspection Report

District - Clay

School - HARRIS C LONG ADMINISTRATION

Address - 23 S GREEN STREET

Inspection date - 2011-02-25

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	100	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	3-PERMANENT	300	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	4-PERMANENT	407B	2011-03-25	0	N/A
FBC1006.3.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	4-PERMANENT	404A	2011-03-25	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

KEYSTONE HEIGHTS TRANSPORTATION



State Fire Marshal - Inspection Report

District - Clay

School - KEYSTONE TRANSPORTATION

Address - 6800 COUNTY ROAD 315

Inspection date - 2011-02-16

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	2	2011-03-16 0	N/A
NFPA-70-110	0808 IMPROPER STORAGE IN ELECT/MECH ROOMS	91-RELOCATABLE	2	2011-03-16 0	SHELF BLOCKING ELECTRICAL PANEL - MOVE SHELF

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

MIDDLEBURG TRANSPORTATION



State Fire Marshal - Inspection Report

District - Clay

School - MIDDLEBURG TRANSPORTATION

Address - 3674 COUNTY ROAD 2

Inspection date - 2011-01-14

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
	0010 IMMINENT HAZARD	1- PERMANENT	1	2011-01-14	0	ALL BUILDINGS OK

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

SCHOOL BUS GARAGE



State Fire Marshal - Inspection Report

District - Clay

School - SCHOOL BUS GARAGE

Address - 800 CENTER STREET

Inspection date - 2011-02-02

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	11	2011-03-02	0	N/A
NFPA10314.14.1.2	0299 MEANS OF EGRESS OTHER	1-PERMANENT	10	2011-03-02	0	REMOVE EXIT STICKER FROM DOOR-NOT AN EXIT
FBC423.17.1	0204 EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	200	2011-03-02	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

larry, swanson

Additional inspector

N/, A

SUPPORT SERVICES AG LOT



State Fire Marshal - Inspection Report

District - Clay**School** - SUPPORT SERVICES AG LOT**Address** - ROBERTS STREET**Inspection date** - 2011-02-25**Notes** -**Inspectors present****State No** **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
NVO	No violations noted this date	95-RELOCATABLE	1	2011-02-25	0	N/A

Statements acknowledgedI hereby certify that the district has complied with section 1013.12(1) (b), F.S. **Yes**I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No****Primary inspector**

larry, swanson

Additional inspector

N/, A

SUPPORT SERVICES CENTER



State Fire Marshal - Inspection Report

District - Clay

School - SUPPORT SERVICES CENTER

Address - 925 W CENTER STREET

Inspection date - 2011-02-25

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	11A	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	34	2011-03-25	0	N/A
69A-58.008 0503	MONTHLY INSPECTION NOT DONE/RECORDED	1-PERMANENT	20	2011-03-25	0	N/A
69A-58.008 0503	MONTHLY INSPECTION NOT DONE/RECORDED	2-PERMANENT	4	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	4-PERMANENT	2	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	9-PERMANENT	911A	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	9-PERMANENT	906	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	10-PERMANENT	107	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	10-PERMANENT	108	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	10-PERMANENT	104	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	10-PERMANENT	101	2011-03-25	0	N/A
FBC423.17.1 0204	EMERG LIGHTS NOT OPERATIONAL	10-PERMANENT	115	2011-03-25	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**