


# JUNIOR HIGH SCHOOLS



# BANNERMAN LEARNING CENTER





# State Fire Marshal - Inspection Report - LEARNING RESOURCE CENTER

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay  
 School: R C BANNERMAN LEARNING RESOURCE CENTER  
 Address: 608 MILL STREET  
 Inspection Date: March 10, 2011  
 Note: N/A

### Inspectors present

State: No    District: No    Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	90-RELOCATABLE	portables	Mar 10, 2011
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90-RELOCATABLE	34	Mar 10, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	90-RELOCATABLE	7	Mar 10, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	108	Mar 10, 2011
N/A	0211	BLOCKED/LOCKED EXITS	1-PERMANENT	109	Mar 10, 2011
N/A	0499	FIRE ALARM OTHER	1-PERMANENT	319	Mar 10, 2011

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: clu wright

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



# GREEN COVE SPRINGS JUNIOR HIGH





# State Fire Marshal - Inspection Report - SPRINGS JUNIOR HIGH

PDF version is recommended for printing and requires Adobe Reader

District: Clay  
 School: GREEN COVE SPRINGS JUNIOR HIGH  
 Address: 1220 BONAVENTURE AVENUE  
 Inspection Date: March 10, 2011  
 Note: N/A

## Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	1299	OPERATING FEATURES OTHER	1-PERMANENT	27e	Mar 10, 2011
N/A	0899	UTILITIES OTHER	1-PERMANENT	7	Mar 10, 2011
N/A	0799	BUILDING SERVICES OTHER	1-PERMANENT	closet	Mar 10, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	20	Mar 10, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	109	Mar 10, 2011
N/A	0803	EXTENSION	1-PERMANENT	101	Mar 10,

		CORD NOT RATED FOR USE			2011
N/A	0799	BUILDING SERVICES OTHER	1-PERMANENT	31b	Mar 10, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	411	Mar 10, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	411	Mar 10, 2011
N/A	0799	BUILDING SERVICES OTHER	1-PERMANENT	lincolntunnel	Mar 10, 2011
N/A	0799	BUILDING SERVICES OTHER	1-PERMANENT	422	Mar 10, 2011
N/A	0299	MEANS OF EGRESS OTHER	1-PERMANENT	laundryroom	Mar 10, 2011
N/A	0299	MEANS OF EGRESS OTHER	92- RELOCATABLE	601	Mar 10, 2011

### Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.


Primary inspector: clu wright

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

# LAKE ASBURY JUNIOR HIGH





## State Fire Marshal - Inspection Report - JUNIOR HIGH

PDF version is recommended for printing and requires Adobe Reader

District: Clay  
 School: LAKE ASBURY JUNIOR HIGH  
 Address: 2851 SANDRIDGE ROAD  
 Inspection Date: March 28, 2011  
 Note: N/A

### Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	C
N/A	0209	RATED OPENINGS NOT MAINTAINED	2-PERMANENT	215	Apr 28, 2011	0
N/A	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	3-PERMANENT	345	Apr 28, 2011	0
N/A	0803	EXTENSION CORD NOT RATED FOR USE	2-PERMANENT	209	Apr 28, 2011	0
N/A	0803	EXTENSION CORD NOT RATED FOR USE	2-PERMANENT	212	Apr 28, 2011	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	5-PERMANENT	500	Apr 28, 2011	0
N/A	0803	EXTENSION CORD NOT RATED FOR USE	5-PERMANENT	521	Apr 28, 2011	0

N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	5-PERMANENT	519	Apr 28, 2011	0
N/A	0803	EXTENSION CORD NOT RATED FOR USE	6-PERMANENT	613	Apr 28, 2011	1
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	7-PERMANENT	706	Apr 28, 2011	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	8106	Apr 28, 2011	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	8021	Apr 28, 2011	1
N/A	0803	EXTENSION CORD NOT RATED FOR USE	8-PERMANENT	8032	Apr 28, 2011	0
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	8-PERMANENT	8007	Apr 28, 2011	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	8125	Apr 28, 2011	0
N/A	0803	EXTENSION CORD NOT RATED FOR USE	8-PERMANENT	8052	Apr 28, 2011	0
N/A	0803	EXTENSION CORD NOT RATED FOR USE	8-PERMANENT	8042	Apr 28, 2011	0
N/A	0803	EXTENSION CORD NOT RATED FOR USE	8-PERMANENT	8060	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	8-PERMANENT	8091	Apr 28, 2011	0

N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	8090	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	8-PERMANENT	8089	Apr 28, 2011	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	8071	Apr 28, 2011	0
N/A	0803	EXTENSION CORD NOT RATED FOR USE	8-PERMANENT	8076	Apr 28, 2011	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	91- RELOCATABLE	422	Apr 28, 2011	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	421	Apr 28, 2011	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	423	Apr 28, 2011	0
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91- RELOCATABLE	423	Apr 28, 2011	0
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	91- RELOCATABLE	423	Apr 28, 2011	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	427	Apr 28, 2011	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	B20	Apr 28, 2011	0
N/A	0202	EXIT LIGHTS INOPERABLE NORMAL MODE	91- RELOCATABLE	B20	Apr 28, 2011	0
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	91- RELOCATABLE	B20	Apr 28, 2011	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	91- RELOCATABLE	410	Apr 28, 2011	0
N/A	1308	BLDG ADDRESS/I.D. NOT	91- RELOCATABLE	409	Apr 28, 2011	0

		PRESENT/VISIBLE				
N/A	0400	FIRE ALARM	91- RELOCATABLE	408	Apr 28, 2011	0
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	91- RELOCATABLE	403	Apr 28, 2011	0
N/A	0803	EXTENSION CORD NOT RATED FOR USE	91- RELOCATABLE	403	Apr 28, 2011	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	390	Apr 28, 2011	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	393	Apr 28, 2011	0
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	91- RELOCATABLE	394	Apr 28, 2011	0
N/A	0803	EXTENSION CORD NOT RATED FOR USE	91- RELOCATABLE	494	Apr 28, 2011	0

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Stephen Arzie

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



# LAKESIDE JUNIOR HIGH





# State Fire Marshal - Inspection Report - HIGH

PDF version is recommended for printing and requires Adobe Reader

District: Clay  
 School: LAKESIDE JUNIOR HIGH  
 Address: 2750 MOODY ROAD  
 Inspection Date: April 18, 2011  
 Note: N/A

## Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	5-PERMANENT	133	May 18, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	5-PERMANENT	116	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	5-PERMANENT	208	Apr 22, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	9	May 18, 2011

N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	10	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	11	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	1	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	2	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	3	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	28	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	29	May 18, 2011

N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	30	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	18	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	19	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	20	May 18, 2011
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	1-PERMANENT	Hallways	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	40	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN	2-PERMANENT	54	May 18, 2011

## CORDS

N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	53	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	45	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	44	May 18, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	44	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	43	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	3-PERMANENT	57	May 18, 2011
N/A	0204	EMERG LIGHTS	3-PERMANENT	57	May 18,

		NOT OPERATIONAL			2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	3-PERMANENT	59	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	3-PERMANENT	58	May 18, 2011
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	3-PERMANENT	Hallway	May 18, 2011
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	3-PERMANENT	67	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	3-PERMANENT	71	May 18, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	3-PERMANENT	71	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	3-PERMANENT	79	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	814	May 18, 2011
N/A	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	91- RELOCATABLE	724	May 18, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	91- RELOCATABLE	710	May 18, 2011

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Jason Boree

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

# OAKLEAF JUNIOR HIGH







# State Fire Marshal - Inspection Report -

PDF version is recommended for printing and requires Adobe Reader

District: Clay  
 School: OAKLEAF SCHOOL  
 Address: 4085 PLANTATION OAKS BOULEVARD  
 Inspection Date: March 29, 2011  
 Note: N/A

**Inspectors present**

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0506	EXTINGUISHER MISSING FROM LOCATION	0-Building N/A -- See notes	MDF126	Mar 29, 2016
N/A	0599	SPRINKLER OTHER	0-Building N/A -- See notes	211	Apr 29, 2011
N/A	0508	INADEQUATE CLEARANCE BELOW SPRINK HEAD	5-PERMANENT	517	Apr 29, 2011
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	5-PERMANENT	518	Apr 29, 2011
N/A	0804	IMPROPER USE OF MULTISTRIPEXTEN CORDS	92-RELOCATABLE	611	Apr 29, 2011
N/A	0204	EMERG LIGHTS NOT	92-	707	Apr 29,

		OPERATIONAL	RELOCATABLE		2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	709	Apr 29, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	712	Apr 29, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	716	Apr 29, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	811	Apr 29, 2011
N/A	1399	OUTSIDE STRUCTURE OTHER	1-PERMANENT	1	Apr 29, 2011
N/A	0199	GENERAL REQUIREMENTS	1-PERMANENT	1	Apr 29, 2011
N/A	1307	FIRE HYDRANT(S) NOT MAINTAINED	0-Building N/A -- See notes	1	Apr 29, 2011
N/A	0304	PENETRATION PROTECT MISSING/INADEQUATE	0-Building N/A -- See notes	1	Apr 29, 2011

### Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Silver Ware

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

# ORANGE PARK JUNIOR HIGH





N/A

Yes

## State Fire Marshal - Inspection Report - ORANGE PARK JUNIOR HIGH

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay  
 School: ORANGE PARK JUNIOR HIGH  
 Address: 1500 GANO AVENUE  
 Inspection Date: May 9, 2011  
 Note: Numerous stairwell doors were found blocked open stairwells are designed to give the occupants time to exit the building without fire and smoke getting into this area. if doors are blocked open this safety feature is lost.

**Inspectors present**

State: No    District: Yes    Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0203	EXIT LIGHTS INOPERABLE EMERGENCY MODE	1-PERMANENT	127	May 9, 2011	0	Exit Sign not working
N/A	0211	BLOCKED/LOCKED EXITS	1-PERMANENT	127	May 9, 2011	0	Exit from stage in the back is blocked on both sides.
N/A	0212	AREA OF REFUGE NOT MAINTAINED	1-PERMANENT	136	May 9, 2011	0	Stairwell not kept clear of combustible items.
N/A	0211	BLOCKED/LOCKED EXITS	2-PERMANENT	206A	May 9, 2011	0	Emergency exit blocked.
N/A	0211	BLOCKED/LOCKED EXITS	2-PERMANENT	202	May 9, 2011	0	Emergency exit blocked
N/A	0209	RATED OPENINGS NOT MAINTAINED	2-PERMANENT	217A	May 9, 2011	0	Doors for stairwell are not closing
N/A	0399	PROTECTION OTHER	2-PERMANENT	257	May 9, 2011	0	the closer on the fire door in hallway is disconnected / broken.
N/A	0211	BLOCKED/LOCKED EXITS	3-PERMANENT	302	May 9, 2011	0	Emergency exit blocked.
N/A	0211	BLOCKED/LOCKED EXITS	3-PERMANENT	306	May 9, 2011	0	Emergency exit blocked
N/A	0211	BLOCKED/LOCKED EXITS	3-PERMANENT	308	May 9, 2011	0	Emergency exit blocked
N/A	0399	PROTECTION OTHER	3-PERMANENT	317	May 9, 2011	0	Door found blocked open.
N/A	0211	BLOCKED/LOCKED EXITS	4-PERMANENT	456	May 9, 2011	0	Emergency exit blocked.
N/A	0211	BLOCKED/LOCKED EXITS	4-PERMANENT	408	May 9, 2011	0	Emergency exit blocked
N/A	0211	BLOCKED/LOCKED EXITS	4-PERMANENT	407	May 9, 2011	0	Emergency exit blocked
N/A	0211	BLOCKED/LOCKED EXITS	4-PERMANENT	403	May 9, 2011	0	Emergency exit blocked
N/A	0209	RATED OPENINGS NOT MAINTAINED	4-PERMANENT	465	May 9, 2011	0	Stairwell door closer broken.
N/A	NVO	No violations noted this date	6-PERMANENT	000	May 9, 2011	0	N/A
N/A	0506	EXTINGUISHER MISSING FROM LOCATION	5-PERMANENT	000	May 9, 2011	1	All portable fire extinguishers have been taken out of there cabinets.
N/A	0203	EXIT LIGHTS INOPERABLE	5-	502	May 9, 2011	0	Emergency lighting does

N/A	0502	EMERGENCY MODE PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	PERMANENT 4- PERMANENT	457	May 9, 2011	0	not work. Portable fire extinguisher needs to be mounted.
-----	------	---	------------------------------	-----	-------------	---	---

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. Yes

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. Yes

I hereby certify that the required fire drills have been completed as of this inspection date. No

Or  
Acknowledgement N/A. No

Primary inspector: **Danny Yeager**

Additional inspector:

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

# WILKINSON JUNIOR HIGH





# State Fire Marshal - Inspection Report - JUNIOR HIGH

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay
School:	JACK L WILKINSON JUNIOR HIGH
Address:	5025 STATE ROAD 218
Inspection Date:	March 7, 2011
Note:	N/A

**Inspectors present**

State: No    District: Yes    Local: No

Reference	Code	Violation	Building	Room	Anticipate Compliance Date
5.10.1.2	0299	MEANS OF EGRESS OTHER	90- RELOCATABLE	5	Mar 7, 201
5.10.1.2	0299	MEANS OF EGRESS OTHER	90- RELOCATABLE	10	Mar 7, 201
5010.1.2	0299	MEANS OF EGRESS OTHER	90- RELOCATABLE	17	Mar 7, 201
5.10.1.2	0299	MEANS OF EGRESS OTHER	90- RELOCATABLE	30	Mar 7, 201
5.10.1.2	0010	IMMINENT HAZARD	90- RELOCATABLE	40	Mar 7, 201
5.10.1.2	0299	MEANS OF EGRESS OTHER	90- RELOCATABLE	41	Mar 7, 201
5.10.1.2	0299	MEANS OF EGRESS OTHER	90- RELOCATABLE	43	Mar 7, 201
5.10.1.2	0299	MEANS OF EGRESS OTHER	4-PERMANENT	412	Mar 7, 201
5.10.1.2	0010	IMMINENT HAZARD	4-PERMANENT	405	Mar 7, 201

5.10.1.2	0299	MEANS OF EGRESS OTHER	3-PERMANENT	317	Mar 7, 201
5.10.1.2	0299	MEANS OF EGRESS OTHER	4-PERMANENT	407	Mar 7, 201
5.10.1.2	0010	IMMINENT HAZARD	4-PERMANENT	414	Mar 7, 201
10.310-25	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	4-PERMANENT	414	Mar 7, 201
10.310-25	0809	OPEN ELECTRICAL JUNCTION BOX	4-PERMANENT	410	Mar 7, 201
N/A	0199	GENERAL REQUIREMENTS	90- RELOCATABLE	12	Mar 7, 201
1.11.1.5.3.5	0803	EXTENSION CORD NOT RATED FOR USE	6-PERMANENT	600	Mar 7, 201

### Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.


Primary inspector: Karen Golish

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.




# SENIOR HIGH SCHOOLS



# CLAY HIGH SCHOOL





# State Fire Marshal - Inspection Report - SCHOOL

PDF version is recommended for printing and requires Adobe Reader

District:	Clay
School:	CLAY HIGH SCHOOL
Address:	2025 HIGHWAY 16 W
Inspection Date:	March 28, 2011
Note:	All Alarm paper work on file
<b>Inspectors present</b>	
State: No	District: No    Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	C
N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	921	Mar 28, 2011	0
N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	916	Mar 28, 2011	0
N/A	0010	IMMINENT HAZARD	1- PERMANENT	913	Mar 28, 2011	0
N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	gym	Mar 28, 2011	0

N/A	0010	IMMINENT HAZARD	1-PERMANENT	gymsouthend	Mar 28, 2011	0
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	328	Mar 28, 2011	0

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.  
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.  
 I hereby certify that the required fire drills have been completed as of this inspection date.  
 Or  
 Acknowledgement N/A.

Primary inspector: randy brunson  
 Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

# FLEMING ISLAND HIGH SCHOOL





# State Fire Marshal - Inspection Report - SENIOR HIGH

PDF version is recommended for printing and requires Adobe Reader

District: Clay  
 School: FLEMING ISLAND SENIOR HIGH  
 Address: 2233 VILLAGE SQUARE PARKWAY  
 Inspection Date: March 16, 2011  
 Note: School looks to be in good shape.

**Inspectors present**

State: No    District: No    Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cite
N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	042	Mar 25, 2011	0
N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	216	Mar 25, 2011	1
N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	Mech1028	Mar 25, 2011	1

N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	Libary	Mar 25, 2011	0
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	268	Mar 25, 2011	2
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	267	Mar 25, 2011	2

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.  
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.  
 I hereby certify that the required fire drills have been completed as of this inspection date.  
 Or  
 Acknowledgement N/A.

Primary inspector: randy brunson  
 Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



# KEYSTONE HEIGHTS JUNIOR/SENIOR HIGH







# State Fire Marshal - Inspection Report - KEYSTONE HEIGHTS JUNIOR/SENIOR HIGH

PDF version is recommended for printing and requires Adobe Reader

District:	Clay
School:	KEYSTONE HEIGHTS JUNIOR/SENIOR HIGH
Address:	900 SW ORCHID AVENUE
Inspection Date:	December 2, 2010
Note:	N/A

**Inspectors present**

State: No    District: No    Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0407	FACP INDICATES TROUBLE CONDITION	1-PERMANENT	112	Dec 29, 2010
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	1-PERMANENT	112	Dec 2, 2010
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	1-PERMANENT	106	Dec 2, 2010
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	180	Dec 2, 2010
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	5-PERMANENT	548	Dec 2, 2010
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	4-PERMANENT	403	Dec 2, 2010

N/A	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	7478	Dec 2, 2010
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	82	Dec 2, 2010
N/A	0899	UTILITIES OTHER	92-RELOCATABLE	84	Dec 2, 2010
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	11	Dec 2, 2010
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	52	Dec 2, 2010
N/A	0899	UTILITIES OTHER	92-RELOCATABLE	62	Dec 2, 2010


**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.  
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.  
 I hereby certify that the required fire drills have been completed as of this inspection date.  
 Or  
 Acknowledgement N/A.

Primary inspector: Silver Ware  
 Additional inspector: N/A

# MIDDLEBURG HIGH SCHOOL





# State Fire Marshal - Inspection Report - SENIOR HIGH

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay
School:	MIDDLEBURG SENIOR HIGH
Address:	3750 STATE ROAD 220
Inspection Date:	March 23, 2011
Note:	N/A
<b>Inspectors present</b>	
State: No	District: Yes    Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0499	FIRE ALARM OTHER	1-PERMANENT	MainOffice	Apr 23, 2011
N/A	0805	GFCI'S NOT INSTALLED IN WET LOCATIONS	1-PERMANENT	289	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	330	Apr 23, 2011
N/A	0301	UNPROTECTED VERTICAL OPENING	1-PERMANENT	304	Apr 23, 2011

N/A	0301	UNPROTECTED VERTICAL OPENING	1-PERMANENT	294	Apr 23, 2011
N/A	0301	UNPROTECTED VERTICAL OPENING	1-PERMANENT	298	Apr 23, 2011
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	1-PERMANENT	298	Apr 23, 2011
N/A	0103	BLDG CONST/RENOVAT WITHOUT PLAN APPROVAL	1-PERMANENT	Nextto298	Apr 23, 2011
N/A	0704	COMPRESSED GAS CYLINDERS NOT SECURED	1-PERMANENT	277	Apr 23, 2011
N/A	1306	FIRE DEPARTMENT ACCESS INADEQUATE	1-PERMANENT	371	Apr 1, 2011
N/A	1306	FIRE DEPARTMENT ACCESS INADEQUATE	1-PERMANENT	372	Apr 1, 2011
N/A	0211	BLOCKED/LOCKED EXITS	1-PERMANENT	361B	Apr 1, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	358	Apr 23, 2011
N/A	0399	PROTECTION OTHER	1-PERMANENT	342	Apr 23, 2011

N/A	0211	BLOCKED/LOCKED EXITS	1-PERMANENT	341	Apr 1, 2011
N/A	0210	EXIT ACCESS NOT MAINTAINED	1-PERMANENT	341	Apr 23, 2011
N/A	1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	1-PERMANENT	360	Apr 1, 2011
N/A	0704	COMPRESSED GAS CYLINDERS NOT SECURED	1-PERMANENT	361	Apr 23, 2011
N/A	0211	BLOCKED/LOCKED EXITS	1-PERMANENT	367	Apr 1, 2011
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	1-PERMANENT	367	Apr 23, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	226	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	226	Apr 23, 2011
N/A	1202	DANGEROUS CONDITION EXISTS	1-PERMANENT	230	Apr 23, 2011
N/A	0704	COMPRESSED GAS CYLINDERS NOT SECURED	1-PERMANENT	229C	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	241	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	240	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	239	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	178	Apr 23, 2011

N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	136	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	142	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	122	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	129	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	62	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	54	Apr 23, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	33	Apr 23, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	91-RELOCATABLE	64	Apr 23, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	91-RELOCATABLE	9	Apr 23, 2011

**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or


Acknowledgement N/A.

Primary inspector: Jason Boree

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

# ORANGE PARK HIGH SCHOOL







# State Fire Marshal - Inspection Report - SENIOR HIGH

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay
School:	ORANGE PARK SENIOR HIGH
Address:	2300 KINGSLEY AVENUE
Inspection Date:	March 29, 2011
Note:	Fire drill and alarm paper work on file. Through out the entire school there are numours door windows covered with paper products.
<b>Inspectors present</b>	
State: No	District: No    Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	Library	Mar 29, 2011
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	126	Mar 29, 2011
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	elec9	Mar 29, 2011
N/A	0200	MEANS OF EGRESS	90-RELOCATABLE	K10	Mar 29, 2011
N/A	0200	MEANS OF EGRESS	1-PERMANENT	L1	Mar 29, 2011
N/A	0200	MEANS OF EGRESS	0-Building N/A -- See notes	Room13Gym	Mar 29, 2011



**Statements acknowledged**

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector:                   randy brunson

Additional inspector:               N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

# RIDGEVIEW HIGH SCHOOL





# State Fire Marshal - Inspection Report - SENIOR HIGH

PDF version is recommended for printing and requires Adobe Reader

District: Clay  
 School: RIDGEVIEW SENIOR HIGH  
 Address: 466 MADISON AVENUE  
 Inspection Date: March 29, 2011  
 Note: Frie drill and alarm paper work on file.

## Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	AVstorageroom	Mar 29, 2011
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	libarystorage	Mar 29, 2011
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	630	Mar 29, 2011
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	632	Mar 29, 2011
N/A	0010	IMMINENT HAZARD	1-PERMANENT	613	Mar 29, 2011
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	650	Mar 29, 2011
N/A	0100	GENERAL REQUIREMENTS	2-PERMANENT	676	Mar 29, 2011
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	309	Mar 29, 2011

N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	315	Mar 29, 2011
N/A	0300	PROTECTION	1-PERMANENT	346	Mar 29, 2011
N/A	0200	MEANS OF EGRESS	90-RELOCATABLE	82	Mar 29, 2011
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	1037	Mar 29, 2011
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	1013	Mar 29, 2011

### Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: randy brunson

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.