

ELEMENTARY SCHOOLS



ARGYLE ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District:	Clay
School:	ARGYLE ELEMENTARY
Address:	2625 SPENCER PLANTATION BOULEVARD
Inspection Date:	March 16, 2011
Note:	N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited
1017.10.5.1	0299	MEANS OF EGRESS OTHER	91-RELOCATABLE	706	Apr 16, 2011	0
1017.10.5.1	0299	MEANS OF EGRESS OTHER	91-RELOCATABLE	707	Apr 16, 2011	0
31-8.4.1	1205	FIRE EVACUATION PLAN(S) NOT POSTED	91-RELOCATABLE	707	Mar 25, 2011	0
31-8.4.1	1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	410	Apr 16, 2011	0
31-8.4.1	1205	FIRE EVACUATION PLAN(S) NOT POSTED	91-RELOCATABLE	804	Apr 16, 2011	0
31-8.4.1	1205	FIRE EVACUATION PLAN(S) NOT	91-RELOCATABLE	901	Mar 25, 2011	0

1017.10.5.1	0299	POSTED MEANS OF EGRESS OTHER	91- RELOCATABLE	711	Apr 16, 2011	0
N/A	0199	GENERAL REQUIREMENTS	0-Building N/A -- See notes	1908	Apr 16, 2011	0

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.
 I hereby certify that the required fire drills have been completed as of this inspection date.
 Or
 Acknowledgement N/A.

Primary inspector: Karen Golish
 Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

CHARLES E. BENNETT ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - BENNETT ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: CHARLES E BENNETT ELEMENTARY
 Address: 1 S OAKRIDGE AVENUE
 Inspection Date: March 15, 2011
 Note: Clean school.

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
-----------	------	-----------	----------	------	-----------------------------	-------	-------

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.
 I hereby certify that the required fire drills have been completed as of this inspection date.
 Or
 Acknowledgement N/A.

Primary inspector: randy brunson
 Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

CLAY HILL ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: CLAY HILL ELEMENTARY
 Address: 6345 STATE ROAD 218
 Inspection Date: March 7, 2011
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited
5.10.1.2	0299	MEANS OF EGRESS OTHER	91-RELOCATABLE	704	Mar 7, 2011	0
5.10.1.2	0299	MEANS OF EGRESS OTHER	91-RELOCATABLE	706	Mar 7, 2011	0
101.1.9.2.3	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	707	Mar 7, 2011	0
10.370-25	0809	OPEN ELECTRICAL JUNCTION BOX	1-PERMANENT	104A	Mar 7, 2011	0

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.


I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Karen Golish

Additional inspector: N/A




Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

STATE FIRE MARCH 10

COPPERGATE ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District:	Clay
School:	COPPERGATE ELEMENTARY
Address:	2250 COUNTY ROAD 209 NORTH
Inspection Date:	December 15, 2010
Note:	N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	C
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	338	Jan 15, 2011	1
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	451	Dec 15, 2011	0
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	21-PERMANENT	21	Dec 15, 2011	1
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	91-RELOCATABLE	502	Dec 15, 2011	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	502	Dec 15, 2011	0
N/A	0210	EXIT ACCESS NOT MAINTAINED	91-RELOCATABLE	502	Dec 15, 2011	0

N/A	0210	EXIT ACCESS NOT MAINTAINED	91-RELOCATABLE	503	Dec 15, 2011	0
N/A	0514	STANDPIPE SYSTEM INOPERABLE	0-Building N/A -- See notes	000	Dec 15, 2011	2

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.
 I hereby certify that the required fire drills have been completed as of this inspection date.
 Or
 Acknowledgement N/A.

Primary inspector: Stephen Arzie
 Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

DOCTORS INLET ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: DOCTORS INLET ELEMENTARY
 Address: 2634 STATE ROAD 220
 Inspection Date: March 29, 2011
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	4-PERMANENT	123	Apr 29, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	4-PERMANENT	123	Apr 29, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	4-PERMANENT	108	Apr 29, 2011
N/A	0506	EXTINGUISHER MISSING FROM LOCATION	7-PERMANENT	701	Apr 29, 2011
N/A	0210	EXIT ACCESS NOT MAINTAINED	7-PERMANENT	702	Apr 29, 2011

N/A	0210	EXIT ACCESS NOT MAINTAINED	7-PERMANENT	700	Apr 29, 2011
N/A	0210	EXIT ACCESS NOT MAINTAINED	8-PERMANENT	802	Apr 29, 2011
N/A	1205	FIRE EVACUATION PLAN(S) NOT POSTED	8-PERMANENT	803	Apr 29, 2011
N/A	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	8-PERMANENT	806	Apr 29, 2011
N/A	0210	EXIT ACCESS NOT MAINTAINED	8-PERMANENT	806	Apr 29, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	9-PERMANENT	901A	Apr 29, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	9-PERMANENT	904	Apr 29, 2011
N/A	0899	UTILITIES OTHER	9-PERMANENT	902A	Apr 29, 2011
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	90-RELOCATABLE	845	Apr 29, 2011
N/A	0899	UTILITIES OTHER	90-RELOCATABLE	845	Apr 29, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	90-RELOCATABLE	847	Apr 29, 2011
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	90-RELOCATABLE	851	Apr 29, 2011
N/A	1303	EXIT DISCHARGE NOT MAINTAINED	90-RELOCATABLE	851	Apr 29, 2011
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	90-RELOCATABLE	844	Apr 29, 2011

N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	90- RELOCATABLE	840	Apr 29, 2011
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	90- RELOCATABLE	840	Apr 29, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	90- RELOCATABLE	840	Apr 29, 2011
N/A	0899	UTILITIES OTHER	90- RELOCATABLE	869	Apr 29, 2011
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	90- RELOCATABLE	870	Apr 29, 2011
N/A	0899	UTILITIES OTHER	90- RELOCATABLE	872	Apr 29, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90- RELOCATABLE	874	Apr 29, 2011
N/A	0899	UTILITIES OTHER	90- RELOCATABLE	874	Apr 29, 2011
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	90- RELOCATABLE	876	Apr 29, 2011
N/A	0899	UTILITIES OTHER	90- RELOCATABLE	876	Apr 29, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	90- RELOCATABLE	895	Apr 29, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90- RELOCATABLE	895	Apr 29, 2011
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	90- RELOCATABLE	894	Apr 29, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN	90- RELOCATABLE	893	Apr 29, 2011

CORDS

N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	90- RELOCATABLE	892	Apr 29, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	90- RELOCATABLE	892	Apr 29, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90- RELOCATABLE	891	Apr 29, 2011
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	90- RELOCATABLE	890	Apr 29, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90- RELOCATABLE	890	Apr 29, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	90- RELOCATABLE	889	Apr 29, 2011
N/A	0899	UTILITIES OTHER	90- RELOCATABLE	889	Apr 29, 2011
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	0-Building N/A -- See notes	copyroom	Apr 29, 2011
N/A	0301	UNPROTECTED VERTICAL OPENING	0-Building N/A -- See notes	copyroom	Apr 29, 2011
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	5-PERMANENT	108	Apr 29, 2011
N/A	0899	UTILITIES OTHER	5-PERMANENT	stage	Apr 29, 2011

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or


Acknowledgement N/A.

Primary inspector: Stephen Arzie
Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

FLEMING ISLAND ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: FLEMING ISLAND ELEMENTARY
 Address: 4425 LAKESHORE DRIVE
 Inspection Date: March 25, 2011
 Note: Clean school has been working to make sure all past violations were corrected.

Inspectors present

State: No District: No Local: Yes


Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited
N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	Libary	Mar 25, 2011	0
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	42	Mar 25, 2011	0
N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	820	Mar 25, 2011	0

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.
 I hereby certify that the required fire drills have been completed as of this inspection date.
 Or
 Acknowledgement N/A.

Primary inspector: randy brunson
Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.



[The following text is extremely faint and illegible, appearing to be a large block of mirrored or bleed-through text.]

GROVE PARK ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - GROVE PARK ELEMENTARY


PDF version is recommended for printing and requires Adobe Reader

District:	Clay						
School:	GROVE PARK ELEMENTARY						
Address:	1643 MILLER STREET						
Inspection Date:	April 22, 2011						
Note:	N/A						
Inspectors present							
State:	No	District:	Yes	Local:	No		
Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	NVO	No violations noted this date	1-PERMANENT	123	Apr 22, 2011	0	N/A
N/A	0200	MEANS OF EGRESS	2-PERMANENT	123	Apr 22, 2011	0	ADA ramp for the stage is blocked with misc. items
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	2-PERMANENT	123B	Apr 22, 2011	0	N/A
N/A	0399	PROTECTION OTHER	6-PERMANENT	006	Apr 22, 2011	3	Egress hallway has paper artwork hanging throughout. this hallway is designed for emergency egress and should not have combustable items in it.
N/A	0399	PROTECTION OTHER	7-PERMANENT	700	Apr 22, 2011	3	Hallway is a egress hallway and should not contain combustable items same as building 6.
N/A	NVO	No violations noted this date	8-PERMANENT	800	Apr 22, 2011	0	N/A
N/A	0211	BLOCKED/LOCKED EXITS	9-PERMANENT	003	Apr 22, 2011	0	Emergency exit blocked with furniture
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	90-RELOCATABLE	521	Apr 22, 2011	0	N/A
N/A	0899	UTILITIES OTHER	7-PERMANENT	703	May 4, 2011	0	Accessory lighting shall not be used. Accessary lighting bulbs found making direct contact with top of cabinet
Statements acknowledged							
I hereby certify that the district has complied with section 1013.12(1)(b), F.S.							Yes
I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.							Yes
I hereby certify that the required fire drills have been completed as of this inspection date.							Yes
Or Acknowledgement N/A.							No
Primary inspector:	Danny Yeager						
Additional inspector:	N/A						

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

WILKINSON ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: J L WILKINSON ELEMENTARY
 Address: 4965 COUNTY ROAD 218
 Inspection Date: November 1, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipat Complian Date
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	109	Feb 1, 201
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	2-PERMANENT	234	Feb 1, 201
N/A	0199	GENERAL REQUIREMENTS	3-PERMANENT	313	Feb 1, 201
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	36	Feb 1, 201
1017.5.1.1.1	0211	BLOCKED/LOCKED EXITS	91- RELOCATABLE	40	Nov 1, 20

N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	45	Feb 1, 201
N/A	0299	MEANS OF EGRESS OTHER	91-RELOCATABLE	50	Feb 1, 201
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	32	Feb 1, 201
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	16	Feb 1, 201
1017.5.1.1.1	0211	BLOCKED/LOCKED EXITS	91-RELOCATABLE	3	Jan 3, 201

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.


Primary inspector: Karen Golish

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

KEYSTONE HEIGHTS ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - HEIGHTS ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District:	Clay
School:	KEYSTONE HEIGHTS ELEMENTARY
Address:	335 S PECAN STREET
Inspection Date:	March 15, 2011
Note:	N/A
Inspectors present	
State: No	District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0407	FACP INDICTAES TROUBLE CONDITION	2-PERMANENT	234A	Mar 31, 2011
N/A	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	2-PERMANENT	1	Mar 31, 2011
N/A	UNK	UNKNOWN CODE VIOLATION	2-PERMANENT	1	Mar 31, 2011
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	3-PERMANENT	1	Mar 31, 2011
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	9-PERMANENT	923	Mar 31, 2011
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	9-PERMANENT	914	Mar 31, 2011

N/A	0204	EMERG LIGHTS NOT OPERATIONAL	10-PERMANENT	20M	Mar 31, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	12-PERMANENT	15G	Mar 31, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	771	Mar 31, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	772	Mar 31, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	773	Mar 31, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	770	Mar 31, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	705A	Mar 31, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	718	Mar 31, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	713	Mar 31, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92-RELOCATABLE	717	Mar 31, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	92-RELOCATABLE	721	Mar 31, 2011

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.


Primary inspector: Silver Ware

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

LAKE ASBURY ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: LAKE ASBURY ELEMENTARY
 Address: 2901 SANDRIDGE ROAD
 Inspection Date: March 7, 2011
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipa Complia Date
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	1-PERMANENT	114	Mar 7, 20
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	116	Apr 7, 20
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	2-PERMANENT	201	Apr 7, 20
N/A	0301	UNPROTECTED VERTICAL OPENING	2-PERMANENT	201	Apr 7, 20
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	2-PERMANENT	215	Apr 7, 20
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	2-PERMANENT	206	Apr 7, 20

N/A	0899	UTILITIES OTHER	2-PERMANENT	211	Apr 7, 20
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	2-PERMANENT	225	Apr 7, 20
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	3-PERMANENT	00	Apr 7, 20
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	134	Apr 7, 20
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	134	Apr 7, 20
N/A	0199	GENERAL REQUIREMENTS	1-PERMANENT	132B	Apr 7, 20
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	131	Apr 7, 20
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	138	Apr 7, 20
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	1-PERMANENT	137	Apr 7, 20
N/A	0899	UTILITIES OTHER	1-PERMANENT	137	Apr 7, 20
N/A	0209	RATED OPENINGS NOT MAINTAINED	1-PERMANENT	136to126	Apr 7, 20
N/A	0210	EXIT ACCESS NOT MAINTAINED	5-PERMANENT	501	Apr 7, 20

N/A	0210	EXIT ACCESS NOT MAINTAINED	5-PERMANENT	523	Apr 7, 20
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	6-PERMANENT	608	Apr 7, 20
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	6-PERMANENT	629	Apr 7, 20
N/A	0803	EXTENSION CORD NOT RATED FOR USE	7-PERMANENT	716	Apr 7, 20
N/A	0803	EXTENSION CORD NOT RATED FOR USE	7-PERMANENT	729	Apr 7, 20
N/A	0803	EXTENSION CORD NOT RATED FOR USE	7-PERMANENT	723	Apr 7, 20
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90-RELOCATABLE	80	Apr 7, 20
N/A	0205	EMERG LIGHTING NOT TESTED/RECS MAINT'D	90-RELOCATABLE	80	Apr 7, 20
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90-RELOCATABLE	82	Apr 7, 20
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90-RELOCATABLE	82	Apr 7, 20
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90-RELOCATABLE	87	Apr 7, 20
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	90-RELOCATABLE	88	Apr 7, 20
N/A	0804	IMPROPER USE OF	90-	88	Apr 7, 20

N/A	0899	MULTISTRIP/EXTEN CORDS UTILITIES OTHER	RELOCATABLE 90- RELOCATABLE	88	Apr 7, 20
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	90- RELOCATABLE	85	Apr 7, 20
N/A	0803	EXTENSION CORD NOT RATED FOR USE	90- RELOCATABLE	45	Apr 7, 20
N/A	0899	UTILITIES OTHER	90- RELOCATABLE	44to43	Apr 7, 20
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90- RELOCATABLE	9	Apr 7, 20
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90- RELOCATABLE	94	Apr 7, 20
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90- RELOCATABLE	94	Apr 8, 20
N/A	0010	IMMINENT HAZARD	90- RELOCATABLE	93	Apr 8, 20
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90- RELOCATABLE	91	Apr 8, 20

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or
Acknowledgement N/A.

Primary inspector: Stephen Arzie
Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

LAKESIDE ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay
School:	LAKESIDE ELEMENTARY
Address:	2752 MOODY ROAD
Inspection Date:	March 16, 2011
Note:	N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0804	IMPROPER USE OF MULTISTrip/EXTEN CORDS	2-PERMANENT	143	Apr 16, 2011
N/A	0804	IMPROPER USE OF MULTISTrip/EXTEN CORDS	2-PERMANENT	136	Apr 16, 2011
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	8-PERMANENT	815	Apr 16, 2011

N/A	0406	FIRE ALARM NOT LISTED FOR USE	2-PERMANENT	FrontOffice	Apr 16, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	91-RELOCATABLE	25	Apr 16, 2011
N/A	0899	UTILITIES OTHER	91-RELOCATABLE	22	Apr 16, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	44	Apr 16, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	42A	Apr 16, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	91-RELOCATABLE	20	Apr 16, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	19	Apr 16, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	18	Apr 16, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	91-RELOCATABLE	16	Apr 16, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	61	Apr 16, 2011

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.


Primary inspector: Jason Boree

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

MCRRAE ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: MCRAE ELEMENTARY
 Address: 6770 COUNTY ROAD 315
 Inspection Date: January 31, 2011
 Note: N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	1-PERMANENT	509	Feb 14, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	509	Feb 14, 2011
N/A	0804	IMPROPER USE OF MULTISTrip/EXTEN CORDS	1-PERMANENT	509	Feb 14, 2011
N/A	0199	GENERAL REQUIREMENTS	1-PERMANENT	59	Feb 14, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	509	Feb 14, 2011
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	1-PERMANENT	501	Feb 14, 2011
N/A	0211	BLOCKED/LOCKED EXITS	1-PERMANENT	517	Feb 14, 2011

N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	530	Feb 14, 2011
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	1-PERMANENT	625	Feb 14, 2011
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	1-PERMANENT	606	Feb 15, 2011
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	1-PERMANENT	609	Feb 15, 2011
N/A	0199	GENERAL REQUIREMENTS	91-RELOCATABLE	401	Feb 15, 2011
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	92-RELOCATABLE	403	Feb 15, 2011
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	91-RELOCATABLE	403	Feb 15, 2011
N/A	0199	GENERAL REQUIREMENTS	91-RELOCATABLE	403	Feb 15, 2011
N/A	0408	MANUAL PULL STATION MISSING/INOPERABLE	91-RELOCATABLE	408	Feb 15, 2011
N/A	0100	GENERAL REQUIREMENTS	91-RELOCATABLE	406	Feb 15, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	91-RELOCATABLE	404	Feb 15, 2011
N/A	0408	MANUAL PULL STATION MISSING/INOPERABLE	91-RELOCATABLE	801	Feb 15, 2011
N/A	0100	GENERAL REQUIREMENTS	91-RELOCATABLE	801	Feb 15, 2011
N/A	0100	GENERAL REQUIREMENTS	91-RELOCATABLE	804	Feb 15, 2011
N/A	0408	MANUAL PULL STATION MISSING/INOPERABLE	91-RELOCATABLE	804	Feb 15, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	91-RELOCATABLE	821	Feb 15, 2011
N/A	0100	GENERAL REQUIREMENTS	91-RELOCATABLE	821	Feb 15, 2011
N/A	0504	EXTINGUISHER ACCESS	91-	821	Feb 15,

		OBSTRUCTED	RELOCATABLE		2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	91-RELOCATABLE	821	Feb 15, 2011
N/A	0100	GENERAL REQUIREMENTS	91-RELOCATABLE	823	Feb 15, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	91-RELOCATABLE	825	Feb 15, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	91-RELOCATABLE	825	Feb 15, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	91-RELOCATABLE	827	Feb 15, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	91-RELOCATABLE	827	Feb 15, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	91-RELOCATABLE	842	Feb 15, 2011
N/A	0100	GENERAL REQUIREMENTS	91-RELOCATABLE	842	Feb 15, 2011
N/A	0408	MANUAL PULL STATION MISSING/INOPERABLE	91-RELOCATABLE	708	Feb 15, 2011
N/A	0100	GENERAL REQUIREMENTS	91-RELOCATABLE	708	Feb 15, 2011
N/A	0800	UTILITIES	91-RELOCATABLE	706	Feb 15, 2011
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91-RELOCATABLE	706	Feb 15, 2011
N/A	0100	GENERAL REQUIREMENTS	91-RELOCATABLE	706	Feb 15, 2011
N/A	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	91-RELOCATABLE	704	Feb 15, 2011
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	91-RELOCATABLE	704	Feb 15, 2011
N/A	0100	GENERAL REQUIREMENTS	91-RELOCATABLE	704	Feb 15, 2011
N/A	0100	GENERAL REQUIREMENTS	91-RELOCATABLE	701	Feb 15, 2011

N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	1-PERMANENT	229	Feb 15, 2011
N/A	0201	INADEQUATE EGRESS WIDTH	1-PERMANENT	215	Feb 15, 2011
N/A	0201	INADEQUATE EGRESS WIDTH	1-PERMANENT	209	Feb 15, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	129	Feb 15, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	303	Feb 15, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	303	Feb 15, 2011
N/A	0400	FIRE ALARM	1-PERMANENT	office	Feb 15, 2011

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: clu wright

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

MIDDLEBURG ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay
School:	MIDDLEBURG ELEMENTARY
Address:	3958 MAIN STREET
Inspection Date:	March 17, 2011
Note:	N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticip. Compli. Date
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	7-PERMANENT	69	Apr 17, 2011
N/A	0899	UTILITIES OTHER	7-PERMANENT	CafeteriaKitchen	Apr 17, 2011

N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	7-PERMANENT	35	Apr 17, 2011
N/A	0899	UTILITIES OTHER	7-PERMANENT	75	Apr 17, 2011
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	9-PERMANENT	113	Apr 17, 2011
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	9-PERMANENT	113	Apr 17, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	9-PERMANENT	104	Apr 17, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	39	Apr 17, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91-RELOCATABLE	36	Apr 17, 2011
N/A	0200	MEANS OF EGRESS	4-PERMANENT	17	Apr 17, 2011
N/A	0899	UTILITIES OTHER	91-RELOCATABLE	57	Apr 17, 2011

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.


Primary inspector: Jason Boree

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

MONTCLAIR ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: MONTCLAIR ELEMENTARY
 Address: 2398 MOODY ROAD
 Inspection Date: March 29, 2011
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Ant Cor Dat
N/A	0499	FIRE ALARM OTHER	1-PERMANENT	MainOffice	Apr 201
N/A	0399	PROTECTION OTHER	1-PERMANENT	106	Apr 201
N/A	0301	UNPROTECTED VERTICAL OPENING	1-PERMANENT	125A	Apr 201
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	125A	Apr 201
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	4-PERMANENT	414	Apr 201

N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	4-PERMANENT	416	Apr 201
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	4-PERMANENT	Acrossfrom433	Apr 201
N/A	0802	CIRCUITS NOT LEGIBLE/PERMANENTLY LABELED	5-PERMANENT	523	Apr 201
N/A	0899	UTILITIES OTHER	5-PERMANENT	523	Apr 201
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	5-PERMANENT	523	Apr 201
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	5-PERMANENT	endofhallway	Apr 201
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	23	Apr 201
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	28	Apr 201
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	30	Apr 201

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.


Primary inspector: Jason Boree

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

OAKLEAF VILLAGE ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: OAKLEAF VILLAGE ELEMENTARY
 Address: 410 OAKLEAF VILLAGE PARKWAY
 Inspection Date: March 16, 2011
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	709	Apr 16, 2011	0
1017.9.2.3	0204	EMERG LIGHTS NOT OPERATIONAL	0-Building N/A -- See notes	909	Apr 16, 2011	0
N/A	0299	MEANS OF EGRESS OTHER	0-Building N/A -- See notes	913	Apr 16, 2011	0
1017.5.1.1.1	0210	EXIT ACCESS NOT MAINTAINED	0-Building N/A -- See notes	914	Mar 16, 2011	0

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.



Primary inspector: Karen Golish

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

ORANGE PARK ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ORANGE PARK ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay
School:	ORANGE PARK ELEMENTARY
Address:	1401 PLAINFIELD AVENUE
Inspection Date:	May 4, 2011
Note:	N/A

Inspectors present

State: No District: Yes Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	57	May 4, 2011	0	N/A
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	2-PERMANENT	5	May 4, 2011	0	Portable fire extinguisher not hanging on bracket.
N/A	NVO	No violations noted this date	3-PERMANENT	000	May 4, 2011	0	N/A
N/A	NVO	No violations noted this date	4-PERMANENT	000	May 4, 2011	0	N/A
N/A	NVO	No violations noted this date	5-PERMANENT	000	May 4, 2011	0	N/A
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	0-Building N/A -- See notes	14	May 4, 2011	0	Building #7 room # 14 portable fire extinguisher was found on shelf not hung correctly.

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. Yes
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. Yes
 I hereby certify that the required fire drills have been completed as of this inspection date. Yes
 Or
 Acknowledgement N/A. No

Primary inspector: Danny Yeager
 Additional inspector: N/A

Powered by [eGroupWare's CSS Design](#) and the [Bureau of Economic and Business Research](#).

PLANTATION OAKS ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District:	Clay
School:	PLANTATION OAKS ELEMENTARY
Address:	4150 PLANTATION OAKS BOULEVARD
Inspection Date:	March 14, 2011
Note:	N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipate Compliance Date
N/A	0304	PENETRATION PROTECT MISSING/INADEQUATE	1- PERMANENT	712	Mar 31, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1- PERMANENT	718A	Mar 31, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1- PERMANENT	702A	Mar 31, 2011

NFPA10115.7.4.3	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1- PERMANENT	703	Mar 31, 2011
N/A	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	1- PERMANENT	211	Mar 31, 2011
N/A	0599	SPRINKLER OTHER	1- PERMANENT	518B	Mar 31, 2011
N/A	0599	SPRINKLER OTHER	1- PERMANENT	522B	Mar 31, 2011
N/A	0599	SPRINKLER OTHER	1- PERMANENT	506B	Mar 31, 2011

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.
 I hereby certify that the required fire drills have been completed as of this inspection date.
 Or


Acknowledgement N/A.

Primary inspector: Silver Ware
Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

RIDEOUT ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: RIDEOUT ELEMENTARY
 Address: 3065 APALACHICOLA BOULEVARD
 Inspection Date: December 13, 2010
 Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	344	Dec 13, 2011
N/A	0399	PROTECTION OTHER	1-PERMANENT	159	Dec 13, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	210	Dec 13, 2011

N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92- RELOCATABLE	11	Dec 13, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92- RELOCATABLE	23B	Dec 13, 2011
N/A	0405	SMOKE DETECTORS INOPERABLE/MISSING	92- RELOCATABLE	22	Dec 13, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92- RELOCATABLE	24	Dec 13, 2011
N/A	0899	UTILITIES OTHER	92- RELOCATABLE	24	Dec 13, 2011
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	25	Dec 13, 2011
N/A	0803	EXTENSION CORD NOT RATED FOR USE	25- PERMANENT	602	Dec 13, 2011

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Stephen Arzie

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

RIDGEVIEW ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires [Adobe Reader](#)

District:	Clay
School:	RIDGEVIEW ELEMENTARY
Address:	421 JEFFERSON AVENUE
Inspection Date:	March 28, 2011
Note:	all alarm and drill paper work filed accordingly copies provided.
Inspectors present	
State: No	District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticip: Compli: Date
N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	mainoffice	Mar 28, 2011
N/A	0200	MEANS OF EGRESS	0-Building N/A -- See notes	main	Mar 28, 2011
N/A	1300	OUTSIDE STRUCTURE	0-Building N/A -- See notes	watertreatmentplantarea	Mar 28, 2011

N/A

1200

OPERATING
FEATURES

0-Building
N/A -- See
notes

generator

Mar 28,
2011



Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: randy brunson

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

R.M. PATERSON ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - PATERSON ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: ROBERT M PATERSON ELEMENTARY
 Address: 5400 PINE AVENUE
 Inspection Date: March 25, 2011
 Note: Claen school very few violations noted, All Fire drill paper work and maintance on file.

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	Library	Mar 25, 2011	0
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	43	Mar 25, 2011	0
N/A	0100	GENERAL REQUIREMENTS	1- PERMANENT	56	Mar 25, 2011	0
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	47	Mar 25, 2011	0
N/A	0100	GENERAL	0-Building	519	Mar 25,	0

REQUIREMENTS

N/A -- See notes

2011

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: randy brunson

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

S. BRYAN JENNINGS ELEMENTARY SCHOOL





Jason Boree

No

State Fire Marshal - Inspection Report - S BRYAN JENNINGS ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District:	Clay
School:	S BRYAN JENNINGS ELEMENTARY
Address:	215 CORONA DRIVE
Inspection Date:	March 28, 2011
Note:	N/A

Inspectors present

State: No District: Yes Local: No


Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	7-PERMANENT	14	Apr 28, 2011	0	Surges chained together.
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	7-PERMANENT	16	Apr 28, 2011	0	Surges chained together and extention cord.
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	17	Apr 28, 2011	0	Surges chained together.
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	9-PERMANENT	21	Apr 28, 2011	0	Surges chained together.
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	9-PERMANENT	24	Apr 28, 2011	0	Surges chained together.
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	37CTechnologyRoom	Apr 28, 2011	0	Surges chained together.
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	37BNewsRoom	Apr 28, 2011	0	Surges chained together.
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	37BNewsRoom	Apr 28, 2011	0	Emerg Light out.
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	4-PERMANENT	2	Apr 28, 2011	0	Surges chained together.
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	4-PERMANENT	3	Apr 28, 2011	0	Surges chained together.
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	4-PERMANENT	4	Apr 28, 2011	0	Exten Cord in use.
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	6-PERMANENT	10	Apr 28, 2011	0	Surges chained together.

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. No
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.
 I hereby certify that the required fire drills have been completed as of this inspection date.

SHADOWLAWN ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader


District:	Clay
School:	SHADOWLAWN ELEMENTARY
Address:	2945 County Road 218
Inspection Date:	February 23, 2011
Note:	N/A

Inspectors present

State: No District: Yes Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date
N/A	0402	SYSTEM NEEDS INSPECTION	1-PERMANENT	406	Mar 1, 2011
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	1-PERMANENT	811	Mar 1, 2011
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	1-PERMANENT	413	Mar 1, 2011
N/A	0304	PENETRATION PROTECT MISSING/INADEQUATE	1-PERMANENT	413	Mar 1, 2011

N/A 0899 UTILITIES OTHER 1-PERMANENT 301A Mar 1, 2011



N/A 0210 EXIT ACCESS NOT MAINTAINED 92-RELOCATABLE 902 Mar 1, 2011

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.
 I hereby certify that the required fire drills have been completed as of this inspection date.
 Or
 Acknowledgement N/A.

Primary inspector: Stephen Arzie
 Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

SWIMMING PEN CREEK ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - CREEK ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: SWIMMING PEN CREEK ELEMENTARY
 Address: 1630 WOODPECKER LANE
 Inspection Date: March 29, 2011
 Note: School continues to work on issues from last year. All Fire alarm and Frie drill paper work on file.

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited
N/A	0100	GENERAL REQUIREMENTS	1-PERMANENT	Gym626	Mar 29, 2011	0

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.
 I hereby certify that the required fire drills have been completed as of this inspection date.
 Or
 Acknowledgement N/A.

Primary inspector: randy brunson
 Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

THUNDERBOLT ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District: Clay
 School: THUNDERBOLT ELEMENTARY
 Address: 2020 THUNDERBOLT ROAD
 Inspection Date: March 28, 2011
 Note: All paper work on file, alarm checks and Fire drill's. copies provided. I have listed several rooms that had storage and wall coverage issues. The staff at this school has worked hard over the last 4 years to try and meet the requirements.

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	212	Mar 28, 2011	1	Storage above sprinkler heads
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	312	Mar 28, 2011	1	Storage above sprinkler heads
N/A	0100	GENERAL REQUIREMENTS	0-Building N/A -- See notes	120	Mar 28, 2011	1	Over 20% paper production on wall

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: randy brunson

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

TYNNE'S ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY


PDF version is recommended for printing and requires [Adobe Reader](#)

District: Clay
 School: TYNES ELEMENTARY
 Address: 1550 TYNES BOULEVARD
 Inspection Date: March 2, 2011
 Note: N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipat Complian Date
N/A	0407	FACP INDICTAES TROUBLE CONDITION	1-PERMANENT	102	Mar 31, 2011
N/A	0411	HORN/STROBE DEVICE INADEQUATE/INOPERABLE	1-PERMANENT	102	Mar 31, 2011
N/A	0599	SPRINKLER OTHER	2-PERMANENT	203	Mar 31, 2011
N/A	0304	PENETRATION PROTECT MISSING/INADEQUATE	1-PERMANENT	216	Mar 31, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	149	Mar 31, 2011



N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	151	Mar 31, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	3-PERMANENT	327	Mar 31, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	3-PERMANENT	324	Mar 31, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	3-PERMANENT	328	Mar 31, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	3-PERMANENT	336	Mar 31, 2011
N/A	0304	PENETRATION PROTECT MISSING/INADEQUATE	3-PERMANENT	341	Mar 31, 2011
N/A	0210	EXIT ACCESS NOT MAINTAINED	4-PERMANENT	400	Mar 31, 2011

N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	5-PERMANENT	529	Mar 31, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	22	Mar 31, 2011
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-RELOCATABLE	29	Mar 31, 2011
N/A	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	92-RELOCATABLE	29	Mar 31, 2011
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-RELOCATABLE	29	Mar 31, 2011
N/A	0211	BLOCKED/LOCKED EXITS	92-RELOCATABLE	1	Mar 31, 2011

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or
Acknowledgement N/A.

Primary inspector: Silver Ware
Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.

Item	Description	Inspector	Date	Notes
1	Fire Drill	Silver Ware	4/13/11	Completed
2	Fire Drill	Silver Ware	4/13/11	Completed
3	Fire Drill	Silver Ware	4/13/11	Completed
4	Fire Drill	Silver Ware	4/13/11	Completed
5	Fire Drill	Silver Ware	4/13/11	Completed
6	Fire Drill	Silver Ware	4/13/11	Completed
7	Fire Drill	Silver Ware	4/13/11	Completed
8	Fire Drill	Silver Ware	4/13/11	Completed
9	Fire Drill	Silver Ware	4/13/11	Completed
10	Fire Drill	Silver Ware	4/13/11	Completed

W.E. CHERRY ELEMENTARY SCHOOL





State Fire Marshal - Inspection Report - ELEMENTARY

PDF version is recommended for printing and requires Adobe Reader

District:	Clay
School:	W E CHERRY ELEMENTARY
Address:	420 EDSON DRIVE
Inspection Date:	March 28, 2011
Note:	N/A
Inspectors present	
State: No	District: Yes Local: No

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	C
N/A	0804	IMPROPER USE OF MULTISTrip/EXTEN CORDS	3-PERMANENT	55	Apr 28, 2011	0
N/A	0301	UNPROTECTED VERTICAL OPENING	3-PERMANENT	55	Apr 28, 2011	0
N/A	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	91-RELOCATABLE	32	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91-RELOCATABLE	56	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91-RELOCATABLE	57	Apr 28, 2011	0

N/A	0899	UTILITIES OTHER	91- RELOCATABLE	58	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	59	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	65	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	64	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	63	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	62	Apr 28, 2011	0
N/A	0204	EMERG LIGHTS NOT OPERATIONAL	91- RELOCATABLE	61	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	61	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91-	66	Apr 28,	0

			RELOCATABLE		2011	
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	67	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	68	Apr 28, 2011	0
N/A	0899	UTILITIES OTHER	91- RELOCATABLE	69	Apr 28, 2011	0

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary inspector: Jason Boree

Additional inspector: N/A

Powered by eGroupWare's CSS Design and the Bureau of Economic and Business Research.