

# FISCAL YEAR 2007-2008

## FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES

### FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY #: 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: OCTOBER 25, 2007

*[Signature]*  
INSPECTOR'S SIGNATURE

10-25-07  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	3	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	8	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	11	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
92	13	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	21	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	23	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	24	CEILING LIGHTS OUT		X						NFPA 70 401
92	24	EMERGENCY LIGHTS OUT		X						FBC 423.17.1
92	27	EMERGENCY LIGHTS OUT		X						FBC 423.17.1
92	27	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	32	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	34	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	41	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	42	FIRE ALARM BOX DANGLING FROM CEILING ON BAY SIDE		X						NFPA 70 110.26