

Elementary Schools

State Fire Marshal - Inspection Report

District - Clay

School - ARGYLE ELEMENTARY

Address - 2625 SPENCER PLANTATION BOULEVARD

Inspection date - 2006-09-29

Notes -

Inspectors present

State No **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes	
0303	INADEQUATE FIRE RESISTANCE	1-PERMANENT	114	2006-10-10	0	treat flag used as drape or remove, also drapes/curtains through out school multiple rooms
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	104	2006-10-03	0	discontinue powerstrip into powerstrip
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	1-PERMANENT	115	2006-10-03	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	2-PERMANENT	206	2006-10-03	0	discontinue use of extension cord can replace with powerstrip
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	205	2006-10-03	0	discontinue extension cord into powerstrip/ discontinue use of improper extension cord
0803	EXTENSION CORD NOT RATED FOR USE	2-PERMANENT	219	2006-10-03	0	discontinue use of extension cord can use powerstrip
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	3-PERMANENT	317	2006-10-10	0	discontinue powerstrip into extension cord/ discontinue use of extension cord
0301	UNPROTECTED VERTICAL OPENING	3-PERMANENT	311	2006-10-03	0	cap or seal 4" conduit in ceiling, no wiring just open
0199	GENERAL REQUIREMENTS	4-PERMANENT	408	2006-10-03	0	reduce wall covering to less than 25% not counting bullentin/white boards
0199	GENERAL REQUIREMENTS	4-PERMANENT	432	2006-10-10	0	reduce wall covering to less than 25% not counting bullentin/white boards
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	4-PERMANENT	424	2006-10-10	0	discontinue extension cord into powersrtip/ discontinue use of extension cord
1205	FIRE EVACUATION PLAN(S) NOT POSTED	4-PERMANENT	433	2006-10-10	0	post correct plan by exit
0300	PROTECTION	4-PERMANENT	437	2006-10-10	0	seal horizontal opening in wall chase for pipes
0399	PROTECTION OTHER	5-PERMANENT	500	2006-10-10	0	remove paper apple tree from hallway, treat picture drape between classrooms
0506	EXTINGUISHER MISSING FROM LOCATION	6-PERMANENT	630	2006-10-10	0	need fire extinguisher and properly mount same
0199	GENERAL REQUIREMENTS	6-PERMANENT	603	2006-10-10	0	reduce wall covering to less than 25% not counting bullentin/white boards
0304	PENETRATION PROTECT MISSING/INADEQUATE	0-Building N/A -- See	92702	2006-12-08	0	Portables not listed on form replace missing ceiling tile

		notes				
0199	GENERAL REQUIREMENTS	0-Building N/A -- See notes	92701	2006-12-08	0	reduce wall coverage to less than 25% portables not listed
0199	GENERAL REQUIREMENTS	0-Building N/A -- See notes	92703	2006-12-08	0	reduce wall coverage to less than 25% portables not listed
0299	MEANS OF EGRESS OTHER	0-Building N/A -- See notes	92705	2006-12-08	0	need emergency exit sign
0010	IMMINENT HAZARD	0-Building N/A -- See notes	92705	2006-12-08	0	reduce wall coverage to less than 25% portables not listed
0299	MEANS OF EGRESS OTHER	0-Building N/A -- See notes	92710	2006-11-26	0	need emergency exit sign
0299	MEANS OF EGRESS OTHER	0-Building N/A -- See notes	92714	2006-12-08	0	need concrete poured at steps
1205	FIRE EVACUATION PLAN(S) NOT POSTED	0-Building N/A -- See notes	92802	2006-12-08	0	N/A
0299	MEANS OF EGRESS OTHER	0-Building N/A -- See notes	92902	2006-12-08	0	uncover door window
0299	MEANS OF EGRESS OTHER	0-Building N/A -- See notes	92904	2006-11-26	0	uncover door window
0200	MEANS OF EGRESS	0-Building N/A -- See notes	92905	2006-11-26	0	also violation 504 move desk away for exit and extinguisher
1205	FIRE EVACUATION PLAN(S) NOT POSTED	0-Building N/A -- See notes	92906	2006-12-08	0	N/A
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	0-Building N/A -- See notes	92908	2006-12-08	0	clear area around electric panel
1205	FIRE EVACUATION PLAN(S) NOT POSTED	0-Building N/A -- See notes	92908	2006-11-26	1	N/A
1205	FIRE EVACUATION PLAN(S) NOT POSTED	0-Building N/A -- See notes	92910	2006-12-08	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Michael, Swartz

Additional inspector

N/, A

State Fire Marshal - Inspection Report

District - Clay

School - CHARLES E BENNETT ELEMENTARY

Address - 1 S OAKRIDGE AVENUE

Inspection date - 2007-01-23

Notes -

Inspectors present

State No **District No** **Local** **Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	BoysGirlsRestrooms	2007-01-23 0	Emergency lighting does not work in power off mode.
0204	EMERG LIGHTS NOT OPERATIONAL	3-PERMANENT	BoysGirlsRestrooms	2007-01-23 0	Bulb out in boys restroom. Lights do not work in power off mode.
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	10-PERMANENT	Kitchen	2007-01-23 0	Class K extinguisher missing required signage. Also needs to be service. It reads overcharged.
0303	INADEQUATE FIRE RESISTANCE	10-PERMANENT	Stage	2007-01-23 0	"temporary" curtains do not meet code. They are not fire rated and must be taken down.
0301	UNPROTECTED VERTICAL OPENING	11-PERMANENT	114	2007-01-23 0	Replace ceiling tiles that are missing to protect vertical openings.
0203	EXIT LIGHTS INOPERABLE EMERGENCY MODE	92-PORTABLE	605	2007-01-23 0	Illuminated exit signs at each door failed to operate in emergency mode.

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)


Acknowledgement N/A. **No**

Primary inspector

Kevin, Mobley

Additional inspector

N/, A



State Fire Marshal - Inspection Report - CLAY HILL ELEMENTARY

District: Clay
School: CLAY HILL ELEMENTARY
Address: 6345 STATE ROAD 218
Inspection Date: November 16, 2006
Note: N/A

Inspectors present

State: No District: Yes Local: No

Reference	Code Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0899 UTILITIES OTHER	1-PERMANENT	106	October 17, 2006	1	expoused electrical wire

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S.

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S.


I hereby certify that the required fire drills have been completed as of this inspection date.

Or

Acknowledgement N/A.

Primary Inspector: Karen Golish

Additional inspector: N/A



State Fire Marshal - Inspection Report - GROVE PARK ELEMENTARY

District: Clay
 School: GROVE PARK ELEMENTARY
 Address: 1643 MILLER STREET
 Inspection Date: January 10, 2006
 Note: N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0399	PROTECTION OTHER	8-PERMANENT	144a	March 26, 2006	0	holes in the drywall
N/A	0899	UTILITIES OTHER	6-PERMANENT	600	March 26, 2006	0	outlet inserts
N/A	0899	UTILITIES OTHER	7-PERMANENT	700	March 26, 2006	0	outlet inserts
N/A	0299	MEANS OF EGRESS OTHER	2-PERMANENT	129a	March 26, 2006	0	hand rails too low
N/A	0299	MEANS OF EGRESS OTHER	92-PORTABLE	504	February 26, 2006	0	no exit plan
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	528	February 26, 2006	0	N/A
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91-PORTABLE	525	February 26, 2006	0	N/A
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	92-PORTABLE	521	February 26, 2006	0	missing blank in elect panel
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	92-PORTABLE	28	February 26, 2006	0	blank in electric panel
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	6	February 26, 2006	0	N/A
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	10	February 26, 2006	0	N/A

State Fire Marshal - Inspection Report - GROVE PARK ELEMENTARY

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. No
I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. Yes

I hereby certify that the required fire drills have been completed as of this inspection date. Yes

Or
Acknowledgement N/A. No

Primary Inspector: Scott Baltes

Additional inspector: N/A

State Fire Marshal - Inspection Report

District - Clay

School - DOCTORS INLET ELEMENTARY

Address - 2634 STATE ROAD 220

Inspection date - 2006-10-11

Notes -

Inspectors present

State No **District No** **Local** Yes

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	4-PERMANENT	1	2006-10-11	3	Building Number not on building
0803	EXTENSION CORD NOT RATED FOR USE	4-PERMANENT	118	2006-10-11	0	corrected
0901	IMPROPER STORAGE	4-PERMANENT	121	2006-10-11	0	around water heater
0901	IMPROPER STORAGE	4-PERMANENT	106	2006-10-11	0	Blocking asile
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	4-PERMANENT	109	2006-10-11	2	To high
0304	PENETRATION PROTECT MISSING/INADEQUATE	4-PERMANENT	105B	2006-10-11	3	Missing ceiling tile
0211	BLOCKED/LOCKED EXITS	5-PERMANENT	106	2006-10-11	0	Comming off the stage
0301	UNPROTECTED VERTICAL OPENING	5-PERMANENT	100	2006-10-11	0	N/A
0304	PENETRATION PROTECT MISSING/INADEQUATE	5-PERMANENT	104	2006-10-11	0	N/A
0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	5-PERMANENT	104	2006-10-11	0	N/A
0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	5-PERMANENT	110	2006-10-11	3	N/A
1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	5-PERMANENT	110	2006-10-11	3	No room number
0901	IMPROPER STORAGE	5-PERMANENT	110	2006-10-11	3	Electrical room, remove storage and freon bottle
0204	EMERG LIGHTS NOT OPERATIONAL	5-PERMANENT	110	2006-10-11	0	N/A
0304	PENETRATION PROTECT MISSING/INADEQUATE	5-PERMANENT	110	2006-10-11	3	Ceiling tiles
1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	5-PERMANENT	1	2006-10-11	3	No Building number on building
1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	9-PERMANENT	1	2006-10-11	3	No Building number on building
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	9-PERMANENT	901	2006-10-11	0	Storage to high
	ACCUMULATION OF	9-		2006-		

0106	COMBUSTIBLE MATERIALS	PERMANENT	903B	10-11	0	Storage to high
0901	IMPROPER STORAGE	9- PERMANENT	911	2006- 10-11	0	Kilm room
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	9- PERMANENT	906B	2006- 10-11	0	Storage blocking asile
0901	IMPROPER STORAGE	9- PERMANENT	915	2006- 10-11	0	Paint and storage
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	8- PERMANENT	803B	2006- 10-11	0	clear asile, remove storage
0499	FIRE ALARM OTHER	8- PERMANENT	803	2006- 10-11	0	Pull Station Blocked
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	8- PERMANENT	807B	2006- 10-11	0	Remove storage blocking asile
0211	BLOCKED/LOCKED EXITS	8- PERMANENT	807	2006- 10-11	0	N/A
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	8- PERMANENT	808B	2006- 10-11	0	Remove storage in asile
0901	IMPROPER STORAGE	8- PERMANENT	815	2006- 10-11	0	N/A
0499	FIRE ALARM OTHER	8- PERMANENT	802	2006- 10-11	0	Pull station Blocked
1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	8- PERMANENT	1	2006- 10-11	3	No building number on building
1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	7- PERMANENT	1	2006- 10-11	3	No Building number on building
1205	FIRE EVACUATION PLAN(S) NOT POSTED	7- PERMANENT	701	2006- 10-11	0	N/A
1205	FIRE EVACUATION PLAN(S) NOT POSTED	7- PERMANENT	703	2006- 10-11	0	N/A
0901	IMPROPER STORAGE	7- PERMANENT	714B	2006- 10-11	0	Electric room
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	7- PERMANENT	705	2006- 10-11	0	Remove canopy in room not fire rated
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	7- PERMANENT	707B	2006- 10-11	2	Clean out store room unble to enter
0901	IMPROPER STORAGE	7- PERMANENT	716	2006- 10-11	0	N/A
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	7- PERMANENT	704B	2006- 10-11	0	Clear asile space
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	7- PERMANENT	702B	2006- 10-11	0	Clear asile space
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	892	2006- 10-11	0	N/A
0504	EXTINGUISHER ACCESS OBSTRUCTED	92- PORTABLE	896	2006- 10-11	0	N/A
0211	BLOCKED/LOCKED EXITS	92- PORTABLE	896	2006- 10-11	0	N/A
0499	FIRE ALARM OTHER	92- PORTABLE	898	2006- 10-11	0	Blocked pull station
0504	EXTINGUISHER ACCESS OBSTRUCTED	92- PORTABLE	898	2006- 10-11	0	N/A
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	8- PERMANENT	899	2006- 10-11	0	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	920	2006- 10-11	0	To high less than 5'
0803	EXTENSION CORD NOT RATED FOR USE	92- PORTABLE	921	2006- 10-11	0	N/A
	INADEQUATE ACCESS TO	92-		2006-		

0801	ELECTRICAL PANEL	PORTABLE	876	10-11	0	N/A
0499	FIRE ALARM OTHER	92- PORTABLE	876	2006- 10-11	0	Blocked Pull station
0504	EXTINGUISHER ACCESS OBSTRUCTED	92- PORTABLE	873	2006- 10-11	0	N/A
1205	FIRE EVACUATION PLAN(S) NOT POSTED	92- PORTABLE	870	2006- 10-11	0	N/A
0299	MEANS OF EGRESS OTHER	92- PORTABLE	870	2006- 10-11	0	Door sticking and door knob not working properly
0504	EXTINGUISHER ACCESS OBSTRUCTED	92- PORTABLE	870	2006- 10-11	0	N/A
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	92- PORTABLE	869	2006- 10-11	0	Storage in closet and clear aisle
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	836	2006- 10-11	0	N/A
0504	EXTINGUISHER ACCESS OBSTRUCTED	92- PORTABLE	836	2006- 10-11	0	N/A
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	837	2006- 10-11	0	N/A
0504	EXTINGUISHER ACCESS OBSTRUCTED	92- PORTABLE	837	2006- 10-11	0	N/A
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	838	2006- 10-11	0	N/A
0504	EXTINGUISHER ACCESS OBSTRUCTED	92- PORTABLE	838	2006- 10-11	0	N/A
0299	MEANS OF EGRESS OTHER	92- PORTABLE	839	2006- 10-11	0	Exit door knob problem
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	839	2006- 10-11	0	N/A
0211	BLOCKED/LOCKED EXITS	92- PORTABLE	840	2006- 10-11	0	Corrected
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	841B	2006- 10-11	0	Corrected
0211	BLOCKED/LOCKED EXITS	92- PORTABLE	843	2006- 10-11	0	N/A
0504	EXTINGUISHER ACCESS OBSTRUCTED	92- PORTABLE	843	2006- 10-11	0	N/A
0499	FIRE ALARM OTHER	92- PORTABLE	843	2006- 10-11	0	Blocked Pull station
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	845	2006- 10-11	0	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	845	2006- 10-11	0	To high
0299	MEANS OF EGRESS OTHER	92- PORTABLE	845	2006- 10-11	0	Exit door sticking
0499	FIRE ALARM OTHER	92- PORTABLE	846	2006- 10-11	0	Blocked pull station
0803	EXTENSION CORD NOT RATED FOR USE	92- PORTABLE	847	2006- 10-11	0	N/A
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	848	2006- 10-11	0	N/A
0504	EXTINGUISHER ACCESS OBSTRUCTED	92- PORTABLE	848	2006- 10-11	0	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	848	2006- 10-11	0	N/A
1205	FIRE EVACUATION PLAN(S) NOT POSTED	92- PORTABLE	848	2006- 10-11	0	N/A
	INADEQUATE ACCESS TO	92-		2006-		

0801 ELECTRICAL PANEL	PORTABLE	849	10-11	0	N/A
0499 FIRE ALARM OTHER	92- PORTABLE	849	2006- 10-11	0	Blocked pull station

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Philip, Crider

Additional inspector

N/, A

State Fire Marshal - Inspection Report

District - Clay

School - FLEMING ISLAND ELEMENTARY

Address - 4425 LAKESHORE DRIVE

Inspection date - ~~2007~~
2020-03-20

Notes - fire drills in the county wide system are not monthly

Inspectors present

State No **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
	0399 PROTECTION OTHER	2-PERMANENT	204	2007-04-03	1	remove all door stops on self closing doors
	0399 PROTECTION OTHER	1-PERMANENT	all	2007-04-03	1	remove all door stops on self closing doors
	0204 EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	133	2007-04-03	0	there are no emergency lights in the hall it is considered windowless and the chair was a trip hazard with not lights
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	402	2007-04-03	0	N/A
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	407	2007-04-03	0	N/A
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	423	2007-04-03	0	also need inserts for pre k and k
	0211 BLOCKED/LOCKED EXITS	92-PORTABLE	801	2007-04-03	0	rear exit blocked
	0211 BLOCKED/LOCKED EXITS	92-PORTABLE	824	2007-04-03	0	rear exit blocked
	0211 BLOCKED/LOCKED EXITS	92-PORTABLE	826	2007-04-03	0	rear exit blocked
	0801 INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	841	2007-04-03	0	N/A
	0204 EMERG LIGHTS NOT OPERATIONAL	92-PORTABLE	860	2007-04-03	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)


Acknowledgement N/A. **No**

Primary inspector

Scott, Baltes

Additional inspector

N/, A



State Fire Marshal - Inspection Report - GROVE PARK ELEMENTARY

District: Clay
 School: GROVE PARK ELEMENTARY
 Address: 1643 MILLER STREET
 Inspection Date: January 10, 2006
 Note: N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0399	PROTECTION OTHER	8-PERMANENT	144a	March 26, 2006	0	holes in the drywall
N/A	0899	UTILITIES OTHER	6-PERMANENT	600	March 26, 2006	0	outlet inserts
N/A	0899	UTILITIES OTHER	7-PERMANENT	700	March 26, 2006	0	outlet inserts
N/A	0299	MEANS OF EGRESS OTHER	2-PERMANENT	129a	March 26, 2006	0	hand rails too low
N/A	0299	MEANS OF EGRESS OTHER	92-PORTABLE	504	February 26, 2006	0	no exit plan
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	528	February 26, 2006	0	N/A
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91-PORTABLE	525	February 26, 2006	0	N/A
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	92-PORTABLE	521	February 26, 2006	0	missing blank in elect panel
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	92-PORTABLE	28	February 26, 2006	0	blank in electric panel
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	6	February 26, 2006	0	N/A
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	10	February 26, 2006	0	N/A

State Fire Marshal - Inspection Report - GROVE PARK ELEMENTARY

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. No
I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. Yes

I hereby certify that the required fire drills have been completed as of this inspection date. Yes
Or No
Acknowledgement N/A.

Primary Inspector: Scott Baltus
Additional inspector: N/A

State Fire Marshal - Inspection Report

District - Clay

School - KEYSTONE HEIGHTS ELEMENTARY

Address - 335 S PECAN STREET

Inspection date - 2006-11-03

Notes -

Inspectors present

State No **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	9-PERMANENT	924	2006-11-30	1	N/A
0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	1-PERMANENT	14	2006-11-30	1	N/A
0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	2-PERMANENT	214	2006-11-30	1	N/A
0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	3-PERMANENT	33	2006-11-30	1	N/A
0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	4-PERMANENT	26B	2006-11-30	1	N/A
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	1-PERMANENT	1	2006-11-30	1	blocked by ref
0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	7-PERMANENT	43	2006-11-30	1	N/A
0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	9-PERMANENT	913	2006-11-30	1	N/A
0411	HORN/STROBE DEVICE INADEQUATE/INOPERABLE	92-PORTABLE	772	2006-11-30	1	N/A
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	771	2006-11-30	1	in bathroom used as store room
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	770	2006-11-30	1	in bathroom used as store room
1301	FIRE LANES NOT POSTED/MAINTAINED	92-PORTABLE	1	2006-11-30	1	on Orchid Ave
0411	HORN/STROBE DEVICE INADEQUATE/INOPERABLE	92-PORTABLE	724	2006-11-30	1	N/A
0411	HORN/STROBE DEVICE INADEQUATE/INOPERABLE	92-PORTABLE	710	2006-11-30	1	N/A
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	713	2006-11-30	1	N/A
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	717	2006-11-30	1	N/A
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	718	2006-11-30	1	N/A
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	719	2006-11-30	1	N/A
	FACP INDICTAES TROUBLE	1-		2006-		

0407 CONDITION

PERMANENT 1

11-30

1

N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Silver, Ware

Additional inspector

N/, A



State Fire Marshal - Inspection Report:

District - Clay

School - LAKE ASBURY ELEMENTARY

Address - 2901 SANDRIDGE ROAD

Inspection date - 2007-01-16

Notes -

Inspectors present

State No **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cite#	Notes
0204	EMERG LIGHTS NOT OPERATIONAL	92-PORTABLE	10	2007-02-16	1	N/A
0704	COMPRESSED GAS CYLINDERS NOT SECURED	92-PORTABLE	13	2007-02-16	1	N/A
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92-PORTABLE	14	2007-02-16	1	N/A
0299	MEANS OF EGRESS OTHER	92-PORTABLE	14	2007-02-16	1	N/A
0211	BLOCKED/LOCKED EXITS	92-PORTABLE	15	2007-01-16	1	Corrected Date of Inspection
0204	EMERG LIGHTS NOT OPERATIONAL	92-PORTABLE	39A	2007-02-16	1	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	92-PORTABLE	40	2007-02-16	1	N/A
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92-PORTABLE	78	2007-02-16	1	N/A
0506	EXTINGUISHER MISSING FROM LOCATION	92-PORTABLE	80	2007-02-16	1	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92-PORTABLE	84	2007-02-16	1	N/A
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92-PORTABLE	89	2007-02-16	1	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92-PORTABLE	96	2007-02-16	1	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92-PORTABLE	97	2007-02-16	1	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector
Karen, Golish

Additional inspector
N/, A

State Fire Marshal - Inspection Report**District** - Clay**School** - LAKESIDE ELEMENTARY**Address** - 2752 MOODY ROAD**Inspection date** - 2007-01-05**Notes** -**Inspectors present****State No** **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	127	2007-01-05	0	N/A
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	2-PERMANENT	126	2007-01-05	0	Remove storage around water heater
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	2-PERMANENT	121	2007-01-05	0	Remove storage around water heater
0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	120	2007-01-05	0	N/A
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	1-PERMANENT	111	2007-01-05	0	Out of date
0304	PENETRATION PROTECT MISSING/INADEQUATE	1-PERMANENT	111	2007-01-05	0	Ceiling tile missing
0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	107	2007-01-05	0	N/A
0210	EXIT ACCESS NOT MAINTAINED	1-PERMANENT	105	2007-01-05	0	N/A
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	103	2007-01-05	0	To High
0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	109	2007-01-05	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	109	2007-01-05	0	N/A
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	6-PERMANENT	601B	2007-01-05	0	To High
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	6-PERMANENT	603B	2007-01-05	0	To High and clear the floor area
0704	COMPRESSED GAS CYLINDERS NOT SECURED	6-PERMANENT	613	2007-01-05	0	N/A
0405	SMOKE DETECTORS INOPERABLE/MISSING	6-PERMANENT	613	2007-01-05	0	Hanging from ceiling
0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	6-PERMANENT	612	2007-01-05	0	N/A
1205	FIRE EVACUATION PLAN(S) NOT POSTED	6-PERMANENT	602	2007-01-05	0	N/A
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	7-PERMANENT	701B	2007-01-05	0	Storage to high
		7-		2007-		

0210	EXIT ACCESS NOT MAINTAINED	PERMANENT	701	01-05	0	Door covered with a large paper
0211	BLOCKED/LOCKED EXITS	7- PERMANENT	703	2007- 01-05	0	N/A
0304	PENETRATION PROTECT MISSING/INADEQUATE	7- PERMANENT	714	2007- 01-05	0	Missing ceiling tile
0304	PENETRATION PROTECT MISSING/INADEQUATE	7- PERMANENT	716	2007- 01-05	0	Missing ceiling tile
0304	PENETRATION PROTECT MISSING/INADEQUATE	8- PERMANENT	812	2007- 01-05	0	Missing ceiling tile
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	8- PERMANENT	801B	2007- 01-05	0	Clear floor area
0803	EXTENSION CORD NOT RATED FOR USE	8- PERMANENT	803	2007- 01-05	0	N/A
0210	EXIT ACCESS NOT MAINTAINED	8- PERMANENT	805	2007- 01-05	0	Latch on door sticking
0210	EXIT ACCESS NOT MAINTAINED	8- PERMANENT	808	2007- 01-05	0	Carpet tripping hazard
1205	FIRE EVACUATION PLAN(S) NOT POSTED	8- PERMANENT	806	2007- 01-05	0	N/A
1205	FIRE EVACUATION PLAN(S) NOT POSTED	8- PERMANENT	802	2007- 01-05	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	4- PERMANENT	146	2007- 01-05	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	4- PERMANENT	147	2007- 01-05	0	N/A
NVO	No violations noted this date	6- PERMANENT	1	2007- 01-05	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	5- PERMANENT	148	2007- 01-05	0	N/A
1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	31- PERMANENT	1	2007- 01-05	0	N/A
1205	FIRE EVACUATION PLAN(S) NOT POSTED	92- PORTABLE	47	2007- 01-05	0	N/A
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	46	2007- 01-05	0	N/A
0899	UTILITIES OTHER	92- PORTABLE	43	2007- 01-05	0	Unable to open electric panel
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92- PORTABLE	20	2007- 01-05	0	Surge into a surge
0211	BLOCKED/LOCKED EXITS	92- PORTABLE	22	2007- 01-05	0	N/A
1205	FIRE EVACUATION PLAN(S) NOT POSTED	92- PORTABLE	22	2007- 01-05	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	92- PORTABLE	24	2007- 01-05	0	N/A
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	26	2007- 01-05	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	92- PORTABLE	25	2007- 01-05	0	Came on then flashed for a minute before stopping
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	23	2007- 01-05	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	92- PORTABLE	23	2007- 01-05	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	92- PORTABLE	18	2007- 01-05	0	N/A
0408	MANUAL PULL STATION MISSING/INOPERABLE	92- PORTABLE	16	2007- 01-05	0	Blocked
	INADEQUATE ACCESS TO	92-		2007-		

	0801	ELECTRICAL PANEL	PORTABLE	16	01-05	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	92-PORTABLE	12A	2007-01-05	0	Remove storage and large amount of foam
	0210	EXIT ACCESS NOT MAINTAINED	92-PORTABLE	12	2007-01-05	0	Door sticks on bottom
	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	6-PERMANENT	1	2007-01-05	0	6 inch
	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	7-PERMANENT	1	2007-01-05	0	6 inch
	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	8-PERMANENT	1	2007-01-05	0	6 inch
101-15.7.2	1201	FIRE DRILLS NOT BEING CONDUCTED	1-PERMANENT	100	2007-01-11	1	Fire drills not being conduct on a monthly basis.

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **Yes**

Primary inspector

Philip, Crider

Additional inspector

N/, A

State Fire Marshal - Inspection Report**District** - Clay**School** - MCRAE ELEMENTARY**Address** - 6770 COUNTY ROAD 315**Inspection date** - 2006-11-06**Notes****Inspectors present****State No** **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	1-PERMANENT	1	2006-12-01	1	N/A
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	119	2006-12-01	1	N/A
0504	EXTINGUISHER ACCESS OBSTRUCTED	2-PERMANENT	218	2006-12-01	1	Blocked by open door
0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	2-PERMANENT	229	2006-12-01	1	N/A
0511	SPRINK HEAD WRENCH MISSING OR WRONG TYPE	2-PERMANENT	203	2006-12-01	1	N/A
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	5-PERMANENT	530	2006-12-01	1	N/A
0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	5-PERMANENT	537	2006-12-01	1	N/A
0809	OPEN ELECTRICAL JUNCTION BOX	92-PORTABLE	706	2006-12-01	1	Juction Box extetior not secured
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	708	2006-12-01	1	Bathroom used as store room
0204	EMERG LIGHTS NOT OPERATIONAL	92-PORTABLE	824	2006-12-01	1	N/A
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	825	2006-12-01	1	Bathrooms used as store room
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	804	2006-12-01	1	bathroom used as store room
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	803	2006-12-01	1	bathroom used as store room
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	802	2006-12-01	1	bathroom used as store room
0405	SMOKE DETECTORS INOPERABLE/MISSING	92-PORTABLE	801	2006-12-01	1	bathroom used as store room
0499	FIRE ALARM OTHER	92-PORTABLE	404	2006-12-01	1	pull station blocked by book shelf

Statements acknowledgedI hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**I hereby certify that the local authority having jurisdiction has complied with **No**

section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of this inspection date.

Yes

(Or)

Acknowledgement N/A.

No

Primary inspector

Silver, Ware

Additional inspector

N/, A

State Fire Marshal - Inspection Report**District** - Clay**School** - MIDDLEBURG ELEMENTARY**Address** - 3958 MAIN STREET**Inspection date** - 2006-12-11**Notes** -**Inspectors present****State No** **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
0809	OPEN ELECTRICAL JUNCTION BOX	1-PERMANENT	4	2006-12-11	0	AT A/C
0211	BLOCKED/LOCKED EXITS	1-PERMANENT	13	2006-12-11	0	N/A
0202	EXIT LIGHTS INOPERABLE NORMAL MODE	2-PERMANENT	3	2006-12-11	0	N/A
NVO	No violations noted this date	3-PERMANENT	1	2006-12-11	0	N/A
0301	UNPROTECTED VERTICAL OPENING	2-PERMANENT	4	2006-12-11	0	tile pushed up
0204	EMERG LIGHTS NOT OPERATIONAL	2-PERMANENT	4	2006-12-11	0	No emergency lighting
NVO	No violations noted this date	4-PERMANENT	1	2006-12-11	0	N/A
0600	SPECIAL PROVISIONS	7-PERMANENT	51	2006-12-11	4	Remove the Flammable storage sign.
0407	FACP INDICTAES TROUBLE CONDITION	7-PERMANENT	55	2006-12-11	0	N/A
0202	EXIT LIGHTS INOPERABLE NORMAL MODE	7-PERMANENT	5	2006-12-11	0	N/A
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	7-PERMANENT	68	2006-12-11	0	Multi plug adapter
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	7-PERMANENT	62	2006-12-11	0	There is a new Wet Chemical Ext. that was installed with out was service inspection.
0211	BLOCKED/LOCKED EXITS	7-PERMANENT	73	2006-12-11	0	Mantaince advised onsite.
0202	EXIT LIGHTS INOPERABLE NORMAL MODE	7-PERMANENT	37	2006-12-11	0	N/A
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	7-PERMANENT	38	2006-12-11	0	Orange multi plug adapter.
0210	EXIT ACCESS NOT MAINTAINED	2-PERMANENT	3	2006-12-11	0	The door has been blocked off. This access is still showing on fish map as a egress.
0202	EXIT LIGHTS INOPERABLE NORMAL MODE	9-PERMANENT	101	2006-12-11	3	Two exit signs at enter section are out.
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	9-PERMANENT	104	2006-12-11	2	N/A
	UNPROTECTED VERTICAL	9-		2006-		

0301	OPENING	PERMANENT	106	12-11	0	tile push up.
0202	EXIT LIGHTS INOPERABLE NORMAL MODE	9- PERMANENT	114	2006- 12-11	0	N/A
0303	INADEQUATE FIRE RESISTANCE	9- PERMANENT	117	2006- 12-11	0	Media back drop not fire rated.
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	90- PORTABLE	24	2006- 12-11	0	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90- PORTABLE	23	2006- 12-11	0	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90- PORTABLE	38	2006- 12-11	0	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90- PORTABLE	35	2006- 12-11	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	90- PORTABLE	35	2006- 12-11	0	N/A
0408	MANUAL PULL STATION MISSING/INOPERABLE	90- PORTABLE	64	2006- 12-11	0	Pull station is blocked
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	90- PORTABLE	64	2006- 12-11	0	Orange extention cord.
0299	MEANS OF EGRESS OTHER	90- PORTABLE	64	2006- 12-11	2	There is no Fish number posted.
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	90- PORTABLE	69	2006- 12-11	0	Pin is pulled and unit is not mounted.
0212	AREA OF REFUGE NOT MAINTAINED	90- PORTABLE	69A	2006- 12-11	0	Boxes to ceiling.
0803	EXTENSION CORD NOT RATED FOR USE	90- PORTABLE	69A	2006- 12-11	0	Orange extention cord
0105	VACANT BUILDING NOT SECURED	0-Building N/A -- See notes	1	2006- 12-11	3	The old water treatment system has unlocked gates as well a unlocked out buildings. Gate is marked Restricted area and building marked Chlorine.
1399	OUTSIDE STRUCTURE OTHER	90- PORTABLE	new	2007- 01-05	0	Portable not anchored on all four sides.
0401	ALRAM LOG NOT MAINT/PRESENT	7- PERMANENT	office	2007- 01-05	0	Unable to check record due to responsible being out of office.
0408	MANUAL PULL STATION MISSING/INOPERABLE	2- PERMANENT	1	2007- 01-05	0	The pull station at rear door needs service. Face plate is not secure.
0513	FIRE PUMP NEEDS INSPECT/TEST/MAINT	12- PERMANENT	12	2007- 01-05	0	Unable to check fire pump. Know one on site has a key to open the door.

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Stephen, Arzie

Additional inspector

N/, A

State Fire Marshal - Inspection Report

District - Clay

School - MONTCLAIR ELEMENTARY

Address - 2398 MOODY ROAD

Inspection date - 2007-05-08

Notes

Inspectors present

State No **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
	0899 UTILITIES OTHER	0- Building N/A -- See notes	1000	2007-06-04	1	Fire hydrant needs to be turned.

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Horace, Earls

Additional inspector

N/A

State Fire Marshal - Inspection Report**District** - Clay**School** - ORANGE PARK ELEMENTARY**Address** - 1401 PLAINFIELD AVENUE**Inspection date** - 2007-04-03**Notes** -**Inspectors present****State No** **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
0299	MEANS OF EGRESS OTHER	1- PERMANENT	1	2007- 04-03	0	door stops on auto closing doors
0210	EXIT ACCESS NOT MAINTAINED	4- PERMANENT	all	2007- 04-03	3	all rooms only have 1 exit
0211	BLOCKED/LOCKED EXITS	4- PERMANENT	all	2007- 04-03	3	all rooms only have 1 exit
0299	MEANS OF EGRESS OTHER	5- PERMANENT	all	2007- 04-03	0	exit signs missing sliding glass doors are not exits
0204	EMERG LIGHTS NOT OPERATIONAL	5- PERMANENT	court	2007- 04-03	0	no emergency lighting in the court room
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	5- PERMANENT	courtroom	2007- 04-03	0	to many combustibles
0203	EXIT LIGHTS INOPERABLE EMERGENCY MODE	3- PERMANENT	hall	2007- 04-03	0	the exit in the hall way to the left of the stag is improperly marked
0803	EXTENSION CORD NOT RATED FOR USE	92- PORTABLE	37	2007- 04-03	0	remove white extinction cord
0210	EXIT ACCESS NOT MAINTAINED	92- PORTABLE	36	2007- 04-03	0	too many obstrustions the fire alarm fire extinguisher in not accessible
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92- PORTABLE	50	2007- 04-03	0	multi plugs is prohibited
0200	MEANS OF EGRESS	92- PORTABLE	51	2007- 04-03	0	no exit signs
0200	MEANS OF EGRESS	92- PORTABLE	22	2007- 04-03	0	no exit signs
0210	EXIT ACCESS NOT MAINTAINED	92- PORTABLE	52	2007- 04-03	0	rear exit blocked
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92- PORTABLE	44	2007- 04-03	0	inspection tage broken :Green tag
0199	GENERAL REQUIREMENTS	92- PORTABLE	43	2007- 04-03	0	curtains are not fire rated
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92- PORTABLE	39	2007- 04-03	0	green inspection tag broken
0211	BLOCKED/LOCKED EXITS	92- PORTABLE	40	2007- 04-03	0	the rear exit is missing the steps and the door is nailed shut with no signage stating exit closed
0809	OPEN ELECTRICAL JUNCTION BOX	92- PORTABLE	45and54	2007- 04-03	0	blanks in electric panel. maintains fixed while we were there

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Scott, Baltes

Additional inspector

N/, A

State Fire Marshal - Inspection Report

District - Clay

School - ORANGE PARK ELEMENTARY

Address - 1401 PLAINFIELD AVENUE

Inspection date - 2007-04-03

Notes -

Inspectors present

State No **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
-----	----------------	------	------	-----------	-------------

No data present

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Scott, Baltes

Additional inspector

N/, A

State Fire Marshal - Inspection Report**District** - Clay**School** - ROBERT M PATERSON ELEMENTARY**Address** - 5400 PINE AVENUE**Inspection date** - 2007-01-08**Notes** -**Inspectors present****State No** **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	6-PERMANENT	606	2007-02-08	0	too many combustibles in stoarage room
0304	PENETRATION PROTECT MISSING/INADEQUATE	6-PERMANENT	610	2007-01-08	0	missing ceiling in storage room
0204	EMERG LIGHTS NOT OPERATIONAL	92-PORTABLE	16	2007-01-08	0	N/A
1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	5-PERMANENT	524	2007-01-08	0	N/A
1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	5-PERMANENT	503	2007-01-08	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	4-PERMANENT	412	2007-01-08	0	N/A
1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	4-PERMANENT	413	2007-01-08	0	N/A
1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	4-PERMANENT	406	2007-01-08	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	92-PORTABLE	21	2007-01-08	0	N/A
0010	IMMINENT HAZARD	92-PORTABLE	26	2007-01-08	0	remove door hasp
0204	EMERG LIGHTS NOT OPERATIONAL	92-PORTABLE	51	2007-01-08	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	92-PORTABLE	52	2007-01-08	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	92-PORTABLE	50	2007-01-08	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	92-PORTABLE	48	2007-01-08	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	92-PORTABLE	48	2007-01-08	0	N/A
0202	EXIT LIGHTS INOPERABLE NORMAL MODE	92-PORTABLE	45	2007-01-08	0	N/A
0202	EXIT LIGHTS INOPERABLE NORMAL MODE	92-PORTABLE	44	2007-01-08	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	92-PORTABLE	41	2007-01-08	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Scott, Baltes

Additional inspector

N/, A

State Fire Marshal - Inspection Report**District** - Clay**School** - RIDEOUT ELEMENTARY**Address** - 3065 APALACHICOLA BOULEVARD**Inspection date** - 2007-03-16**Notes** -**Inspectors present****State No** **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	311	2007-03-16	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	312	2007-03-16	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	307	2007-03-16	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	302	2007-03-16	0	N/A
1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-PERMANENT	336	2007-03-16	0	N/A
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	1-PERMANENT	206	2007-03-16	0	N/A
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	237	2007-03-16	0	N/A
0100	GENERAL REQUIREMENTS	1-PERMANENT	235	2007-03-16	0	Tables blocking access to stage
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	234	2007-03-16	0	No storage in wheel chair lift to stage
0199	GENERAL REQUIREMENTS	1-PERMANENT	126	2007-03-16	0	Clear asile space
0304	PENETRATION PROTECT MISSING/INADEQUATE	1-PERMANENT	136	2007-03-16	0	N/A
0504	EXTINGUSIHER ACCESS OBSTRUCTED	1-PERMANENT	125	2007-03-16	0	N/A
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	119	2007-03-16	0	Floor area
0210	EXIT ACCESS NOT MAINTAINED	1-PERMANENT	159	2007-03-16	0	Door sticking
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	150	2007-03-16	0	Clear floor
0803	EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	104	2007-03-16	0	N/A
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	405	2007-03-16	0	Storage Floor and to high
0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	449	2007-03-16	0	Clear floor
	ACCUMULATION OF	1-		2007-		

	0106	COMBUSTIBLE MATERIALS	PERMANENT	447	03-16	0	Clear floor
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	412	2007-03-16	0	Storage Clear floor and to high
	0901	IMPROPER STORAGE	1-PERMANENT	443	2007-03-16	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	439	2007-03-16	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	436	2007-03-16	0	N/A
	0304	PENETRATION PROTECT MISSING/INADEQUATE	1-PERMANENT	438	2007-03-16	0	N/A
	0304	PENETRATION PROTECT MISSING/INADEQUATE	1-PERMANENT	467	2007-03-16	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	464	2007-03-16	0	Clear floor
	0304	PENETRATION PROTECT MISSING/INADEQUATE	1-PERMANENT	430	2007-03-16	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	425	2007-03-16	0	Clear floor
	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92-PORTABLE	10	2007-03-16	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	92-PORTABLE	12	2007-03-16	0	N/A
	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	20	2007-03-16	0	N/A
	0199	GENERAL REQUIREMENTS	92-PORTABLE	22	2007-03-16	0	Time out room 1 padding on door ripped, TO-2 No light
	0210	EXIT ACCESS NOT MAINTAINED	92-PORTABLE	22	2007-03-16	0	N/A
	0210	EXIT ACCESS NOT MAINTAINED	92-PORTABLE	26	2007-03-16	0	Door very hard to open "Door Knob"
	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92-PORTABLE	28	2007-03-16	0	N/A
	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	28	2007-03-16	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	92-PORTABLE	29	2007-03-16	0	Closet
	0210	EXIT ACCESS NOT MAINTAINED	92-PORTABLE	29	2007-03-16	0	N/A
	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	25	2007-03-16	0	N/A
	0803	EXTENSION CORD NOT RATED FOR USE	92-PORTABLE	33	2007-03-16	0	N/A
	0210	EXIT ACCESS NOT MAINTAINED	92-PORTABLE	31	2007-03-16	0	Door does not open correctly hits outside hand rail before completely open
	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	43	2007-03-16	0	N/A
	0408	MANUAL PULL STATION MISSING/INOPERABLE	92-PORTABLE	43	2007-03-16	0	Blocked
	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92-PORTABLE	42	2007-03-16	0	N/A
	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	41	2007-03-16	0	N/A
101-15.2.5.4	0200	MEANS OF EGRESS	1-PERMANENT	217	2007-03-26	0	Classroom off of the stage
101-15.2.5.4	0200	MEANS OF EGRESS	1-PERMANENT	218	2007-03-26	0	Classroom in stage dressing room

Mixing in Lock downs and Tornado drills to

1201 FIRE DRILLS NOT BEING CONDUCTED

1- PERMANENT 1

2007-03-26 0

count as Fire Drills "Do Not Count". Those drills do not exit the building

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Philip, Crider

Additional inspector

N/, A

State Fire Marshal - Inspection Report

District - Clay

School - RIDGEVIEW ELEMENTARY

Address - 421 JEFFERSON AVENUE

Inspection date - 2006-12-06

Notes -

Inspectors present

State No **District No** **Local** Yes

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
	0303 INADEQUATE FIRE RESISTANCE	1-PERMANENT	106	2007-01-09	0	window shades and valences/curtains need tretating
	0303 INADEQUATE FIRE RESISTANCE	1-PERMANENT	101	2007-01-09	0	window shades and valences/curtains need treating
	0303 INADEQUATE FIRE RESISTANCE	1-PERMANENT	108	2007-01-09	0	window shades and valences/curtains need treating
	0501 FIRE EXTINGUISHER REQUIRES INSPECTION	1-PERMANENT	120	2007-01-09	0	extinguishers need servicing, several on floor
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	126	2007-01-09	0	Hay still in TV recording room left from picture taking
	0299 MEANS OF EGRESS OTHER	3-PERMANENT	308	2007-01-09	0	no evacuation plan posted
	0803 EXTENSION CORD NOT RATED FOR USE	6-PERMANENT	603	2007-01-09	0	discontinue use of extension cord replace with powerstrip
	0303 INADEQUATE FIRE RESISTANCE	92-PORTABLE	712	2007-01-09	0	remove paper curtains from windows all so treat canopy over desk or remove
	0199 GENERAL REQUIREMENTS	92-PORTABLE	712	2007-01-09	0	reduce wall coverage to less than 25%
	0502 PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92-PORTABLE	716	2007-01-09	0	mount extinguisher
	0502 PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92-PORTABLE	718	2007-01-09	0	mount extinguisher
	0199 GENERAL REQUIREMENTS	92-PORTABLE	724	2007-01-09	0	reduce wall coverage to less than 25%
	0199 GENERAL REQUIREMENTS	92-PORTABLE	733	2007-01-09	0	reduce wall coverage to less than 25%
	0303 INADEQUATE FIRE RESISTANCE	92-PORTABLE	733	2006-12-06	0	remove paper curtains
	0303 INADEQUATE FIRE RESISTANCE	92-PORTABLE	732	2007-01-09	0	window shades and valences/curtains need treating
	0803 EXTENSION CORD NOT RATED FOR USE	92-PORTABLE	732	2007-01-09	0	replace extension cord with powerstrip
	0299 MEANS OF EGRESS OTHER	92-PORTABLE	732	2007-01-09	0	need exit sign on door
	0303 INADEQUATE FIRE RESISTANCE	92-PORTABLE	730	2007-01-09	0	window shades and valences/curtains need treating
		92-		2007-		

0199	GENERAL REQUIREMENTS	PORTABLE	730	01-09	0	remove wall coverage to less than 25%
0803	EXTENSION CORD NOT RATED FOR USE	7-PERMANENT	708	2007-01-09	0	replace extension cord with powerstrip
0803	EXTENSION CORD NOT RATED FOR USE	7-PERMANENT	701	2007-01-09	0	replace extension cord with powerstrip
1399	OUTSIDE STRUCTURE OTHER	30-PERMANENT	1	2007-01-09	0	fix nails in deck and ramp leading to Bldg
0299	MEANS OF EGRESS OTHER	92-PORTABLE	741	2007-01-09	0	need emergency exit sign on door
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92-PORTABLE	742	2007-01-09	0	hang extinguisher
0803	EXTENSION CORD NOT RATED FOR USE	92-PORTABLE	743	2007-01-09	0	replace with powerstrip
0299	MEANS OF EGRESS OTHER	0-Building N/A -- See notes	772	2007-01-09	0	need emergency sign on door
0199	GENERAL REQUIREMENTS	92-PORTABLE	772	2007-01-09	0	reduce wall coverage to less than 25%
0303	INADEQUATE FIRE RESISTANCE	92-PORTABLE	772	2007-01-09	0	remove paper curtains from windows
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	91-PORTABLE	770	2007-01-09	0	mount extinguisher
0303	INADEQUATE FIRE RESISTANCE	91-PORTABLE	770	2007-01-09	0	window shades and valences/curtains need treating
0803	EXTENSION CORD NOT RATED FOR USE	92-PORTABLE	745	2007-01-09	0	replace with powerstrip
0504	EXTINGUISHER ACCESS OBSTRUCTED	92-PORTABLE	748	2007-01-09	0	clear area around extinguisher
0199	GENERAL REQUIREMENTS	92-PORTABLE	748	2007-01-09	0	reduce wall coverage to less than 25%
0803	EXTENSION CORD NOT RATED FOR USE	92-PORTABLE	750	2007-01-09	0	Replace using cart code with powerstrip to operate microwave
0199	GENERAL REQUIREMENTS	91-PORTABLE	778	2007-01-09	0	general housekeeping
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	752	2007-01-09	0	discontinue powerstrip into powerstrip must be plugged in to seperate outlets
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	751	2007-01-09	0	replace extension cord to overhead with powerstrip
0199	GENERAL REQUIREMENTS	92-PORTABLE	754	2007-01-09	0	reduce wall coverage to less than 25%
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92-PORTABLE	755	2007-01-09	0	N/A
0506	EXTINGUISHER MISSING FROM LOCATION	92-PORTABLE	759	2007-01-09	0	get and mount extinguisher
0506	EXTINGUISHER MISSING FROM LOCATION	92-PORTABLE	783	2007-01-09	0	get and mount extinguisher
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	784	2007-01-09	0	replace extension cord to coffe maker with powerstrip
1400	CONSTRUCTION/RENOVATION	92-PORTABLE	785	2007-01-09	0	guttled being remodeled
0303	INADEQUATE FIRE RESISTANCE	92-PORTABLE	786	2007-01-09	0	window shades and valences/curtains need treating
0899	UTILITIES OTHER	92-PORTABLE	786	2007-01-09	0	home made power cord to TV have replaced by electrician
0210	EXIT ACCESS NOT MAINTAINED	0-Building N/A -- See notes	1	2007-01-02	0	need to concrete in front of new ramps to multiple portables not safe for handicap or samll children

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Michael, Swartz

Additional inspector

N/, A

State Fire Marshal - Inspection Report**District** - Clay**School** - S BRYAN JENNINGS ELEMENTARY**Address** - 215 CORONA DRIVE**Inspection date** - 2006-12-07**Notes** -**Inspectors present****State No** **District No** **Local Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes	
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	5-PERMANENT	8	2007-01-02	0	discontinue use of extension cords (2) replace with powerstrip
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	5-PERMANENT	5	2007-01-02	0	discontinue use of extension cord replace with powerstrip
0303	INADEQUATE FIRE RESISTANCE	6-PERMANENT	11	2007-01-02	0	treat curtains/valences or remove
0211	BLOCKED/LOCKED EXITS	6-PERMANENT	12E	2007-01-02	0	move cabinet by door
0211	BLOCKED/LOCKED EXITS	1-PERMANENT	35C	2007-01-02	0	move tables from path to door
0211	BLOCKED/LOCKED EXITS	1-PERMANENT	35D	2007-01-02	0	move trash can from doorway
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	31H	2007-01-02	0	discontinue use of adapter in electrical outlet
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	34C	2007-01-02	0	discontinue extension cord going to fridge do not use extension cord and powerstrip together
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	1-PERMANENT	33A	2007-01-02	0	mount extinguisher on wall
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	2-PERMANENT	37A	2007-01-02	0	discontinue powerstrip into powerstrip each must plug directly into wall
0211	BLOCKED/LOCKED EXITS	8-PERMANENT	18B	2007-01-02	0	clear access to door
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	8-PERMANENT	17A	2007-01-02	0	discontinue use of extension cord, orange going to TV also green at front of room
0211	BLOCKED/LOCKED EXITS	8-PERMANENT	20E	2007-01-02	0	clear access around door
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	9-PERMANENT	24A	2007-01-02	0	discontinue powerstrips into powerstrips each one must be plugged directly into wall
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	10-PERMANENT	1	2007-01-02	0	mount extinguisher on wall
0299	MEANS OF EGRESS OTHER	92-PORTABLE	80A	2007-01-02	0	evacuation plan needed
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	81	2007-01-02	0	discontinue powerstrip into powerstrip each must be plugged directly into wall
	EXTINGUISHER ACCESS	92-		2007-		

0504	OBSTRUCTED	PORTABLE	78	01-02	0	move cabinet away from extinguisher
0303	INADEQUATE FIRE RESISTANCE	92-PORTABLE	78	2007-01-02	0	treat or remove curtains/valences
0299	MEANS OF EGRESS OTHER	92-PORTABLE	75	2007-01-02	0	handrail at rear exit broken
0211	BLOCKED/LOCKED EXITS	92-PORTABLE	26	2007-01-02	0	clear access to emergency exit
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	26	2007-01-02	0	discontinue extension cord use powerstrip must be plugged directly into wall
0504	EXTINGUISHER ACCESS OBSTRUCTED	92-PORTABLE	27	2007-01-02	0	clear access to extinguisher or remount it
0299	MEANS OF EGRESS OTHER	92-PORTABLE	30	2007-01-02	0	uncover and keep visible emergency exit signs
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	29	2007-01-02	0	discontinue extension cord use , behind desk
0211	BLOCKED/LOCKED EXITS	92-PORTABLE	37	2007-01-02	0	clear access to exit
0504	EXTINGUISHER ACCESS OBSTRUCTED	92-PORTABLE	37	2007-01-02	0	clear access to extinguisher or relocate
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	34	2007-01-02	0	discontinue extension cord use
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	91-PORTABLE	6	2007-01-02	0	mount extinguisher on wall
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	43	2007-01-02	0	discontinue powerstrip into extension cord must be plugged directly into wall
0506	EXTINGUISHER MISSING FROM LOCATION	92-PORTABLE	44	2007-01-02	0	N/A
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	45	2007-01-02	0	discontinue extension cord use
0211	BLOCKED/LOCKED EXITS	92-PORTABLE	50	2007-01-02	0	clear access to exit
0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	93-PORTABLE	76	2007-01-02	0	need faceplate on outlet by TV
0303	INADEQUATE FIRE RESISTANCE	93-PORTABLE	76	2007-01-02	0	treat or remove curtains/valences in all rooms

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Michael, Swartz

Additional inspector

N/, A

State Fire Marshal - Inspection Report

District - Clay

School - SWIMMING PEN CREEK ELEMENTARY

Address - 1630 WOODPECKER LANE

Inspection date - 2006-10-23

Notes -

Inspectors present

State No **District No** **Local** Yes

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
	1308 BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	1-PERMANENT	1	2006-10-23	1	N/A
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	117	2006-10-23	0	Storage on floor
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	1-PERMANENT	113	2006-10-23	0	Storage to high
	0803 EXTENSION CORD NOT RATED FOR USE	1-PERMANENT	114	2006-10-23	0	N/A
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	2-PERMANENT	207	2006-10-23	0	Storage to high and asile blocked with storage
15.2.5.4	0299 MEANS OF EGRESS OTHER	2-PERMANENT	203	2006-10-23	0	Used as classroom no second exit. 15.2.5.4 and 69A-58.008 sect.1h
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	2-PERMANENT	210	2006-10-23	0	Clear floor area
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	2-PERMANENT	227	2006-10-23	0	To high
	0802 CIRCUITS NOT LEGIBLE/PERMANENTLY LABELED	2-PERMANENT	228	2006-10-23	0	Panel 2LN mislabeled
	0901 IMPROPER STORAGE	2-PERMANENT	230	2006-10-23	0	Remove paint
	1308 BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	2-PERMANENT	1	2006-10-23	1	N/A
	1308 BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	3-PERMANENT	1	2006-10-23	1	N/A
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	3-PERMANENT	307	2006-10-23	0	Storage to high
	0803 EXTENSION CORD NOT RATED FOR USE	3-PERMANENT	308	2006-10-23	0	N/A
	0106 ACCUMULATION OF COMBUSTIBLE MATERIALS	3-PERMANENT	316	2006-10-23	0	Storage to high
	0803 EXTENSION CORD NOT RATED FOR USE	3-PERMANENT	301	2006-10-23	0	N/A
	0802 CIRCUITS NOT LEGIBLE/PERMANENTLY LABELED	3-PERMANENT	318	2006-10-23	0	Panel 3LN #43 - 62
	0808 IMPROPER STORAGE IN ELECT/MECH ROOMS	3-PERMANENT	319	2006-10-23	0	N/A
	BLDG ADDRESS/I.D. NOT	4-		2006-		

	1308	PRESENT/VISIBLE	PERMANENT	1	10-23	1	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	404	2006-10-23	0	Storage
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	405	2006-10-23	0	Storage to high and clear asile
	0807	MISSING/BROKEN RECEPTACLE/FACEPLATE	4-PERMANENT	418	2006-10-23	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	421	2006-10-23	0	Storage clear asile
15.2.5.4	0299	MEANS OF EGRESS OTHER	4-PERMANENT	433	2006-10-23	0	No second Exit. 15.2.5.4 and 69A-58.008 sect. 1h
	0408	MANUAL PULL STATION MISSING/INOPERABLE	4-PERMANENT	433	2006-10-23	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	429	2006-10-23	0	Clear floor space
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	4-PERMANENT	412	2006-10-23	0	Clear floor space
	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	5-PERMANENT	1	2006-10-23	1	N/A
	0803	EXTENSION CORD NOT RATED FOR USE	5-PERMANENT	502	2006-10-23	0	N/A
	1205	FIRE EVACUATION PLAN(S) NOT POSTED	5-PERMANENT	502	2006-10-23	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	5-PERMANENT	505	2006-10-23	0	Storage to high
15.2.5.4	0299	MEANS OF EGRESS OTHER	5-PERMANENT	533	2006-10-23	0	No second Exit. 15.2.5.4 and 69A-58.008 sect. 1h
	0408	MANUAL PULL STATION MISSING/INOPERABLE	5-PERMANENT	533	2006-10-23	0	N/A
	0899	UTILITIES OTHER	5-PERMANENT	538	2006-10-23	0	Panel 5LN breaker 60 pops off, Not labeled properly
	0504	EXTINGUISHER ACCESS OBSTRUCTED	5-PERMANENT	532	2006-10-23	0	Corrected
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	5-PERMANENT	529	2006-10-23	0	Storage to high and clear floor area
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	5-PERMANENT	528	2006-10-23	0	Storage to high
	0504	EXTINGUISHER ACCESS OBSTRUCTED	5-PERMANENT	526	2006-10-23	0	Corrected
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	5-PERMANENT	526	2006-10-23	0	Remove Bat Cave in classroom made of plastic bags. Corrected
	0504	EXTINGUISHER ACCESS OBSTRUCTED	5-PERMANENT	516	2006-10-23	0	Corrected
	0504	EXTINGUISHER ACCESS OBSTRUCTED	5-PERMANENT	510	2006-10-23	0	Corrected
	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	6-PERMANENT	1	2006-10-23	1	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	6-PERMANENT	628	2006-10-23	0	Storage to high
15.2.5.4	0299	MEANS OF EGRESS OTHER	6-PERMANENT	627	2006-10-23	0	No second Exit. 15.2.5.4 and 69A-58.008 sect. 1h
	0408	MANUAL PULL STATION MISSING/INOPERABLE	6-PERMANENT	627	2006-10-23	0	N/A
	1205	FIRE EVACUATION PLAN(S) NOT POSTED	6-PERMANENT	627	2006-10-23	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	6-PERMANENT	614	2006-10-23	0	Storage clear floor space
		ACCUMULATION OF	6-		2006-		

	0106	COMBUSTIBLE MATERIALS	PERMANENT	606	10-23	0	Storage clear floor area
	0504	EXTINGUISHER ACCESS OBSTRUCTED	6- PERMANENT	603	2006-10-23	0	Corrected
	0802	CIRCUITS NOT LEGIBLE/PERMANENTLY LABELED	6- PERMANENT	632	2006-10-23	0	Panel 6LN 43 - 68
	0809	OPEN ELECTRICAL JUNCTION BOX	92- PORTABLE	702	2006-10-23	1	On all Portables all outside boxes not secure. they are not locked.
	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	704	2006-10-23	0	N/A
	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	706	2006-10-23	0	N/A
15.2.5.4	0299	MEANS OF EGRESS OTHER	92- PORTABLE	707	2006-10-23	0	Exit door will not open
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	92- PORTABLE	705	2006-10-23	0	Storage room
	0204	EMERG LIGHTS NOT OPERATIONAL	92- PORTABLE	703	2006-10-23	0	N/A
	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	701	2006-10-23	0	N/A
	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	804	2006-10-23	0	To high
	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	806	2006-10-23	0	N/A
	0106	ACCUMULATION OF COMBUSTIBLE MATERIALS	92- PORTABLE	808	2006-10-23	0	Storage room floor
	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	92- PORTABLE	810	2006-10-23	0	N/A
	0501	FIRE EXTINGUISHER REQUIRES INSPECTION	92- PORTABLE	809	2006-10-23	0	Pin pulled
	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	807	2006-10-23	0	on Floor
	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	805	2006-10-23	0	N/A
	0499	FIRE ALARM OTHER	92- PORTABLE	805	2006-10-23	0	Pull station Blocked
	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	803	2006-10-23	0	N/A
	0304	PENETRATION PROTECT MISSING/INADEQUATE	92- PORTABLE	803	2006-10-23	0	Missing Ceiling tile
	0204	EMERG LIGHTS NOT OPERATIONAL	92- PORTABLE	801	2006-10-23	0	Falling off the wall
	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	21- PERMANENT	1	2006-10-23	0	N/A
	1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	25- PERMANENT	1	2006-10-23	0	N/A
	0899	UTILITIES OTHER	4- PERMANENT	430	2006-10-23	0	Panel 4LN Breaker #54 pops off

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**
 I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Philip, Crider

Additional inspector

N/, A

State Fire Marshal - Inspection Report**District** - Clay**School** - THUNDERBOLT ELEMENTARY**Address** - 2020 THUNDERBOLT ROAD**Inspection date** - ~~2005~~ 10-18**Notes** - 2006**Inspectors present****State No** **District No** **Local** **Yes**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
0409	RELOCATE AUDIBLE TROUBLE INDICATOR	1-PERMANENT	207	2006-12-18	0	N/A
0209	RATED OPENINGS NOT MAINTAINED	1-PERMANENT	100	2006-12-18	1	door stops on fire/ smoke doors
0899	UTILITIES OTHER	1-PERMANENT	102	2006-12-18	1	outlet protectors in all kendergartens
0899	UTILITIES OTHER	1-PERMANENT	103111	2006-12-18	1	outlet protectors
0809	OPEN ELECTRICAL JUNCTION BOX	1-PERMANENT	126	2006-12-18	0	panel hnb
0204	EMERG LIGHTS NOT OPERATIONAL	1-PERMANENT	124	2006-12-18	0	N/A
1101	COMBUSTIBLE MATERIAL IMPROPERLY STORED	1-PERMANENT	261a	2006-12-18	0	cumbustibles under stairs
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	91-PORTABLE	740	2006-12-18	0	N/A

Statements acknowledgedI hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No****Primary inspector**

Scott, Baltes

Additional inspector

N/, A

State Fire Marshal - Inspection Report**District** - Clay**School** - TYNES ELEMENTARY**Address** - 1550 TYNES BOULEVARD**Inspection date** - 2007-03-26**Notes** -**Inspectors present****State Yes** **District No** **Local No**

Ref	Code Violation	Bldg	Room	Comp date		Cited Notes
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	2-PERMANENT	232	2007-03-26	0	N/A
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	3-PERMANENT	301	2007-03-26	0	N/A
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	3-PERMANENT	315	2007-03-26	0	N/A
0809	OPEN ELECTRICAL JUNCTION BOX	3-PERMANENT	341	2007-03-26	0	Box on upper wall between listed numser door and entery door.
0504	EXTINGUSIHER ACCESS OBSTRUCTED	4-PERMANENT	414	2007-03-26	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	5-PERMANENT	511	2007-03-26	2	White cord to TV
0803	EXTENSION CORD NOT RATED FOR USE	5-PERMANENT	527	2007-03-26	0	White extension cord.
0209	RATED OPENINGS NOT MAINTAINED	1-PERMANENT	115	2007-03-26	0	Two doors open
0204	EMERG LIGHTS NOT OPERATIONAL	91-PORTABLE	8	2007-03-26	0	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	91-PORTABLE	22	2007-03-26	0	N/A
0204	EMERG LIGHTS NOT OPERATIONAL	91-PORTABLE	25	2007-03-26	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	91-PORTABLE	26	2007-03-26	0	Orange
0202	EXIT LIGHTS INOPERABLE NORMAL MODE	91-PORTABLE	43	2007-03-26	0	N/A
0803	EXTENSION CORD NOT RATED FOR USE	91-PORTABLE	43	2007-03-26	0	Green To Fridge.
0210	EXIT ACCESS NOT MAINTAINED	91-PORTABLE	68	2007-03-26	0	Rear exit not maintained.
1202	DANGEROUS CONDITION EXISTS	91-PORTABLE	67	2007-03-26	0	Rear wondows covered with black paper.
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	91-PORTABLE	67	2007-03-26	0	N/A
0408	MANUAL PULL STATION MISSING/INOPERABLE	91-PORTABLE	66	2007-03-26	2	Missing glass bar.
		91-		2007-		

0899	UTILITIES OTHER	PORTABLE	28	03-26	0	Door closer broken.
0411	HORN/STROBE DEVICE INADEQUATE/INOPERABLE	91- PORTABLE	28	2007- 03-26	0	Strobe falling off wall.
0809	OPEN ELECTRICAL JUNCTION BOX	91- PORTABLE	28	2007- 03-26	0	Box door is broken.
0501	FIRE EXTINGUISHER REQUIRES INSPECTION	91- PORTABLE	29	2007- 03-26	0	Pin pulled.
0499	FIRE ALARM OTHER	91- PORTABLE	27	2007- 03-26	0	Pull station is blocked.
1399	OUTSIDE STRUCTURE OTHER	91- PORTABLE	25	2007- 03-26	0	Rear exit steps has nails sticking up and a poor amount of anti skid.
1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	91- PORTABLE	000	2007- 03-26	2	The new style portables have fish number on rear exit doors only.
0299	MEANS OF EGRESS OTHER	91- PORTABLE	000	2007- 03-26	2	All new portables do not have fish numbers on inter. rooms.
0405	SMOKE DETECTORS INOPERABLE/MISSING	91- PORTABLE	000	2007- 03-26	2	New portables have no smoke detectors in inter. rooms.

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **Yes**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Stephen, Arzie

Additional inspector

N/, A

State Fire Marshal - Inspection Report**District** - Clay**School** - W E CHERRY ELEMENTARY**Address** - 420 EDSON DRIVE**Inspection date** - 2006-09-26**Notes** -**Inspectors present****State No** **District No** **Local** Yes

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	1-PERMANENT	3	2006-10-10	0	get correct mount or change extinguisher so it can be mounted on wall
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	1-PERMANENT	4	2006-10-10	1	mount extinguisher
0303	INADEQUATE FIRE RESISTANCE	1-PERMANENT	7	2006-10-10	0	either trat or remove curtains
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	3-PERMANENT	55	2006-10-03	0	discontinue powerstrip into powerstrip at computers
0304	PENETRATION PROTECT MISSING/INADEQUATE	3-PERMANENT	55A	2006-10-10	1	replace missing ceiling tile
0803	EXTENSION CORD NOT RATED FOR USE	3-PERMANENT	55A	2006-10-10	0	discontinue use of extension cord
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	3-PERMANENT	55C	2006-10-10	1	discontinue powerstrip into powestrip TV production
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	3-PERMANENT	55B	2006-10-10	1	N/A
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	4-PERMANENT	20	2006-10-10	0	N/A
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	4-PERMANENT	20	2006-10-10	0	discontinue powerstrip into powestrip
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	4-PERMANENT	21	2006-10-10	0	discontinue powerstrip into powestrip
0199	GENERAL REQUIREMENTS	4-PERMANENT	21	2006-10-10	0	reduce wall covering to less than 25% not counting bullentin/white boards
0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	4-PERMANENT	59	2006-10-10	0	N/A
0304	PENETRATION PROTECT MISSING/INADEQUATE	4-PERMANENT	12A	2006-10-10	0	replace missing ceiling tile
0803	EXTENSION CORD NOT RATED FOR USE	4-PERMANENT	12	2006-10-10	0	discontinue use of extension cord (white residential)
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92-PORTABLE	36	2006-10-10	0	discontinue powerstrip into powestrip
0504	EXTINGUSIHER ACCESS OBSTRUCTED	92-PORTABLE	36	2006-10-10	0	clear area around extinguisher
0199	GENERAL REQUIREMENTS	92-PORTABLE	40	2006-10-10	1	reduce wall covering to less than 25% not counting bullentin/white boards
	PORTABLE EXTINGUISHER	92-		2006-		

0502	IMPROPERLY MOUNTED	PORTABLE	41	10-10	0	N/A
0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	92- PORTABLE	41	2006- 10-10	0	discontinue powerstrip into powestrip
1400	CONSTRUCTION/RENOVATION	92- PORTABLE	38	2006- 10-03	0	being converted to computer lab no students in room
0299	MEANS OF EGRESS OTHER	92- PORTABLE	42	2006- 10-10	0	need emergency exit sign in second room
1205	FIRE EVACUATION PLAN(S) NOT POSTED	92- PORTABLE	42	2006- 10-10	0	in second room
0299	MEANS OF EGRESS OTHER	92- PORTABLE	43	2006- 10-10	1	emergency exit sign needed on door
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	34	2006- 10-10	0	mounted to high over 5', lower to within limits
1205	FIRE EVACUATION PLAN(S) NOT POSTED	92- PORTABLE	34	2006- 10-10	0	mount by door
1400	CONSTRUCTION/RENOVATION	92- PORTABLE	34	2006- 10-06	0	second exit not available for use new concrete access being done
1400	CONSTRUCTION/RENOVATION	92- PORTABLE	33	2006- 10-06	0	second exit not available for use new concrete access being placed
0199	GENERAL REQUIREMENTS	92- PORTABLE	51	2006- 10-10	0	reduce wall covering to less than 25% not counting bulletin/white boards
0303	INADEQUATE FIRE RESISTANCE	92- PORTABLE	51	2006- 10-10	0	either treat or remove curtains
0303	INADEQUATE FIRE RESISTANCE	92- PORTABLE	32	2006- 10-10	0	either treat or remove valence
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	50	2006- 10-10	0	place second screw in holder so extinguisher can be mounted
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	54B	2006- 10-10	0	N/A
1400	CONSTRUCTION/RENOVATION	92- PORTABLE	50	2006- 10-06	0	only one exit new sidewalks being poured at back door
1400	CONSTRUCTION/RENOVATION	92- PORTABLE	51	2006- 10-06	0	only one exit new sidewalk being poured at back door
0504	EXTINGUISHER ACCESS OBSTRUCTED	92- PORTABLE	58	2006- 10-10	0	clear area around extinguisher, recommend moving to other door due to set up of classroom
0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	92- PORTABLE	59	2006- 10-10	0	change out either extinguisher or bracket so extinguisher can be mounted
1400	CONSTRUCTION/RENOVATION	92- PORTABLE	60	2006- 10-10	0	not in use
0803	EXTENSION CORD NOT RATED FOR USE	92- PORTABLE	91	2006- 10-10	0	discontinue use of extension cord

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with
section 1013.12(2)(b), F.S. **Yes**

I hereby certify that the required fire drills have been completed as of this
inspection date. **Yes**

(Or)

Acknowledgement N/A. **No**

Primary inspector

Michael, Swartz

Additional inspector

N/, A



State Fire Marshal - Inspection Report - J L WILKINSON ELEMENTARY

District: Clay
 School: J L WILKINSON ELEMENTARY
 Address: 4965 COUNTY ROAD 218
 Inspection Date: November 16, 2006
 Note: N/A

Inspectors present

State: No District: No Local: Yes

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	1-PERMANENT	109	December 18, 2006	0	Need 30" clearance around Hot Water Heater
N/A	0899	UTILITIES OTHER	1-PERMANENT	109	November 16, 2006	0	Exposed Wire
N/A	0301	UNPROTECTED VERTICAL OPENING	1-PERMANENT	133	November 16, 2006	0	Missing Ceiling Tile
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	140	November 16, 2006	1	N/A
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	1-PERMANENT	125	December 18, 2006	0	N/A
N/A	0809	OPEN ELECTRICAL JUNCTION BOX	2-PERMANENT	202	December 18, 2006	0	Missing Cover for Breaker in Junction Box
N/A	0808	IMPROPER STORAGE IN ELECT/MECH ROOMS	3-PERMANENT	313	December 18, 2006	0	30" clearance needed for Hot Water Heater
N/A	0504	EXTINGUISHER ACCESS OBSTRUCTED	5-PERMANENT	515	November 16, 2006	0	N/A
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	5-PERMANENT	526	December 18, 2006	0	N/A
N/A	0502	PORTABLE EXTINGUISHER IMPROPERLY MOUNTED	4-PERMANENT	427	December 18, 2006	0	N/A
N/A	0804	IMPROPER USE OF MULTISTRIP/EXTEN CORDS	4-PERMANENT	428	November 16, 2006	0	N/A

State Fire Marshal - Inspection Report - J L WILKINSON ELEMENTARY

Reference	Code	Violation	Building	Room	Anticipated Compliance Date	Cited	Notes
N/A	0804	IMPROPER USE OF MULTISTRIPEXTEN CORDS	96-PORTABLE	18	November 16, 2006	0	N/A
N/A	0801	INADEQUATE ACCESS TO ELECTRICAL PANEL	96-PORTABLE	19	December 18, 2006	1	N/A
N/A	0804	IMPROPER USE OF MULTISTRIPEXTEN CORDS	96-PORTABLE	34	November 16, 2006	0	N/A
N/A	0804	IMPROPER USE OF MULTISTRIPEXTEN CORDS	96-PORTABLE	38	November 16, 2006	0	N/A
N/A	0211	BLOCKED/LOCKED EXITS	96-PORTABLE	42	November 16, 2006	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. No

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. Yes

I hereby certify that the required fire drills have been completed as of this inspection date. Yes

Or

Acknowledgement N/A. No

Primary Inspector: Karen Golish

Additional inspector: N/A