


Clay

High School





DISTRICT: CLAY FACILITY # 0013

FISCAL YEAR 2007-2008

FACILITY: CLAY HIGH SCHOOL
 2025 HIGHWAY 16 WEST
 GREEN COVE SPRINGS, FLORIDA 32043

COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

INSPECTION DATE: OCTOBER 10, 2007

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 10/10/07

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "G"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	110	HANDRAIL BROKEN	X							FBC 1005
1	217B	SWITCH COVER MISSING		X						NFPA 70-410
1	138B	EMERGENCY LIGHT OUT		X						FBC 423.17.1
1	138	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
1	111	NO EXIT LIGHT OR EMERGENCY LIGHTS		X						FBC 1006.3.1
1	118	NO EXIT LIGHT OR EMERGENCY LIGHTS		X						FBC 1006.3.1
1	135A	VACCUM BREAK ON WATER PIPE MISSING		X						FBC P305
2	208	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
2	214	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
3	301	NO EVACUATION SHEET		X						FBC 423.14.2.4
3	302	NO EVACUATION SHEET		X						FBC 423.14.2.4
3	303	NO EVACUATION SHEET		X						FBC 423.14.2.4
3	311	NO EVACUATION SHEET		X						FBC 423.14.2.4
3	328	PANEL L3 COVER REMOVED	X							NFPA 70-110.12



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
 COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0013

FACILITY: CLAY HIGH SCHOOL
 2025 HIGHWAY 16 WEST
 GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: OCTOBER 10, 2007

[Signature]
 INSPECTOR'S SIGNATURE DATE 10/10/07

Building	Room	Deficiency Description and Corrective Action Required:	Maint. (M)	Oper. (O)	Fac. (C)	Info. Serv. (IS)	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
3	381	EMERGENCY LIGHT OUT		X						FBC 423.17.1
3	338	ROOF LEAK	X							
3	341	EMERGENCY LIGHT OUT		X						FBC 423.17.1
3	342	EMERGENCY LIGHT OUT		X						FBC 423.17.1
3	344	EMERGENCY LIGHT OUT		X						FBC 423.17.1
3	300A	EMERGENCY LIGHT OUT		X						FBC 423.17.1
3	353	CEILING TILE BROKEN		X						FBC 804.2.3
3	366	FIRE ALARM PANEL COVER OPEN	X							NFPA 70-110.26
3	383	CEILING TILE OUT/OPEN ELECTRICAL BOXES	X							
4	401	YELLOW STRIP @ EQUIPMENT MISSING		X						NFPA 101
4	406	HALL SWITCH KNOCK OUT MISSING		X						NFPA 70-110.12
4	404	YELLOW STRIPE @ EQUIPMENT MISSING		X						NFPA 101
4	408B	EMERGENCY LIGHT OUT		X						FBC 423.17.1
6	602	ROOF LEAK	X							



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
 COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0013

FACILITY: CLAY HIGH SCHOOL
 2025 HIGHWAY 16 WEST
 GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: OCTOBER 10, 2007

INSPECTOR'S SIGNATURE: *Barrett* DATE: 10/10/07

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
7	784	ROOF LEAK	X							
7	785	ROOF LEAK	X							
7	774	ROOF LEAK	X							
8	830	ROOF LEAK	X							
8	830	BACK DROP ON STAGE REMOVE UNLESS FLAME RESISTANT MATERIAL		X						NFPA 1.14.1
9	901	EMERGENCY LIGHT OUT		X						FBC 423.17.1
9	903	EMERGENCY LIGHT OUT		X						FBC 423.17.1
9	904	EMERGENCY LIGHT OUT		X						FBC 423.17.1
9	920	AIR HANDLER #1 & #4 DRAIN CLOGGED		X						
11	1114	COVER PLATE MISSING BY ROOM 1123		X						NFPA 70-410.2
11	1101	FIRE EXTINGUISHER NOT SIGNED		X						69A-58
11	1108	DRUMS BLOCKING EGRESS		X						FBC 1001
11	1104	COVER PLATE MISSING BY ROOM 1111		X						NFPA 70-410.2



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0013

FACILITY: CLAY HIGH SCHOOL
2025 HIGHWAY 16 WEST
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: OCTOBER 10, 2007

DATE


INSPECTOR'S SIGNATURE

[Signature]

Building	Room	Deficiency Description and Corrective Action Required	Maint. 'M'	Oper. 'O'	Fac. 'C'	Info. Serv. 'I(S)'	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	7	WOOD RAMP NEEDS NON SKID ADDED		X						FBC 1006
92	8	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	17	½ EMERGENCY LIGHT NOT WORKING NEEDS BULB		X						FBC 423.17.1
92	18	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	18	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	19	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	19	SIDEWALK BLOCKED BY STAIRS			X					FBC 1001.3
92	31	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	32	OK								
92	33	WOOD RAMP OK								
92	41	OK								
92	43	LEAK UNDER SINK - KITCHEN	X							

Fleming Island

High School





FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL
 2233 VILLAGE SQUARE PARKWAY
 ORANGE PARK, FLORIDA 32003

INSPECTION DATE: OCTOBER 12, 2007

INSPECTOR'S SIGNATURE: *Jamy A. Fu* DATE: 10/12/07

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	10	SEVERAL EXTENSION CORDS JOINED TOGETHER		X						
92	11	OK								
92	12	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	13	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	14	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	15	OK								
92	20	OK								
92	21	EMERGENCY LIGHTOUT	X							FBC 423.17.1
92	22	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	23	OK								
92	24	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	25	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	30	PIER BLOCK NOT SECURE	X							
92	31	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
 COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY # 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL
 2233 VILLAGE SQUARE PARKWAY
 ORANGE PARK, FLORIDA 32003

INSPECTION DATE: OCTOBER 12, 2007

James H. Brown
 INSPECTOR'S SIGNATURE

10/12/07
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	32	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	33	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	33	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
92	34	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	35	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	35	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	40	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	41	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	41	RAMP EXCEEDS 1 -12 SLOPE	X							FBC 11.4.8
92	42	OK								
92	43	OK								
92	44	OK								
92	45	SEVERAL PIERS ARE UNDERMINED AND LOOSE	X							
92	46	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
 COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT CLAY FACILITY # 0044
 FACILITY: FLEMING ISLAND HIGH SCHOOL
2233 VILLAGE SQUARE PARKWAY
ORANGE PARK, FLORIDA 32003
 INSPECTION DATE: OCTOBER 12, 2007
 DATE 10/12/07
 INSPECTOR'S SIGNATURE [Signature]

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	47	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	48	OK								
92	49	OK								
92	50	OK								
92	51	OK								
92	52	OK								
92	53	PROJECTOR BRACKET NOT INSTALLED PROPERLY	X							
92	53	LEAK IN ROOF ABOVE EXIT AND FAN	X							
92	53	ELECTRIC CORD THRU CEILING		X						
92	60	OK								
92	61	OK								
92	62	OK								
92	63	OK								
92	73	ROOF LEAK WEST END	X							



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
 COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY # 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL
 2233 VILLAGE SQUARE PARKWAY
 ORANGE PARK, FLORIDA 32003

INSPECTION DATE: OCTOBER 12, 2007

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 10/12/07

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	72	OK								
92	71	OK								
92	70	CONCRETE RAMP TIE IN EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	80	OK								
92	81	OK								
92	82	RAMP EXCEEDS 1 -12 SLOPE	X							FBC 11.4.8
92	82	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	83	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	84	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	85	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	86	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	87	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	90	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	91	RAMP EXCEEDS 1 - 12 SLOPE	X							FBC 11.4.8



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
 COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL
 2233 VILLAGE SQUARE PARKWAY
 ORANGE PARK, FLORIDA 32003

INSPECTION DATE: OCTOBER 12, 2007

[Signature]
 INSPECTOR'S SIGNATURE DATE 10/21/07

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	91	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	92	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	93	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	94	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	95	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	95	EMERGENCY LIGHT INOPERABLE	X							69A-58.008
92	96	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
92	97	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008

Keynote Highlight

Junior/Senior Highlight



FISCAL YEAR 2007-2008

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY #: 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL
900 S.W. ORCHID AVENUE
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: OCTOBER 18, 2007

[Signature]
INSPECTOR'S SIGNATURE

10/18/07
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	112	FIRE ALARM "TROUBLE"	X							NFPA 70 110.12
1	151	HOOD CERTIFICATION EXPIRED	X							
1	187	EMERGENCY LIGHTS OUT	X							FBC 423.17.1
2	73	EMERGENCY LIGHTS OUT								FBC 423.17.1
4	411	EVACUATION SHEET MISSING		X						FBC 423.14.2.4
4	403	EVACUATION SHEET MISSING		X						FBC 423.14.2.4
5	515	DOOR CLOSER BROKEN	X							
6	606	EVACUATION SHEET MISSING		X						FBC 423.14.2.4
7	701	EVACUATION SHEET MISSING		X						FBC 423.14.2.4
7	700	EXIT LIGHT OUT	X							FBC 423.17.1
7	714	EVACUATION SHEET MISSING		X						FBC 423.14.2.4
8	803	EVACUATION SHEET MISSING		X						FBC 423.14.2.4

FISCAL YEAR 2007-2008

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES FLORIDA STATUTES 1013.12 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY #: 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL
900 S.W. ORCHID AVENUE
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: OCTOBER 18, 2007

[Signature]
INSPECTOR'S SIGNATURE

10/18/07
DATE

Building	Room	Deficiency/Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	2	OK								
92	3	OK								
92	5	EVACUATION SHEET MISSING		X						FBC 423.14.2.4
92	6	OK	92							
92	7	OK	92							
92	11	OK	92							
92	12	OK	92							
92	13	OK	92							
92	14	OK	92							
92	15	OK	92							
92	16	COVER MISSING ON LIGHT		X						

FISCAL YEAR 2007-2008

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY #: 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL
900 S.W. ORCHID AVENUE
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: OCTOBER 18, 2007
[Signature]
INSPECTOR'S SIGNATURE DATE 10/18/07

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	17	OK								
92	18	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	21	OK								
92	23	OK								
92	24	EMERGENCY LIGHT WEAK	X							FBC 423.17.1
92	25	OK								
92	26	OK								
92	50	OK								
92	51	OK								
92	29/30	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	52	EVACUATION SHEET MISSING		X						FBC 423.14.2.4
92	53	OK								
92	54	OK								

FISCAL YEAR 2007-2008

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY #: 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL
900 S.W. ORCHID AVENUE
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: OCTOBER 18, 2007

INSPECTOR'S SIGNATURE: [Signature] DATE: 10/18/07

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	55	OK								
92	56	OK								
92	57	OK								
92	58	OK								
92	59	OK								
92	60	OK								
92	62	OK								
92	64	EVACUATION SHEET MISSING		X						FBC 423.14.2.4
92	65	OK								
92	72	OK								
92	90	OK								
92	91	OK								

Middlebury

High School





FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0019

FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 24, 2007

Samuel Brown
 INSPECTOR'S SIGNATURE 10/24/07
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	227	LIGHTS DAMAGED	X							FBC 1016.3
1	241	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	221	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	164	DOOR SWINGS WRONG DIRECTION	X							
1	314	SMOKE VENT COVER MISSING	X							NFPA 70
1	285	EXIT LIGHT COVER MISSING	X							NFPA 70
1	355	DOORS SWING WRONG DIRECTION	X							
1	316B	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	368	DOOR SWINGS IN WRONG DIRECTION	X							
1	367	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	351	DOOR SWINGS IN WRONG DIRECTION	X							
1	341	REPAINT SAFETY LINES AROUND EQUIPMENT	X							



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0019

FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 24, 2007

Jerry A. Brown
 INSPECTOR'S SIGNATURE

10/24/07
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	5	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
92	7	OK								
92	9	OK								
92	31	OK								
92	32	OK								
92	33	OK								
92	34	OK								
92	35	OK								
92	36	OK								
92	41	OK								
92	42	OK								
92	43	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	44	EMERGENCY LIGHT OUT	X							FBC 423.17.1



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0019

FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 24 2007

INSPECTOR'S SIGNATURE: *Darryl H. Brown* DATE: 10/24/07

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	45	OK								
92	46	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	47	OK								
92	51	OK								
92	52	OK								
92	53	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	54A/B	OK								
92	55	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	60	OK								
92	61	OK								
92	62	OK								
92	63	OK								
92	64	OK								
92	65	OK								



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0019

FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 24, 2007

[Signature]
 INSPECTOR'S SIGNATURE

DATE: 10/24/07

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	66	OK								
92	67	OK								
92	70	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	71	OK								
92	72	OK								
92	73	OK								
92	74	OK								
92	75	OK								
92	76	OK								
92	77	COVER MISSING ON OUTLET BY EMERGENCY LIGHT, TRIP HAZARD AT BASE OF RAMP	X							NFPA 70 410.1.2
92	78	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	79	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	79	WATER PONDING AT BASE OF RAMP			X					
92	81	OK								



FISCAL YEAR 2007-2008

COMPREHENSIVE SAFETY INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"FIRE SAFETY, CASUALTY SAFETY & SANITATION INSPECTION" IN
COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY #: 0019

FACILITY: MIDDLEBURG HIGH SCHOOL
3750 C.R. 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 24, 2007

INSPECTOR'S SIGNATURE: [Signature] DATE: 10/24/07

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	82	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	83	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	84	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	85	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	86	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	87	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	88	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8
92	89	RAMP EXCEEDS 1-12 SLOPE			X					FBC 11.4.8