

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0046

FACILITY: ARGYLE ELEMENTARY SCHOOL
2625 SPENCER PLANTATION BOULEVARD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 29, 2012

[Signature]
INSPECTOR'S SIGNATURE
DATE 11-29-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	701	OK								
92	702	OK								
92	703	OK								
92	704	OK								
92	705	OUT OF SERVICE								
92	706	EMERGENCY LIGHT OUT	X							
92	707	OK								
92	711	EMERGENCY LIGHT OUT	X							
92	713	OK								
92	714	OK								
92	801	OK								
92	802	OK								
92	803	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0046

FACILITY: ARGYLE ELEMENTARY SCHOOL
2625 SPENCER PLANTATION BOULEVARD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 29, 2012

[Signature]
INSPECTOR'S SIGNATURE

[Signature]
DATE 11-29-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	804	OK								
92	805	OK								
92	806	OK								
92	807	OK								
92	808	OK								
92	901	OK								
92	902	OK								
92	903	OK								
92	904	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0002

FACILITY: CHARLES E. BENNETT ELEMENTARY SCHOOL
1 SOUTH OAKRIDGE AVENUE
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: DECEMBER 4, 2012

[Signature]
INSPECTOR'S SIGNATURE

[Signature]
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
4		OK								
5		OK								
9		OK								
10		OK								
11		OK								
12		OK								
14		FDC SIGN MISSING	X							
16		FDC SIGN MISSING	X							
16	1637	EMERGENCY LIGHT BROKEN	X							
20		OK								
21		OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0002

FACILITY: CHARLES E. BENNETT ELEMENTARY SCHOOL
1 SOUTH OAKRIDGE AVENUE
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: DECEMBER 4, 2012

INSPECTOR'S SIGNATURE: [Signature] DATE: 12-04-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	40	OK								
92	41	OK								
92	42	OK								
92	43	OK								
92	45	OK								
92	46	OK								
92	47	OK								
92	48	OK								
92	49	EMERGENCY LIGHT OUT	X							
92	50	OK								
92	51	OK								
92	52	OK								
92	53	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0002

FACILITY: CHARLES E. BENNETT ELEMENTARY SCHOOL
1 SOUTH OAKRIDGE AVENUE
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: DECEMBER 4, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: *12.4.12*

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	54		OK							
92	55		OK							
92	56		OK							
92	57		OK							
92	59		OK							
92	501		OK							
92	502		OK							
92	503		OK							
92	602		OK							
92	603		OK							
92	604		OK							
92	702		OK							
92	703		OK							
92	803		OK							

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0021

FACILITY: CLAY HILL ELEMENTARY SCHOOL
6345 STATE ROAD 218
JACKSONVILLE, FLORIDA 32234

INSPECTION DATE: DECEMBER 7, 2012

[Signature]
INSPECTOR'S SIGNATURE

12-7-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2	222	EMERGENCY LIGHT OUT	X							
3		OK								
5		OK								
6		OK								
7		OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0021

FACILITY: CLAY HILL ELEMENTARY SCHOOL
6345 STATE ROAD 218
JACKSONVILLE, FLORIDA 32234

INSPECTION DATE: DECEMBER 7, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 12-7-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	682	OK								
92	688	OK								
92	701	OK								
92	702	OK								
92	703	OK								
92	704	OK								
92	705	OK								
92	706	OK								
92	707	OK								
92	708	OK								
92	709	OK								
92	710	OK								
92	711	OK								

FISCAL YEAR 2012-2013

COMPREHENSIVE SAFETY & SANITATION

INSPECTION REPORT

STATE BOARD OF EDUCATION

ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

"CASUALTY SAFETY & SANITATION INSPECTION"

IN COMPLIANCE WITH

F.S. 1013.12, 1013.20 & NFPA 101



DISTRICT: CLAY FACILITY: 0021

FACILITY: CLAY HILL ELEMENTARY SCHOOL
6345 STATE RAD 218
JACKSONVILLE, FLORIDA 32234


INSPECTION DATE: DECEMBER 7, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 12-7-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	712	OK								
92	760	OK								
92	762	OK								
92	764	OK								
92	766	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0047

FACILITY: COPPERGATE ELEMENTARY SCHOOL
2250 COUNTY ROAD NORTH
MIDDLEBURG, FLORIDA 32043

INSPECTION DATE: DECEMBER 11, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 12-11-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
1	103	COATING OF TIME-OUT ROOM. PADDING COMING OFF WALL AND FLOOR - MAY NEED TO CALL MANUFACTURER	X							
92	501	OK								
92	502	OK								
92	503	OK								
92	504	OK								
92	511	OK								
92	512	OK								
92	513	OK								
92	514	OK								
92	516	OK								
92	518	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0008

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL
2634 COUNTY ROAD 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 9, 2013

INSPECTOR'S SIGNATURE: *[Signature]*

DATE: 1-9-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
4	107	EMERGENCY LIGHT OUT IN FRONT OF CLINIC		X						
4	119	EMERGENCY LIGHT OUT IN FRONT OF CLINIC		X						
5		OK								
6		OK								
8		OK								
9		OK								

FISCAL YEAR 2012-2013

COMPREHENSIVE SAFETY & SANITATION

INSPECTION REPORT

STATE BOARD OF EDUCATION

ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

"CASUALTY SAFETY & SANITATION INSPECTION"

IN COMPLIANCE WITH

F.S. 1013.12, 1013.20 & NFPA 101



DISTRICT: CLAY FACILITY: 0008

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL
2634 COUNTY ROAD 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 9, 2013

[Signature]
 INSPECTOR'S SIGNATURE

1-9-13
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	801	OK								
92	802	EMERGENCY LIGHT OUT - POST OFFICE		X						
92	836	OK								
92	837	OK								
92	838	OK								
92	839	OK								
92	840	OK								
92	842	OK								
92	843	OK								
92	844	OK								
92	845	OK								
92	847	OK								
92	869	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0008

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL
2634 COUNTY ROAD 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 9, 2013

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1-9-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	870	OK								
92	871	OK								
92	872	OK								
92	873	OK								
92	874	OK								
92	876	OK								
92	888	OK								
92	889	OK								
92	890	OK								
92	891	OK								
92	892	OK								
92	893	OK								
92	894	OK								
92	895	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0008

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL
2634 COUNTY ROAD 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 9, 2013

[Signature]
INSPECTOR'S SIGNATURE

1-9-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	896	OK								
92	897	OK								
92	899	OK								
92	921	OK								
92	923	OK								
92	849	EMERGENCY LIGHT OUT		X						

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL
4425 LAKESHORE DRIVE
FLEMING ISLAND, FLORIDA 32003

INSPECTION DATE: JANUARY 8, 2013

[Signature]
INSPECTOR'S SIGNATURE

1-8-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	111	REPLACE CEILING TILE		X						
2	211	RED TAG ON FIRE RISER	X							
3	304	EXIT LIGHT OUT	X							
3	314	STAINED CEILING TILE		X						
4		OK								
5	519	MATERIAL STORED TOO HIGH		X						
7		OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL
4425 LAKESHORE DRIVE
FLEMING ISLAND, FLORIDA 32003

INSPECTION DATE: JANUARY 8, 2013

[Signature]
INSPECTOR'S SIGNATURE

DATE
1-8-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	601	OK								
92	602	OK								
92	603	OK								
92	604	OK								
92	605	OK								
92	606	OK								
92	607	OK								
92	608	OK								
92	801	RESTROOM LIGHT OUT		X						
92	802	OK								
92	803	OK								
92	804	RESTROOM LIGHT OUT		X						
92	805	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL
4425 LAKESHORE DRIVE
FLEMING ISLAND, FLORIDA 32003

INSPECTION DATE: JANUARY 8, 2013

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1-8-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	806	COVERS MISSING ON LIGHTS		X						
92	807	OK								
92	809	OK								
92	812	OK								
92	821	OK								
92	824	OK								
92	826	OK								
92	828	OK								
92	830	OK								
92	832	OK								
92	841	EMERGENCY LIGHT OUT	X							
92	842	OK								
92	843	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL
4425 LAKESHORE DRIVE
FLEMING ISLAND, FLORIDA 32003

INSPECTION DATE: JANUARY 8, 2013

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1-8-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	844	OK								
92	846	OK								
92	848	OK								
92	850	OK								
92	860	OK								
92	861	EMERGENCY LIGHT OUT	X							
92	862	OK								
92	901	EMERGENCY LIGHT OUT	X							
92	903	OK								
92	904	OK								
92	905	OK								
92	906	OK								
92	907	OK								
92	908	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL
4425 LAKESHORE DRIVE
FLEMING ISLAND, FLORIDA 32003

INSPECTION DATE: JANUARY 8, 2013

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1-8-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	909	OK								
92	910	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0005

FACILITY: GROVE PARK ELEMENTARY SCHOOL
1643 MILLER STREET
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 15, 2013

DATE: 1/15/13

INSPECTOR'S SIGNATURE: *[Signature]*

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
6		OK								
7	707	NO EMERGENCY EVACUATION SHEET		X						
8		OK								
9	3	EMERGENCY LIGHT OUT	X							

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0005

FACILITY: GROVE PARK ELEMENTARY SCHOOL
1643 MILLER STREET
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 15, 2013

[Signature]
INSPECTOR'S SIGNATURE

1-15-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	5	OK								
92	6	OK								
92	7	OK								
92	9	OK								
92	27	OK								
92	29	OK								
92	31	OK								
92	43	OK								
92	44	OK								
92	500	OK								
92	501	OK								
92	504	OK								
92	506	OK								

FISCAL YEAR 2012-2013

COMPREHENSIVE SAFETY & SANITATION INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101



DISTRICT: CLAY FACILITY: 0005

FACILITY: GROVE PARK ELEMENTARY SCHOOL
 1643 MILLER STREET
 ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 15, 2013

1-18-13

INSPECTOR'S SIGNATURE _____ DATE _____

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	507	OK								
92	520 A&B	OK								
92	521	OK								
92	522	OK								
92	523	OK								
92	524	OK								
92	526	OK								
92	527	OK								
92	528	EMERGENCY LIGHT OUT. MISSING GLOBE-RESTROOM.		X						
92	525	EMERGENCY LIGHT VERY WEAK - WATCH								
92	8	EMERGENCY LIGHT IN HALL NOT WORKING		X						
92	10	GLOBE CLOSET LIGHT MISSING		X						
92	30	SIDING ROTTEN BY RAMP. TRIM BY TOILET FALLING OFF	X							

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0005

FACILITY: GROVE PARK ELEMENTARY SCHOOL
1643 MILLER STREET
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 15, 2013

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1.15.13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	37	EMERGENCY LIGHT OUT		X						
92	71	TRIP HAZARD AT LEFT RAMP	X							
92	505	EMERGENCY LIGHT OUT		X						

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0010

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL
335 S. PECAN STREET
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 10, 2013

[Signature]
INSPECTOR'S SIGNATURE

1-10-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
3		OK								
4		MOLD ISSUES - PEELING PAINT			X					
5		OK								
6		OK								
7		OK								
8		OK								
9		OK								
10		OK								
11		OK								
12		OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0010

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL
335 S. PECAN STREET
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 10, 2013

[Signature]
INSPECTOR'S SIGNATURE

1-10-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1									
92	701									
92	702									
92	703									
92	704									
92	705									
92	706									
92	707									
92	708									
92	709									
92	710									
92	713									
92	714									

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"**

IN COMPLIANCE WITH

F.S. 1013.12, 1013.20 & NFPA 101



DISTRICT: CLAY FACILITY: 0010

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL
335 S. PECAN STREET
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 10, 2013

[Signature]
INSPECTOR'S SIGNATURE

1-10-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	715	OK								
92	716	OK								
92	717	OK								
92	718	OK								
92	719	DOOR AT RAMP STICKS	X							
92	721	OK								
92	722	OK								
92	724	OK								
92	750	OK								
92	751	OK								
92	760	OK								
92	770	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0010

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL
335 S. PECAN STREET
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 10, 2013

[Signature]
INSPECTOR'S SIGNATURE

1-10-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	771	OK								
92	772	OK								
92	773	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0023

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 20123

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1.17.13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
5		OK								
6		OK								
7		OK								
20		OK								

FISCAL YEAR 2012-2013


**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0023

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2013

INSPECTOR'S SIGNATURE:  DATE: 1.17.13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	9	OK								
92	10	OK								
92	11	OK								
92	12	OK								
92	14	EMERGENCY LIGHT OUT	X							
92	15	OK								
92	16	OK								
92	18	OK								
92	39	OK								
92	40	OK								
92	41	OUT OF SERVICE								
92	42	OK								
92	43	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0023

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2013

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1.17.13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	44	OK								
92	46	OK								
92	48	OK								
92	69	OK								
92	70	OK								
92	71	OK								
92	72	OK								
92	73	OK								
92	74	OK								
92	75	EMERGENCY LIGHT OUT		X						
92	76	OK								
92	77	OK								
92	79	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0023

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2013

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1-17-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	80	OK								
92	81	OK								
92	82	OK								
92	84	OK								
92	85	OK								
92	86	OK								
92	87	OK								
92	88	OK								
92	99	OK								
92	90	OK								
92	91	OK								
92	93	OK								
92	94	REMOVE SHELVES IN FRONT OF ELECTRICAL PANEL		X						

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0023

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2013

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1.17.13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	95	OK								
92	96	OK								

FISCAL YEAR 2012-2013

COMPREHENSIVE SAFETY & SANITATION INSPECTION
REPORT

STATE BOARD OF EDUCATION

ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5

"CASUALTY SAFETY & SANITATION INSPECTION"

IN COMPLIANCE WITH

F.S. 1013.12, 1013.20 & NFPA 101



DISTRICT: CLAY FACILITY: 0015

FACILITY: LAKESIDE ELEMENTARY SCHOOL
2752 MOODY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 22, 2013

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1-22-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
4		STORAGE ONLY								
5		STORAGE ONLY								
6		OK								
7		OK								
8		OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0015

FACILITY: LAKESIDE ELEMENTARY SCHOOL
2752 MOODY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 22, 2013

INSPECTOR'S SIGNATURE: [Signature] DATE: 1-22-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	10									
92	11									
92	12									
92	13									
92	14									
92	15									
92	16									
92	17									
92	18									
92	19									
92	20									
92	21									
92	22									

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0015

FACILITY: LAKESIDE ELEMENTARY SCHOOL
2752 MOODY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 22, 2013

1-22-13

DATE

INSPECTOR'S SIGNATURE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	23	OK								
92	24	OK								
92	25	OK								
92	26	OK								
92	27	OK								
92	42	OK								
92	43	OK								
92	44	OK								
92	45	OK								
92	46	OK								
92	47	OK								
92	48	OK								
92	51	OK								

FISCAL YEAR 2012-2013

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY: 0015

FACILITY: LAKESIDE ELEMENTARY SCHOOL
2752 MOODY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 22, 2013

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 1-22-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	52	OK								
92	53	OK								
92	54	OK								
92	55	OK								
92	56	OK								
92	58	OK								
92	59	OK								
92	60	OK								
92	61	OK								
92	62	OK								
92	63	OK								
96	57	RESTROOM - OK								