



**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**


ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 8

DISTRICT: CLAY FACILITY: 0020

FACILITY: RIDGEVIEW ELEMENTARY SCHOOL  
421 JEFFERSON AVENUE  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: FEBRUARY 19, 2013

INSPECTOR'S SIGNATURE:  DATE: 2-19-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	712	EMERGENCY LIGHT OUT		X						
92	733	EMERGENCY LIGHT OUT		X						
92	746	EMERGENCY LIGHT OUT		X						
92	749	EMERGENCY LIGHT OUT		X						
92	753	EMERGENCY LIGHT OUT		X						
92	756	EMERGENCY LIGHT OUT		X						
92	757	EMERGENCY LIGHT OUT		X						



**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION   
 FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0012

FACILITY: S. B. JENNINGS ELEMENTARY SCHOOL  
215 CORONA DRIVE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: FEBRUARY 21, 2013

*[Signature]*  
 INSPECTOR'S SIGNATURE

2.21.13  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	44	EMERGENCY LIGHT OUT	X							





**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 6

DISTRICT: CLAY FACILITY: 0050

FACILITY: SHADOWLAWN ELEMENTARY SCHOOL  
2945 COUNTY ROAD 218  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: MARCH 1, 2013

*David A. [Signature]*  
INSPECTOR'S SIGNATURE DATE: 3-1-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	901	OK								
92	902	OK								



**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 6

DISTRICT: CLAY FACILITY: 0053

FACILITY: SWIMMING PEN CREEK ELEMENTARY SCHOOL  
1630 WOODPECKER LANE  
MIDDLEBURG, FLORIDA 32073

INSPECTION DATE: MARCH 1, 2013

INSPECTOR'S SIGNATURE: [Signature] DATE: 3-1-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	704	EMERGENCY LIGHT OUT	X							



**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY: 0042

FACILITY: THUNDERBOLT ELEMENTARY SCHOOL  
2020 THUNDERBOLT ROAD  
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: MARCH 13, 2013

3-13-13  
DATE

*[Signature]*  
INSPECTOR'S SIGNATURE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	400	PAPER TREE IN CORRIDOR/EXIT - REMOVE		X						
1	400	PAPER TREE IN CORRIDOR/EXIT - REMOVE		X						
1	108	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						
1	109	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						
1	113	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						
1	116	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						
1	117	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						
1	118	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY: 0042

FACILITY: THUNDERBOLT ELEMENTARY SCHOOL  
2020 THUNDERBOLT ROAD  
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: MARCH 13, 2013

INSPECTOR'S SIGNATURE:  DATE: 3-13-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	120	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						
1	121	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						
1	319	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						
1	320	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						
1	317	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						
1	309	CLOSET TOO FULL. REMOVE STORAGE FROM TOP SHELF. MUST BE 18" FROM THE CEILING.		X						

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 5


DISTRICT: CLAY FACILITY: 0042

FACILITY: THUNDERBOLT ELEMENTARY SCHOOL  
2020 THUNDERBOLT ROAD  
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: MARCH 13, 2013

3-13-13  
DATE

INSPECTOR'S SIGNATURE



Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
ALL		NO DEFICIENCIES								

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0040

FACILITY: TYNES ELEMENTARY SCHOOL  
1550 TYNES BOULEVARD  
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: MARCH 20, 2013

*[Signature]*  
INSPECTOR'S SIGNATURE

DATE 3-20-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
ALL		NO DEFICIENCIES								

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0040

FACILITY: TYNES ELEMENTARY SCHOOL  
1550 TYNES BOULEVARD  
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: MARCH 20, 2013

*[Handwritten Signature]*  
INSPECTOR'S SIGNATURE

3-20-13  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	5	EMERGENCY LIGHT NOT WORKING		X						

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 7

DISTRICT: CLAY FACILITY: 0006

FACILITY: W. E. CHERRY ELEMENTARY SCHOOL  
420 EDSON DRIVE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: MARCH 19, 2013

INSPECTOR'S SIGNATURE: [Signature] DATE: 3-19-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
4	25	NO EVACUATION SHEET		X						
4	21	NO EVACUATION SHEET		X						



**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 7

DISTRICT: CLAY FACILITY: 0006

FACILITY: W. E. CHERRY ELEMENTARY SCHOOL  
420 EDSON DRIVE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: MARCH 19, 2013

*[Signature]*  
INSPECTOR'S SIGNATURE 3-19-13  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	33	EMERGENCY LIGHT OUT	X							
92	58	MOVE FIRE EXTINGUISHER WITHIN 15' OF STOVE		X						
92	59	MOVE FIRE EXTINGUISHER WITHIN 15' OF STOVE		X						
92	60	EMERGENCY LIGHT OUT	X							
92	63	MOVE FIRE EXTINGUISHER WITHIN 15' OF STOVE		X						
92	64	MOVE FIRE EXTINGUISHER WITHIN 15' OF STOVE		X						
92	67	EXCESSIVE COMBUSTIBLES		X						

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**


ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 6

DISTRICT: CLAY FACILITY: 0026

FACILITY: WILKINSON ELEMENTARY SCHOOL  
4966 C. R. 218  
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: MARCH 21, 2013

INSPECTOR'S SIGNATURE:  DATE: 3-21-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2	209	FIRE RISER MISSING PLACARD	X							

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION


FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 6

DISTRICT: CLAY FACILITY: 0026

FACILITY: WILKINSON ELEMENTARY SCHOOL  
4966 C. R. 218  
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: MARCH 21, 2013

INSPECTOR'S SIGNATURE \_\_\_\_\_ DATE 3-26-13



Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	8	EMERGENCY LIGHT OUT	X							
92	16	EXCESSIVE COMBUSTIBLES		X						
92	34	EMERGENCY LIGHT OUT	X							
92	38	EXCESSIVE COMBUSTIBLES		X						



**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0001

FACILITY: GREEN COVE SPRINGS JUNIOR HIGH SCHOOL  
1220 BONAVENTURE AVENUE  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 7, 2012

*[Signature]*  
INSPECTOR'S SIGNATURE

11-7-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
		NONE -- ALL BUILDINGS OK								



**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0025

FACILITY: LAKE ASBURY JUNIOR HIGH SCHOOL  
2851 SANDRIDGE ROAD  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 13, 2012

*[Signature]*  
INSPECTOR'S SIGNATURE

11-13-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	133	REMOVE ALL CUSTODIAL EQUIPMENT FROM ELECTRICAL ROOM		X						
8	8131	REMOVE FERTILIZER FROM MECHANICAL ROOM - 10 BAGS MUST BE REMOVED		X						
8	8131	RED TAG ON SPRINKLER RISER - 5 YEAR INSPECTION?	X							
*		RED TAG ALL SPRINKLER RISERS FOR 5 YEAR INSPECTION	X							



**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**


ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY: 0014

FACILITY: LAKESIDE JUNIOR HIGH SCHOOL  
2750 MOODY ROAD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 15, 2012

INSPECTOR'S SIGNATURE:  DATE: 11-15-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	18	EXTENSION CORD THROUGH CEILING		X						
1	26	FAN COVER MISSING		X						
2	54	EXTENSION CORD THROUGH CEILING		X						
5	223	ELEVATOR OUT OF ORDER	X							
8	808	EXIT DOOR PANIC HARDWARE BROKEN		X						
8	814	BROKEN OUTLET COVER		X						
9	912	ELECTRICAL PANEL BLOCKED		X						

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY: 0014

FACILITY: LAKESIDE JUNIOR HIGH SCHOOL  
2750 MOODY ROAD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 15, 2012

INSPECTOR'S SIGNATURE: [Signature] DATE: 11-15-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	734	COVER MISSING ON LIGHTS		X						
92	737	COVER MISSING ON LIGHTS		X						
92	745	EMERGENCY LIGHT OUT	X							
92	793	EMERGENCY LIGHT OUT	X							

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0048

FACILITY: OAKLEAF JUNIOR HIGH SCHOOL  
410 OAKLEAF VILLAGE PARKWAY  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: DECEMBER 5, 2012

INSPECTOR'S SIGNATURE: [Signature] DATE: 12-5-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
4	409	CLASSROOM NOT BY DESIGN. DOOR SWINGS WRONG DIRECTION FOR 16 STUDENTS (EITHER MOVE TO NORMAL SIZE CLASSROOM OR CHANGE DOOR SWING).	X							
4	417	CLASSROOM NOT BY DESIGN. DOOR SWINGS WRONG DIRECTION FOR 16 STUDENTS (EITHER MOVE TO NORMAL SIZE CLASSROOM OR CHANGE DOOR SWING).	X							

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0048

FACILITY: OAKLEAF JUNIOR HIGH SCHOOL  
410 OAKLEAF VILLAGE PARKWAY  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: DECEMBER 5, 2012

*[Signature]*  
INSPECTOR'S SIGNATURE  
DATE 12.5.12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	601	EMERGENCY LIGHT NOT WORKING		X						
92	604	EMERGENCY LIGHT NOT WORKING		X						
92	611	EMERGENCY LIGHT NOT WORKING		X						
92	612	EMERGENCY LIGHT NOT WORKING		X						
92	705	EMERGENCY LIGHT NOT WORKING		X						
92	709	EMERGENCY LIGHT NOT WORKING		X						
92	710	EMERGENCY LIGHT NOT WORKING		X						
92	715	EMERGENCY LIGHT NOT WORKING		X						
92	821	EMERGENCY LIGHT NOT WORKING		X						
92	823	EMERGENCY LIGHT NOT WORKING		X						
92	824	EMERGENCY LIGHT NOT WORKING		X						

**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0016

FACILITY: ORANGE PARK JUNIOR HIGH SCHOOL  
2750 MOODY ROAD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 27, 2012

*Ed Sweatt*  
INSPECTOR'S SIGNATURE 11-27-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
5	517A	2 EMERGENCY LIGHTS OUT		X						



**FISCAL YEAR 2012-2013**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0016

FACILITY: ORANGE PARK JUNIOR HIGH SCHOOL  
2750 MOODY ROAD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 27, 2012

*[Signature]*  
INSPECTOR'S SIGNATURE

11-27-12  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	501	EMERGENCY LIGHT NOT WORKING		X						
92	503	EMERGENCY LIGHT NOT WORKING		X						
92	504	EMERGENCY LIGHT NOT WORKING		X						
92	507	EMERGENCY LIGHT OUT		X						
92	702	EMERGENCY LIGHT OUT		X						
92	710	EMERGENCY LIGHT OUT		X						