


FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0046
 FACILITY: ARGYLE ELEMENTARY SCHOOL
2625 SPENCER PLANTATION BOULEVARD
ORANGE PARK, FLORIDA 32073
 INSPECTION DATE: NOVEMBER 29, 2013

 INSPECTOR'S SIGNATURE _____ DATE 11-29-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
5	532	NO EVACUATION SHEET		X						

FISCAL YEAR 2012-2013

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0046

FACILITY: ARGYLE ELEMENTARY SCHOOL
2625 SPENCER PLANTATION BOULEVARD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 29, 2012

INSPECTOR'S SIGNATURE [Signature] DATE 11-29-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
5	532	NO EVACUATION SHEET		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0046

FACILITY: ARGYLE ELEMENTARY SCHOOL
2625 SPENCER PLANTATION BOULEVARD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 29, 2012

[Signature]
INSPECTOR'S SIGNATURE

DATE 11-29-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	706	EMERGENCY LIGHT OUT	X							
92	711	EMERGENCY LIGHT OUT	X							

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0002

FACILITY: CHARLES E. BENNETT ELEMENTARY SCHOOL
1 SOUTH OAKRIDGE AVENUE
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: DECEMBER 4, 2012

INSPECTOR'S SIGNATURE: [Signature] DATE: 12-4-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
14		FDC SIGN MISSING	X							
16		FDC SIGN MISSING	X							
16	1637	EMERGENCY LIGHT BROKEN	X							

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0002

FACILITY: CHARLES E. BENNETT ELEMENTARY SCHOOL
1 SOUTH OAKRIDGE AVENUE
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: DECEMBER 4, 2012

INSPECTOR'S SIGNATURE: [Signature] DATE: 12-4-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	49	EMERGENCY LIGHT OUT	X							

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY: 0021

FACILITY: CLAY HILL ELEMENTARY SCHOOL
6345 STATE ROAD 218
JACKSONVILLE, FLORIDA 32244

INSPECTION DATE: DECEMBER 7, 2012


INSPECTOR'S SIGNATURE: [Signature] DATE: 12-7-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2	222	EMERGENCY LIGHT OUT	X							

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION
 FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0047
 FACILITY: COPPERGATE ELEMENTARY SCHOOL
2250 COUNTY ROAD NORTH
MIDDLEBURG, FLORIDA 32043
 INSPECTION DATE: DECEMBER 11, 2012
 INSPECTOR'S SIGNATURE:  DATE: 12-11-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
		NO FIRE VIOLATIONS								

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0008

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL
2634 COUNTY ROAD 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 9, 2013

[Signature]
INSPECTOR'S SIGNATURE

1-9-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
4	107	EMERGENCY LIGHT OUT IN FRONT OF CLINIC		X						
4	119	EMERGENCY LIGHT OUT IN FRONT OF CLINIC		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0008

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL
2634 COUNTY ROAD 220
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 9, 2013

INSPECTOR'S SIGNATURE:  DATE: 1-9-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	802	EMERGENCY LIGHT OUT - POST OFFICE		X						
92	849	EMERGENCY LIGHT OUT		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58


ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL
4425 LAKESHORE DRIVE
FLEMING ISLAND, FLORIDA 32043

INSPECTION DATE: JANUARY 8, 2013

INSPECTOR'S SIGNATURE:  DATE: 1-8-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2	211	RED TAG ON FIRE RISER	X							
3	304	EXIT LIGHT OUT	X							
5	519	MATERIAL STORED TOO HIGH		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL
4425 LAKESHORE DRIVE
FLEMING ISLAND, FLORIDA 32043

INSPECTION DATE: JANUARY 8, 2013

[Signature]
INSPECTOR'S SIGNATURE

1-8-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	806	COVERS MISSING ON LIGHTS		X						
92	841	EMERGENCY LIGHT OUT	X							
92	861	EMERGENCY LIGHT OUT	X							
92	901	EMERGENCY LIGHT OUT	X							

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY: 0005

FACILITY: GROVE PARK ELEMENTARY SCHOOL
1643 MILLER STREET
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 15, 2013

1-15-13
DATE

INSPECTOR'S SIGNATURE



Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
9	3	EMERGENCY LIGHT OUT		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58


ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY: 0005

FACILITY: GROVE PARK ELEMENTARY SCHOOL
1643 MILLER STREET
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 15, 2013

INSPECTOR'S SIGNATURE:  DATE: 1-15-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	528	EMERGENCY LIGHT OUT. MISSING GLOBE-RESTROOM		X						
92	8	EMERGENCY LIGHT IN HALL NOT WORKING		X						
92	37	EMERGENCY LIGHT OUT		X						
92	505	EMERGENCY LIGHT OUT		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0010

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL
335 S. PECAN STREET
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 10, 2013
[Signature]
INSPECTOR'S SIGNATURE
DATE: 1-10-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
ALL		OK								

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0023

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2013
[Signature]
INSPECTOR'S SIGNATURE 1/17/13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
ALL		OK								

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0023

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2013

[Signature]
INSPECTOR'S SIGNATURE

1.17.13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	14	EMERGENCY LIGHT OUT	X							
92	75	EMERGENCY LIGHT OUT	X							
92	94	REMOVE SHELVES IN FRONT OF ELECTRICAL PANEL		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 6

DISTRICT: CLAY FACILITY: 0015

FACILITY: LAKESIDE ELEMENTARY SCHOOL
2752 MOODY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 22, 2013

[Handwritten Signature]
INSPECTOR'S SIGNATURE

1-22-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
ALL		OK								

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY: 0041

FACILITY: M CRAE ELEMENTARY SCHOOL
6770 CPIMTU RPAD 315C
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 25, 2013

[Handwritten Signature]
INSPECTOR'S SIGNATURE 1-25-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	842	EMERGENCY LIGHT OUT	X							
92	842	EXCESSIVE COMBUSTIBLES ON WALLS		X						
92	821	EXCESSIVE COMBUSTIBLES ON WALLS		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58


ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 7

DISTRICT: CLAY FACILITY: 0009

FACILITY: MIDDLEBURG ELEMENTARY SCHOOL
3958 MAIN STREET
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 29, 2013

INSPECTOR'S SIGNATURE:  DATE: 1-29-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2	1	EMERGENCY LIGHT OUT		X						
2	3	EMERGENCY LIGHT WEAK - REPLACE BATTERY		X						
7	38	EXIT LIGHT OUT		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 7

DISTRICT: CLAY FACILITY: 0009

FACILITY: MIDDLEBURG ELEMENTARY SCHOOL
3958 MAIN STREET
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 29, 2013

[Handwritten Signature]
INSPECTOR'S SIGNATURE

1-29-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	25	EXCESSIVE COMBUSTIBLES ON WALLS		X						
92	55	INSIGNIA MISSING			X					

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58


ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 7

DISTRICT: CLAY FACILITY: 0019

FACILITY: MONTCLAIR ELEMENTARY SCHOOL
2398 MOODY ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 31, 2013

INSPECTOR'S SIGNATURE: 

DATE: 1-31-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2	135	MATERIAL IN ELECTRICAL ROOM		X						
5	529	MOVE TOASTER OVEN BY EXIT		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58


ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 7

DISTRICT: CLAY FACILITY: 0019

FACILITY: MONTCLAIR ELEMENTARY SCHOOL
2398 MOODY ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 31, 2013

INSPECTOR'S SIGNATURE:  DATE: 1-31-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
ALL		OK								

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 7

DISTRICT: CLAY FACILITY: 0049

FACILITY: OAKLEAF VILLAGE ELEMENTARY SCHOOL
410 OAKLEAF VILLAGE PARKWAY
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: FEBRUARY 5, 2013

INSPECTOR'S SIGNATURE:  DATE: 2.5.13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		GENERAL NOTE: STORAGE TOO HIGH IN CLOSETS - 18" FROM CEILING REQUIRED.		X						
20	2000	SPRINKLER RED TAG MISSING-SPRINKLER HEAD	X							
ALL		SPRINKLERS ALL HAVE RED TAGS FOR WATER FLOW DEVICE	X							

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 7

DISTRICT: CLAY FACILITY: 0049

FACILITY: OAKLEAF VILLAGE ELEMENTARY SCHOOL
410 OAKLEAF VILLAGE PARKWAY
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: FEBRUARY 5, 2013

[Signature]
INSPECTOR'S SIGNATURE

2.5.13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	909	EXCESSIVE COMBUSTIBLES ON WALLS		X						
92	910	EXCESSIVE COMBUSTIBLES ON WALLS		X						
92	912	EXCESSIVE COMBUSTIBLES ON WALLS		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0004

FACILITY: ORANGE PARK ELEMENTARY SCHOOL
1401 PLAINFIELD AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: FEBRUARY 8, 2013

[Signature]
INSPECTOR'S SIGNATURE DATE 2.8.13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2		SECONDARY EXITS NOT CLEARLY MARKED	X							
5	16	EXIT LIGHT OUT	X							

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0004

FACILITY: ORANGE PARK ELEMENTARY SCHOOL
1401 PLAINFIELD AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: FEBRUARY 8, 2013

Sam A. Gurr
INSPECTOR'S SIGNATURE DATE 2-8-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
ALL		OK								

FISCAL YEAR 2012-2013

DISTRICT: CLAY FACILITY: 0024

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

FACILITY: ROBERT M. PATERSON ELEMENTARY SCHOOL
5400 PINE AVENUE
ORANGE PARK, FLORIDA 32003

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

INSPECTION DATE: FEBRUARY 12, 2013
INSPECTOR'S SIGNATURE: [Signature] DATE: 2-12-13

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 6

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2	208	GAS BOTTLE STORED IN MECHANICAL ROOM -- REMOVE		X						
3	305	EMERGENCY EVACUATION SHEET MISSING		X						
4	408	EMERGENCY EVACUATION SHEET MISSING		X						
6	612	EMERGENCY EVACUATION SHEET MISSING		X						

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 6

DISTRICT: CLAY FACILITY: 0024

FACILITY: ROBERT M. PATERSON ELEMENTARY SCHOOL
5400 PINE AVENUE
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 12, 2013

INSPECTOR'S SIGNATURE:  DATE: 2/12/13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
ALL		NO DEFICIENCIES								

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY: 0051

FACILITY: PLANTATION OAKS ELEMENTARY SCHOOL
4150 PLANTATION OAKS BOULEVARD
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: MARCH 8, 2013
INSPECTOR'S SIGNATURE: *[Signature]* DATE: 3.8.13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	118	RED TAG ON FIRE RISER	X							
20	2000	RED TAG ON FIRE RISER	X							
25	2500	RED TAG ON FIRE RISER	X							

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58


ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY: 0051

FACILITY: PLANTATION OAKS ELEMENTARY SCHOOL
4150 PLANTATION OAKS BOULEVARD
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: MARCH 8, 2013

INSPECTOR'S SIGNATURE:  DATE: 3-8-13

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
ALL		NO DEFICIENCIES								

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 6

DISTRICT: CLAY FACILITY: 0043

FACILITY: RIDEOUT ELEMENTARY SCHOOL
3065 APALACHICOLA BOULEVARD
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 15, 2013

[Signature]
INSPECTOR'S SIGNATURE

2-15-13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
ALL		NO DEFICIENCIES								

FISCAL YEAR 2012-2013

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 6

DISTRICT: CLAY FACILITY: 0043

FACILITY: RIDEOUT ELEMENTARY SCHOOL
3065 APALACHICOLA BOULEVARD
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 15, 2013

[Signature]
INSPECTOR'S SIGNATURE

2/15/13
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	14	EMERGENCY LIGHT OUT	X							
92	20	FIRE ALARM PULL STATION BROKEN	X							