

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT & RELOCATABLE INSPECTION

FIRE DRILL LOG:

DISTRICT: CLAY FACILITY: 0036

FACILITY: CLAY SUPERINTENDENT'S OFFICE
900 WALNUT STREET
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: MARCH 7, 2012

Tom Smeetham
INSPECTOR'S SIGNATURE 3-7-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
95	1	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
95	2	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT & RELOCATABLE INSPECTION

FIRE DRILL LOG:

DISTRICT: CLAY FACILITY: 0027

FACILITY: H. C. LONG ADMINISTRATION BUILDING
23 SOUTH GREEN STREET
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: MARCH 7, 2012

Todd Swearingin
INSPECTOR'S SIGNATURE DATE 3-7-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	100	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
3	300	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
4	404A	ADD EXIT LIGHT - EMERGENCY LIGHT	X							FBC 423.17.1

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT & RELOCATABLE INSPECTION

FIRE DRILL LOG:

DISTRICT: CLAY FACILITY: 0030

FACILITY: SCHOOL BUS GARAGE - TRANSPORTATION
800 CENTER STREET
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: MARCH 7, 2012

Ed Sheatman
INSPECTOR'S SIGNATURE

3-7-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	200	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
91	3	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT & RELOCATABLE INSPECTION

FIRE DRILL LOG: _____

DISTRICT: CLAY FACILITY: 0003

FACILITY: SUPPORT SERVICE CENTER
925 WEST CENTER STREET
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: MARCH 7, 2012

Ed Weathers
INSPECTOR'S SIGNATURE 3-7-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	11A	EMERGENCY LIGHT OUT		X						FBC 423.17.1
10	104	EMERGENCY LIGHT OUT		X						FBC 423.17.1
10	107	EMERGENCY LIGHT OUT		X						FBC 423.17.1