

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0012


**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: S. B. JENNINGS ELEMENTARY SCHOOL
215 CORONA DRIVE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: FEBRUARY 8, 2012

INSPECTOR'S SIGNATURE

DATE



2-8-12



Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2	37A	OUTLETS ABOVE CEILING	X		X					NFPA 70-110.12
2	38A	EMERGENCY LIGHT OUT	X							FBC 423.17.1
3		OK								
4		OK								
5		OK								
6		OK								
7		OK								
8		OK								
9		OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0012

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: S. B. JENNINGS ELEMENTARY SCHOOL
215 CORONA DRIVE
ORANGE PARK, FLORIDA 32073



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: FEBRUARY 8, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

2-8-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	26	OK								
92	27	OK								
92	28	OK								
92	29	OK								
92	30	OK								
92	32	OK								
92	33	OK								
92	34	OK								
92	35	OK								
92	36	OK								
92	37	OK								
92	38	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0012

FACILITY: S. B. JENNINGS ELEMENTARY SCHOOL
215 CORONA DRIVE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: FEBRUARY 8, 2012

[Signature]
 INSPECTOR'S SIGNATURE

2-8-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Pac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	42	OK								
92	43	OK								
92	44	OK								
92	45	OK								
92	46	OK								
92	75	OK								
92	76	OK								
92	77	OK								
92	78	OK								
92	79	OK								
92	80	OK								
92	81	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0053



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: SWIMMING PEN CREEK ELEMENTARY SCHOOL
1630 WOODPECKER LANE
MIDDLEBURG, FLORIDA 32073

INSPECTION DATE: FEBRUARY 14, 2012

Ted Spicattone
INSPECTOR'S SIGNATURE 2-14-12
DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
3		OK								
4		OK								
5		OK								
6		OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0053



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: SWIMMING PEN CREEK ELEMENTARY SCHOOL
1630 WOODPECKER LANE
MIDDLEBURG, FLORIDA 32073

INSPECTION DATE: FEBRUARY 14, 2012

Ted Sweetland
INSPECTOR'S SIGNATURE

2-14-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	701	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	702	OK								
92	703	OK								
92	704	OK								
92	705	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	706	OK								
92	707	OK								
92	708	OK								
92	801	OK								
92	803	EXCESSIVE COMBUSTIBLES ON WALLS		X						NEPA 70 110.28
92	804	OK								
92	805	OK								
92	806	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0053

FACILITY: SWIMMING PEN CREEK ELEMENTARY SCHOOL
1630 WOODPECKER LANE
MIDDLEBURG, FLORIDA 32073

INSPECTION DATE: FEBRUARY 14, 2012

Ted Sweatland
 INSPECTOR'S SIGNATURE 2-14-12
DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint 'M'	Oper 'O'	Fac 'C'	Info. Serv. 'I.S.'	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	807	HANDRAIL EXTENSION MISSING ON RAMP								
92	808	OK								
92	809	OK								
92	810	EMERGENCY LIGHT OUT	X							FBC 423.17.1

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0042



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: THUNDERBOLT ELEMENTARY SCHOOL
2020 THUNDERBOLT ROAD
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 15, 2012

Tom Sweatt
INSPECTOR'S SIGNATURE DATE 2-15-12

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	109	STORAGE TOO HIGH IN CLOSET		X						NFPA 101 9.7.1.1
1	116	STORAGE TOO HIGH IN CLOSET		X						NFPA 101 9.7.1.1
1	125	EMERGENCY LIGHT OUT		X						FBC 423.17.1
1	111	POWER STRIPS DAISY CHAINED TOGETHER -- NEED LONGER POWER STRIPS		X						NFPA 70-400:8
1	234	STORAGE TOO HIGH IN CLOSET		X						NFPA 101 0.7.1.1
1	247	CEILING TILE STAINED -- RIGHT IN FRONT OF STAGE		X						FBNC 804.2.3
1	304	STORAGE TOO HIGH IN CLOSET		X						NFPA 101 9.7.1.1
1	328	OPEN ELECTRICAL BOX	X							NFPA 70-110.12

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0042

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: THUNDERBOLT ELEMENTARY SCHOOL
2020 THUNDERBOLT ROAD
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 15, 2012

Ted Sweattard
INSPECTOR'S SIGNATURE

2-15-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Pac. "C"	Info Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	701	OK								
92	702	OK								
92	703	OK								
92	704	OK								
92	705	OK								
92	706	OK								
92	707	OK								
92	708	OK								
92	709	OK								
92	710	OK								
92	711	OK								
92	713	OK								
92	721	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0042

FACILITY: THUNDERBOLT ELEMENTARY SCHOOL
2020 THUNDERBOLT ROAD
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 15, 2012

Ted Swettone
 INSPECTOR'S SIGNATURE 2-15-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	722	OK								
92	723	OK								
92	724	OK								
92	725	OK								
92	726	OK								
92	727	OK								
92	728	OK								
92	729	OK								
92	730	OK								
92	731	OK								
92	732	OK								
92	733	OK								
92	734	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0042

FACILITY: THUNDERBOLT ELEMENTARY SCHOOL
2020 THUNDERBOLT ROAD
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 15, 2012

Ted Sweetland
 INSPECTOR'S SIGNATURE 2-15-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
96	712	OK - RESTROOM								
92	725	OK								
92	736	OK								
92	737	OK								
92	738	OK								
92	739	OK								
92	740	OK								
92	741	OK								
92	742	OK								
92	743	OK								
92	744	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0040

FACILITY: TYNES ELEMENTARY SCHOOL
1550 TYNES BOULEVARD
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 23, 2012

[Handwritten Signature]
 INSPECTOR'S SIGNATURE

2-23-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "G"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
3		OK								
4		OK								
5		OK								
6		OK								

FISCAL YEAR 2011-2012


DISTRICT: CLAY FACILITY: 0040

FACILITY: TYNES ELEMENTARY SCHOOL
1550 TYNES BOULEVARD
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 23, 2012

INSPECTOR'S SIGNATURE

DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

[Handwritten Signature]

[Handwritten Date: 2-23-12]

Building	Room	Deficiency Description and Corrective Action Required:	Maint "M"	Oper "O"	Pac. "C"	Info. Serv "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	OK								
92	2	OK								
92	3	OK								
92	4	OK								
92	5	OK								
92	6	OK								
92	7	OK								
92	8	OK								
92	9	OK								
92	10	OK								
92	22	OK								

FISCAL YEAR 2011-2012


DISTRICT: CLAY FACILITY: 0040

FACILITY: TYNES ELEMENTARY SCHOOL
1550 TYNES BOULEVARD
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 23, 2012

INSPECTOR'S SIGNATURE

DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

[Handwritten Signature]

2-23-12

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def Gited	Scheduled for Correction	Rule
92	23	OK								
92	25	OK								
92	26	OK								
92	27	OK								
92	28	OK								
92	29	OK								
92	30	OK								
92	41	OK								
92	45	OK								
92	47	OK								
92	61	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0040

FACILITY: TYNES ELEMENTARY SCHOOL
1550 TYNES BOULEVARD
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 23, 2012

[Signature]
INSPECTOR'S SIGNATURE

2-23-12
DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	62	OK								
92	63	OK								
92	64	OK								
92	65	OK								
92	66	OK								
92	67	OK								
92	68	OK								
92	24	EMERGENCY LIGHT OUT		X						FBG 423.17.1
96	21	OK - RESTROOMS								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0006

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: W. E. CHERRY ELEMENTARY SCHOOL
420 EDSON DRIVE
ORANGE PARK, FLORIDA 32073



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: FEBRUARY 21, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

2-21-12
DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	1	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70-110.12
1	3	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70-110.12
1	4	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70-110.12
1	5	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70-110.12
1	6	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70-110.12
2		OK								
3		OK								
4		OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0006

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: W. E. CHERRY ELEMENTARY SCHOOL
420 EDSON DRIVE
ORANGE PARK, FLORIDA 32073



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: FEBRUARY 21, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

2-21-12
DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	57	OK								
92	58	OK								
92	59	OK								
92	60	OK								
92	62	OK								
92	63	OK								
92	64	OK								
92	65	OK								
92	66	OK								
92	67	EXCESSIVE COMBUSTIBLES ON WALLS AND CEILING		X						NFPA 70:110.28
92	68	OK								
92	69	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0006

FACILITY: W. E. CHERRY ELEMENTARY SCHOOL
420 EDSON DRIVE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: FEBRUARY 21, 2012

[Signature]
 INSPECTOR'S SIGNATURE

2/21/12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	70	OK								
92	40	WATER STAIN (MOLD) ON CEILING	X							FBC 803.2.3
92	41	OK								
92	42	OK								
92	43	OK								
92	47	OK								
92	48	OK								
92	49	OK								
92	50	OK								
92	51	OK								
92	53	OK								
92	54	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0006

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: W. E. CHERRY ELEMENTARY SCHOOL
420 EDSON DRIVE
ORANGE PARK, FLORIDA 32073



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: FEBRUARY 21, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

2-21-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	26	OK								
92	27	OK								
92	28	OK								
92	29	OK								
92	30	OK								
92	31	OK								
92	32	OK								
92	33	OK								
92	34	OK								
92	36	OK								
92	37	OK								
92	38	OK								
92	39	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0026

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: WILKINSON ELEMENTARY SCHOOL
4966 C. R. 218
MIDDLEBURG, FLORIDA 32068



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: MARCH 3, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

3-3-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	137	ROOM VERY WARM FROM COMPUTER SERVERS - NEEDS ROOM ENCLOSED - AC				X				
2	209	FIRE SPRINKLER SYSTEM PLACARD MISSING HYDRAULIC CALCULATIONS	X							
20	R1	EXHAUST FAN SCREEN MISSING	X							
20	R2	GENERATOR EXHAUST FAN SCREEN DAMAGED	X							
3		OK								
4		OK								
5	524	LENS MISSING AT CLOSET LIGHT								NFPA 708-401.3

FISCAL YEAR 2011-2012

DISTRICT CLAY FACILITY: 0026

FACILITY: WILKINSON ELEMENTARY SCHOOL
4966 C. R. 218
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: MARCH 3, 2012

INSPECTOR'S SIGNATURE

DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

[Handwritten Signature]

3-3-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	OK								
92	2	OK								
92	3	OK								
92	4	OK								
92	6	OK								
92	7	OK								
92	8	OK								
92	10	OK								
92	11	OK								
92	13	OK								
92	33	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0026

FACILITY: WILKINSON ELEMENTARY SCHOOL
4966 C. R. 218
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: MARCH 3, 2012

[Signature]
 INSPECTOR'S SIGNATURE

3-3-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. 'M'	Oper. 'O'	Fac. 'C'	Info. Serv. 'I.S.'	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	34	OK								
92	35A	OK								
92	35B	OK								
92	36	OK								
92	37	OK								
92	38	OK								
92	39	OK								
92	42	OK								
92	43	OK								
92	45	OK								
92	46	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0026

FACILITY: WILKINSON ELEMENTARY SCHOOL
4966 C. R. 218
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: MARCH 3, 2012

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 3-3-12



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	47	OK								
92	48	OK								
92	49	OK								
92	50	OK								
92	51	OK								
92	52	OK								
92	53	OK								
92	62	OK								
92	64	OK								
92	68	OK								
92	66	BACK DOOR CROWDED WITH CABINET								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0026

FACILITY: WILKINSON ELEMENTARY SCHOOL
4966 C. R. 218
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: MARCH 3, 2012

[Handwritten Signature]
 INSPECTOR'S SIGNATURE

3-3-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. I.S.	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	5	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	22	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	31	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	12	PLUG ABOVE CEILING TO PROJECTOR			X					NFPA 70 110.12
92	14	PLUG ABOVE CEILING TO PROJECTOR			X					NFPA 70 110.12
92	15	PLUG ABOVE CEILING TO PROJECTOR			X					NFPA 70 110.12
92	16	PLUG ABOVE CEILING TO PROJECTOR			X					NFPA 70 110.12
92	17	PLUG ABOVE CEILING TO PROJECTOR			X					NFPA 70 110.12
92	19	PLUG ABOVE CEILING TO PROJECTOR			X					NFPA 70 110.12
92	20	PLUG ABOVE CEILING TO PROJECTOR			X					NFPA 70 110.12
92	40	PLUG ABOVE CEILING TO PROJECTOR			X					NFPA 70 110.12

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0026

FACILITY: WILKINSON ELEMENTARY SCHOOL
4966 C. R. 218
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: MARCH 3, 2012

[Signature]
 INSPECTOR'S SIGNATURE 3-3-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	41	PLUG ABOVE CEILING TO PROJECTOR			X					NFPA 70 110.12
92	44	PLUG ABOVE CEILING TO PROJECTOR			X					NFPA 70 110.12
92	9	OK - RESTROOM								