



**FISCAL YEAR 2010-2011**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: ✓ NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL  
2233 VILLAGE SQUARE PARKWAY  
FLEMING ISLAND, FLORIDA 32003

INSPECTION RATE: OCTOBER 18, 2011

INSPECTOR'S SIGNATURE:  DATE: 10-18-11

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	12	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	13	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	14	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	25	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	31	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	32	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	34	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	51	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	52	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	60	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	63	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	72	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	86	EXIT LIGHT MISSING @ RAMP DOOR	X							BC 423.17.1

**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**- FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY: 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL  
2900 S.W. ORCHID AVENUE  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: OCTOBER 13, 2011

*[Signature]*  
INSPECTOR'S SIGNATURE

10-13-11  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	190	STORAGE TO HIGH - 18" FROM CEILING		X						NFPA 1
2	171	OPEN "J" BOXES IN THREE LOCATIONS	X							NFPA 70-110.26
4	401	OPEN "J" BOXES	X							NFPA 70-110.26
4	403	KNOCK-OUTS OPEN ON ELECTRICAL PANEL	X							NFPA 70-110.26
4	412	OPEN "J" BOX	X							NFPA 70-110.26
4	402	MATERIAL STORED TOO CLOSE TO CEILING		X						NFPA 70-110.26
5	509	MATERIAL STORED TOO CLOSE TO CEILING		X						NFPA 70-110.26
5	518	REMOVE PROPANE TANK		X						NFPA 1.21.3.3.5
6		ALL STORAGE ROOMS HAVE MATERIAL STORED TOO CLOSE TO CEILING		X						NFPA 1.21.3.3.5
7	700	EXIT LIGHT OUT	X							FBC 1016.3.1
20	2	OUTLET COVER MISSING		X						NFPA 70-410.1.2
35	2	REMOVE PROPANE BOTTLE		X						NFPA 1.21.3.3.5

**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY: 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL  
2900 S.W. ORCHID AVENUE  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: OCTOBER 13, 2011

*[Signature]*  
INSPECTOR'S SIGNATURE

10-13-11  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	18	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	26	NO EVACUATION SHEET		X						NFPA 423.14.2.4
92	29	POWER STRIP TO POWER STRIP		X						NFPA 70-400.8
92	29	SPEAKER WIRE ON FLOOR		X						NFPA 70-110.12
92	50	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	61	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	63	SECOND EXIT BLOCKED	X							FBC 423.20.1
92	82	MATERIAL STORED TOO CLOSE TO CEILING		X						NFPA 70-110.26
92	82	NO HEAT DETECTOR IN CLOSET		X						NFPA 72

**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0019

FACILITY: MIDDLEBURG HIGH SCHOOL  
3750 C.R. 220  
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 20, 2011

*[Signature]*  
INSPECTOR'S SIGNATURE

DATE 10-20-11

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	49	EXTENSION CORD THROUGH CEILING		X						NFPA 70-400.8
1	133	MISSING FIRE ALARM COVER	X							NFPA 70
1	139	EXTENSION CORD ABOVE CEILING		X						NFPA 70-400.8
1	142	EXTENSION CORD ABOVE CEILING		X						NFPA 70-400.8
1	161	DIMMER SWITCH HOT	X							NFPA 110
1	241	POWER STRIP DAISY CHAINED		X						NFPA 70-400.8
1	285	OUTLET BOX BROKEN								NFPA 70
1	307	NO FIRE ALARM STROBE	X							NFPA 101-29.3.4.1
1	309	NO FIRE ALARM STROBE	X							NFPA 101-29.3.4.1

**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0019

FACILITY: MIDDLEBURG HIGH SCHOOL  
3750 C.R. 220  
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: OCTOBER 20, 2011

*[Signature]*  
INSPECTOR'S SIGNATURE

10-20-11  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	001	SMOKE DETECTOR NOT FASTEND AT CEILING	X							NFPA 1 (103) 10.4.1
92	41	PROJECTOR NOT WIRED PROPERLY	X							NFPA 70-110.12
92	44	PROJECTOR NOT WIRED PROPERLY	X							NFPA 70-110.12
92	47	PROJECTOR NOT WIRED PROPERLY	X							NFPA 70-110.12
92	51	PROJECTOR NOT WIRED PROPERLY	X							NFPA 70-110.12
92	53	PROJECTOR NOT WIRED PROPERLY	X							NFPA 70-110.12
92	55	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	73	EMERGENCY LIGHT OUT	X							NFPA 101.7.9

**FISCAL YEAR 2011-2012**


**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 1

INSPECTION DATE: NOVEMBER 1, 2011

INSPECTOR'S SIGNATURE: 

DATE: 11-1-11

DISTRICT: CLAY FACILITY #: 0052

FACILITY: OAKLEAF HIGH SCHOOL  
4035 PLANTATION OAKS BOULEVARD  
ORANGE PARK, FLORIDA 32065

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		STAIRWELL DOORS PROPPED OPEN		X						FBC 1008.1.3.7
3	300A	DOORS PROPPED OPEN		X						FBC 1008.1.3.7
3	314H	CARDBOARD STORED IN ROOM CLEARLY MARKED "NO STORAGE"		X						NFPA 1-12.1.1
11	1110	PROPANE GAS BOTTLES STORED IN BUILDING-REMOVE		X						NFPA 1.21.3.3.5
7	703A	PROPANE GAS BOTTLES STORED IN BUILDING-REMOVE		X						NFPA 1.21.3.3.5
7	703	PROPANE GAS BOTTLES STORED IN BUILDING-REMOVE		X						NFPA 1.21.3.3.5

# FISCAL YEAR 2011-2012

## FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES

### FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0003

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK FLORIDA 32073

INSPECTION DATE: OCTOBER 25, 2011

*Tom J. Sautter*  
INSPECTOR'S SIGNATURE

Oct 25, 2011  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	180B	FIRE ALARM --ANUNCIATOR PANEL NOT WORKING	X							NFPA 101-9.6
1	107	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
1	219B	EMERGENCY LIGHT OUT		X						FBC 423.17.1
1	233	EMERGENCY LIGHT OUT		X						FBC 423.17.1
1	225	EXIT LIGHT OUT		X						FBC 423.17.1
1	227	EXTENSION CORD ABOVE CEILING - REMOVE		X						NFPA 70-400.8
1	228	EXTENSION CORD ABOVE CEILING - REMOVE		X						NFPA 70-400.8
4	5G	EMERGENCY LIGHT OUT		X						FBC 423.17.1
4	17C	EMERGENCY LIGHT OUT		X						FBC 423.17.1
4	122	EMERGENCY LIGHT OUT		X						FBC 423.17.1
4	103	EMERGENCY LIGHT OUT		X						FBC 423.17.1



**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0003

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK FLORIDA 32073

INSPECTION DATE: OCTOBER 25, 2011

INSPECTOR'S SIGNATURE: [Signature] DATE: OCT 25, 2011

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
10	104	EMERGENCY LIGHT OUT		X						FBC 423.17.1
12	135	NO EVACUATION SHEET		X						FBC 423.14.2.4
12	141	NO EVACUATION SHEET		X						FBC 423.14.2.4
12	153	NO EVACUATION SHEET		X						FBC 423.14.2.4
24		NO EVACUATION SHEET		X						FBC 423.14.2.4
41	1	EMERGENCY LIGHT OUT		X						FBC 423.17.1
41	1	GAS CANS STORED IN BUILDING - REMOVE		X						NFPA 1
41	1	GAS POWERED TRENCHER - REMOVE		X						NFPA 1
41	4	GAS CANS/EQUIPMENT - REMOVE		X						NFPA 1
51	12	EMERGENCY LIGHT OUT		X						FBC 423.17.1

**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0003

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK FLORIDA 32073

INSPECTION DATE: OCTOBER 25, 2011

*Ted Sweatt*  
 INSPECTOR'S SIGNATURE DATE Oct 25, 2011

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
51	13	EMERGENCY LIGHT OUT		X						FBC 423.17.1
51	21	EMERGENCY LIGHT BROKEN		X						FBC 423.17.1

**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0003

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK FLORIDA 32073

INSPECTION DATE: OCTOBER 25, 2011

*Ed Swanton*  
INSPECTOR'S SIGNATURE

Oct 25, 2011  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	13	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	37	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	38	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	48	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	50	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	53	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	54	PROJECTOR INSTALLED IMPROPERLY		X						NFPA 70
92	55	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	67	EMERGENCY LIGHT OUT		X						FBC 423.17.1

**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY: 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 28, 2011

*[Signature]*  
INSPECTOR'S SIGNATURE

10-28-11  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	124	HEAT DETECTOR LOOSE IN CEILING	X							NFPA 1-10.4.1
1	124	STAINED CEILING TILE		X						FBC 804.2.3
1	149	EXIT LIGHT OUT	X							FBC 1006.3.1
2	204	LIGHT SWITCH BROKEN								NFPA 70
2	201	OPEN ELECTRICAL BOX	X							NFPA 70 110.26
2	207	FIRE ALARM BOX COVER MISSING	X							NFPA 70 110.26
2	220	EXCESSIVE MATERIAL STORED		X						NFPA 70 11.26
2	211	EXTERIOR DOOR - DEADBOLT CANNOT UNLOCK FROM INSIDE	X							NFPA 14.5.2
2	215	DOOR HANDLE BROKEN	X							
3	309	MATERIAL STORED TOO HIGH		X						NFPA 13.8.5.3
3	315	SWITCH COVER MISSING		X						NFPA 70

**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**


ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY: 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 28, 2011

INSPECTOR'S SIGNATURE:  DATE: 10-28-11

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
3	326	LIGHT BULB EXPOSED	X							NFPA 708-401.3
3	332	EXPOSED WIRES	X							NFPA 70-410.1.2
3	329	OUTLET COVER MISSING		X						NFPA 70-410.1.2
3	333	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
5	502	EXIT LIGHT BROKEN	X							FBC 804.2.3
5	528	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
5	530	TWO OUTLETS WITH COVERS		X						NFA70
5	530	NO EMERGENCY EVACUATION SHEET		X						FBC 423.2.4
5	544	ALL POWER STIPS LOOPED TOGETHER		X						NFPA 70 400.8
6	612	BROKEN SWITCH COVER		X						NFPA 70-410.12
6	630	OPEN ELECTRICAL BOX	X							NFPA 70

**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES  
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 2

INSPECTION DATE: OCTOBER 28, 2011

*[Signature]*  
INSPECTOR'S SIGNATURE

10-28-11  
DATE

DISTRICT: CLAY FACILITY: 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32073

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
6	689	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
7	714	NO EVACUATION SHEET		X						FBC 423.14.2.4
8	828	4 WHEELER STORED IN MECHANICAL ROOM		X						NFPA 1
9	903	FIRE EXTINGUISHER MISSING		X						NFPA 1(03) 13.6.3.6
9	924	SWITCH PLATE COVER BROKEN		X						NFPA 70
9	950	LIGHT OUT - NO EMERGENCY LIGHT	X							FBC 423.17.1
9	930	EMERGENCY LIGHT OUT	X							FBC 423.17.1
9	928	SWITCH COVER MISSING		X						NFPA 70
9	914	OUTLET COVER MISSING		X						NFPA 70
10	1008	J-BOX OPEN, CEILING TILE MISSING		X						NFPA 70
10	1006	EXTENSION CORD ABOVE CEILING	X							NFPA 70-110.2.4

**FISCAL YEAR 2011-2012**

**FIRE SAFETY INSPECTION REPORT  
FOR EDUCATIONAL FACILITIES**

**FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION  ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG:  NUMBER OF DRILLS PERFORMED: 2

DISTRICT: CLAY FACILITY: 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 28, 2011

INSPECTOR'S SIGNATURE: 

DATE: 10-28-11

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	2	OPEN JUNCTION BOX @ ENTRY	X							NFPA 70
92	4	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	12	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	25	PROJECTOR NOT WIRED PROPERLY	X							NFPA 70-110.2.4
92	50	EXCESSIVE MATERIAL ON WALLS		X						NFPA 70-110.2.6
92	63	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	68	ACCESS TO ELECTRICAL PANEL		X						NFPA 70 110.26
92	74	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	103	PROJECT WIRED IMPROPERLY	X							NFPA 70-110.2.4