

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58


ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY #: 0003

FACILITY: BANNERMAN LEARNING CENTER
608 MILL STREET
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 4, 2011

INSPECTOR'S SIGNATURE:  DATE: 11-4-11

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
2	208	TOO MUCH STORAGE BLOCKING ELECTRIC PANELS		X						FBC 1006.3.1

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 2

DISTRICT CLAY FACILITY 0001

FACILITY: GREEN COVE SPRINGS JUNIOR HIGH SCHOOL
1220 BONAVENTURE AVENUE
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 10, 2011

INSPECTOR'S SIGNATURE: [Signature] DATE: 11-10-11

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I/S"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
3	34	EMERGENCY LIGHT OUT	X							FBC 423.17.1
4	403	EXTENSION CORD ABOVE CEILING		X						NEPA 70-400.8
4	404	PROJECTOR NOT INSTALLED PROPERLY	X							NFPA 70-110.12
5	501	EXIT SIGNS BROKEN	X							NFPA 1
5	501	NO MAX OCCUPANCY SIGN		X						FBC 423.14.2.2
1	10	PROJECTOR NOT INSTALLED PROPERLY	X							NFPA 70 110.12
1	12	PROJECTOR NOT INSTALLED PROPERLY	X							NFPA 70 110.12
1	14A	FOUR STOVES - NO HOODS	X							NFPA 1-10.4.1
31	1	REMOVE PROPANE TANK		X						NFPA 1.21.3.3.5

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 2

DISTRICT CLAY FACILITY 0001

FACILITY: GREEN COVE SPRINGS JUNIOR HIGH SCHOOL
1220 BONAVENTURE AVENUE
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 10, 2011

[Signature]
INSPECTOR'S SIGNATURE

11-10-11
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	70	PROJECTOR INSTALLED IMPROPERLY	X							NFPA 70-110.12
92	70	EMERGENCY LIGHT OUT	X							FBC 423-17.1
92	74	PROJECTOR INSTALLED IMPROPERLY	X							NFPA 70-110.12
92	107	PROJECTOR INSTALLED IMPROPERLY	X							NFPA 70-110.12

FISCAL YEAR 2011-2012


**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

INSPECTION DATE: NOVEMBER 17, 2011


INSPECTOR'S SIGNATURE

11-17-11
DATE

DISTRICT CLAY FACILITY 0025

FACILITY: LAKE ASBURY JUNIOR HIGH SCHOOL
2851 SANDRIDGE ROAD
GREEN COVE SPRINGS, FLORIDA 32043

Building	Room	Deficiency/Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	111	FIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
1	139	FIRE ALARM FLOW SWITCH BOX OPEN	X							NFPA 70-110.26
3	343	PIRE EXTINGUISHER NOT SIGNED		X						69A-58.008
3	344	ELECTRICAL PANEL KNOCKOUT MISSING	X							NFPA 70(99)-410-4(A)
8	8096	OUTLET FOR PROJECTOR ABOVE CEILING			X					NFPA 70-110.12
8	8019	OUTLET FOR PROJECTOR ABOVE CEILING			X					NFPA 70-110.12
8	8056	OUTLET FOR PROJECTOR ABOVE CEILING			X					NFPA 70-110.12

FISCAL YEAR 2011-2012

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58


ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT CLAY FACILITY 0025

FACILITY: LAKE ASBURY JUNIOR HIGH SCHOOL
2851 SANDRIDGE ROAD
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 17, 2011

INSPECTOR'S SIGNATURE: 

DATE: 11-17-11

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I/S"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	393	PROJECTOR INSTALLED IMPROPERLY			X					NFPA 70-110.12
92	405	PROJECTOR INSTALLED IMPROPERLY			X					NFPA 70-110.12
92	402	PROJECTOR INSTALLED IMPROPERLY			X					NFPA 70-110.12
92	410	EMERGENCY LIGHTOUT	X							FBC 423.17.1

FISCAL YEAR 2011-2012

FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT CLAY FACILITY 0014

FACILITY: LAKESIDE JUNIOR HIGH SCHOOL
2750 MOODY ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 29, 2011

INSPECTOR'S SIGNATURE: *Dan [Signature]* DATE: 11-29-11

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	745	EMERGENCY LIGHT OUT		X						FBC 423.17.1

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY: 0048

FACILITY: OAKLEAF JUNIOR HIGH SCHOOL
410 OAKLEAF VILLAGE PARKWAY
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: DECEMBER 8, 2011

[Signature]
INSPECTOR'S SIGNATURE DATE 12-8-11

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	603	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	713	EMERGENCY LIGHT OUT		X						FBC 423.17.1

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0016

FACILITY: ORANGE PARK JUNIOR HIGH SCHOOL
2750 MOODY ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: DECEMBER 1, 2011

INSPECTOR'S SIGNATURE:  DATE: 12-1-11

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	507	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	505	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	503	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	710	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	702	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	702	MATERIAL STORED TOO CLOSE TO CEILING		X						NFPA 1 12.1

