

FISCAL YEAR 2011-2012

FIRE SAFETY INSPECTION REPORT

FOR EDUCATIONAL FACILITIES

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT CLAY FACILITY 0047

FACILITY: COPPERGATE ELEMENTARY SCHOOL
2250 COUNTY ROAD NORTH
MIDDLEBURG, FLORIDA 32043

INSPECTION DATE: JANUARY 4, 2012

Ed Sweetland

INSPECTOR'S SIGNATURE

1-4-12

DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
		NO FIRE VIOLATIONS								

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL
4425 LAKESHORE DRIVE
FLEMING ISLAND, FLORIDA 32043

INSPECTION DATE: JANUARY 9, 2012

[Signature]
INSPECTOR'S SIGNATURE

1-9-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	601	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	604	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	605	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	606	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	800	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	804	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	812	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	830	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	832	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	903	EMERGENCY LIGHT OUT	X							NFPA 101.7.9
92	909	EMERGENCY LIGHT OUT	X							NFPA 101.7.9

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 6

DISTRICT: CLAY FACILITY: 0005

FACILITY: GROVE PARK ELEMENTARY SCHOOL
1643 MILLER STREET
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 11, 2012

[Signature]
INSPECTOR'S SIGNATURE DATE: 1-11-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
7	702	NO EVACUATION SHEET		X						FBC 423.14.2.4
7	704	NO EVACUATION SHEET		X						FBC 423.14.2.4
7	708	NO EVACUATION SHEET		X						FBC 423.14.2.4

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 6

DISTRICT CLAY FACILITY 0005

FACILITY: GROVE PARK ELEMENTARY SCHOOL
1643 MILLER STREET
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 11, 2012

INSPECTOR'S SIGNATURE [Signature] DATE 1-11-12

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	31	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	501	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	524	EMERGENCY LIGHT OUT		X						FBC 423.17.1

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT CLAY FACILITY 0010

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL
335 S. PECAN STREET
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 13, 2012

Tom Swanson
INSPECTOR'S SIGNATURE

1-13-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	OK	X							FBC 423.17.1
92	701	OK								
92	702	OK								
92	703	OK								
92	704	OK								
92	705	OK								
92	706	OK								
92	707	OK								
92	708	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	710	OK								
92	713	OK								

FISCAL YEAR 2011-2012

FIRE SAFETY INSPECTION REPORT

FOR EDUCATIONAL FACILITIES

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT: CLAY FACILITY: 0010

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL

335 S. PECAN STREET

KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 13, 2012

[Signature]

INSPECTOR'S SIGNATURE

1-13-12

DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Gited	Scheduled for Correction	Rule
92	714	OK								
92	715	OK								
92	716	OK								
92	717	OK								
92	718	OK								
92	719	OK								
92	720	OK								
92	721	OK								
92	722	OK								
92	724	REPLACE BOARDS ON RAMP	X							
92	750	OK								

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT CLAY FACILITY 0010

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL
335 S. PECAN STREET
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 13, 2012

John W. Carter
INSPECTOR'S SIGNATURE

1-13-12
DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I/S"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	751	OK	X							
92	760	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	770	OK								
92	771	OK								
92	772	OK								
92	773	OK								

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 4

DISTRICT CLAY FACILITY 0023

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2012

[Signature]

INSPECTOR'S SIGNATURE

1-17-12

DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "G"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	13	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	43	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	48	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	74	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	85	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	86	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	89	EMERGENCY LIGHT OUT		X						FBC 423.17.1

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

INSPECTION DATE: JANUARY 19, 2012
 INSPECTOR'S SIGNATURE: [Signature]
 DATE: 1-19-12

DISTRICT CLAY FACILITY 0015

FACILITY: LAKESIDE ELEMENTARY SCHOOL
2752 MOODY AVENUE
ORANGE PARK, FLORIDA 32073

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	105	EMERGENCY LIGHT OUT	X							FBC 423.17.1
2	137	GAS & GAS EQUIPMENT STORED INSIDE		X						NEPA 1-2113-3.5
2	142	EMERGENCY LIGHT OUT	X							FBC 423.17.1
8	804B	REMOVE STORED MATERIALS		X						NFPA 70

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT CLAY FACILITY 0041

FACILITY: M CRAE ELEMENTARY SCHOOL
6770 CPIMTU RPAD 315C
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 24, 2012

[Signature]
INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I,S"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	102	EXIT LIGHT OUT	X							FBC 1016.3.1
2	212	PIANO BLOCKING EXIT		X						FBC 423.20.1
2	203	SPRINKLER CERTIFICATE OUT OF STATE	X							69A-58.008
5	514	NO EVACUATION SHEET		X						FBC 423.14.2.4
6	625	NO EVACUATION SHEET		X						FBC 423.14.2.4

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT CLAY FACILITY 0024

FACILITY: ROBERT M. PATERSON ELEMENTARY SCHOOL
5400 PINE AVENUE
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 2, 2012

INSPECTOR'S SIGNATURE:  DATE 2-2-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I,S"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	146	FILE CABINET BLOCKING EXIT		X						FBC 423.20.1
2	208	FIRE SPRINKLER BELL NOT WIRED	X							NFPA 70.110.12
2	208	REMOVE GAS BOTTLES		X						NFPA 1.21.3.3.5
4	408	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**


ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT CLAY FACILITY 0024

FACILITY: ROBERT M. PATERSON ELEMENTARY SCHOOL
5400 PINE AVENUE
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 2, 2012


INSPECTOR'S SIGNATURE

2-2-12
DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	8	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	24	EMERGENCY LIGHT OUT	X							FBC 423.17.1

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT CLAY FACILITY 0043

FACILITY: RIDEOUT ELEMENTARY SCHOOL
3065 APALACHICOLA BOULEVARD
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 6, 2012

Tom Wheatford
INSPECTOR'S SIGNATURE

2-6-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	12	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
92	14	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4

FISCAL YEAR 2011-2012

FIRE SAFETY INSPECTION REPORT

FOR EDUCATIONAL FACILITIES

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT: CLAY FACILITY: 0020

FACILITY: RIDGEVIEW ELEMENTARY SCHOOL
421 JEFFERSON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: FEBRUARY 6, 2012

Tom Sweetland

2-6-12

INSPECTOR'S SIGNATURE _____ DATE _____

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	121	EXIT LIGHT OUT		X						FBC 1016.3
2	208	EXIT LIGHT OUT		X						FBC 1016.3
6	611	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
7	703	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT CLAY FACILITY 0053

FACILITY: SWIMMING PEN CREEK ELEMENTARY SCHOOL
1630 WOODPECKER LANE
MIDDLEBURG, FLORIDA 32073

INSPECTION DATE: FEBRUARY 14, 2012

Carl McArthur
INSPECTOR'S SIGNATURE 2-14-12
DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint. (M)	Oper. (O)	Fac. (F)	Info. Serv. (I.S.)	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
		NO DEFICIENCIES IN PERMANENT BUILDINGS								

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT CLAY FACILITY 0053

FACILITY: SWIMMING PEN CREEK ELEMENTARY SCHOOL
1630 WOODPECKER LANE
MIDDLEBURG, FLORIDA 32073

INSPECTION DATE: FEBRUARY 14, 2012

Todd Sweetland
INSPECTOR'S SIGNATURE 2-14-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "F"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	701	EMERGENCY LIGHT OUT	X							FBC 423.14.2.4
92	705	EMERGENCY LIGHT OUT	X							FBC 423.14.2.4
92	803	EXCESSIVE COMBUSTIBLES ON WALLS		X						NFPA 70 110.28

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES**

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT CLAY FACILITY 0063

FACILITY: SWIMMING PEN CREEK ELEMENTARY SCHOOL
1630 WOODPECKER LANE
MIDDLEBURG, FLORIDA 32073

INSPECTION DATE: FEBRUARY 14, 2012

[Signature]
INSPECTOR'S SIGNATURE DATE 2-14-12

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "G"	Info. Serv. "I;S"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
		NO DEFICIENCIES IN PERMANENT BUILDINGS								

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT CLAY FACILITY 0053

FACILITY: SWIMMING PEN CREEK ELEMENTARY SCHOOL
1630 WOODPECKER LANE
MIDDLEBURG, FLORIDA 32073

INSPECTION DATE: FEBRUARY 14, 2012

John Sweetland
INSPECTOR'S SIGNATURE

2-14-12
DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "G"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	701	EMERGENCY LIGHT OUT	X							FBC 423.14.2.4
92	705	EMERGENCY LIGHT OUT	X							FBC 423.14.2.4
92	803	EXCESSIVE COMBUSTIBLES ON WALLS		X						NFPA 70 110.28
92	810	EMERGENCY LIGHT OUT	X							FBC 423.14.2.4

FISCAL YEAR 2011-2012

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58**

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 6

DISTRICT CLAY FACILITY 0006

FACILITY: W. E. CHERRY ELEMENTARY SCHOOL
420 EDSON DRIVE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: FEBRUARY 21, 2012

[Signature]
INSPECTOR'S SIGNATURE DATE 5/21/12

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
		NO DEFICIENCIES FOUND								

FISCAL YEAR 2011-2012

FIRE SAFETY INSPECTION REPORT

FOR EDUCATIONAL FACILITIES

FLORIDA STATUTES 1013.12, 1013.20 & RULE 69A-58

ANNUAL PERMANENT INSPECTION ANNUAL RELOCATABLE INSPECTION

FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 5

DISTRICT CLAY FACILITY 0026

FACILITY: WILKINSON ELEMENTARY SCHOOL
4966 C. R. 218
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: MARCH 3, 2012

[Signature]
 INSPECTOR'S SIGNATURE
 DATE 3-3-12

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	5	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	22	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	31	EMERGENCY LIGHT OUT		X						FBC 423.17.1