

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0023



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2012

Tom Swanton 1-17-12
INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. 'M'	Oper. 'O'	Fac. 'C'	Info. Serv. 'I.S.'	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
5		OK								
6		OK								
7		OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0023

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2012

Carl Sweetland
INSPECTOR'S SIGNATURE

1-17-12
DATE



Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	9	OK								
92	10	OK								
92	11	OK								
92	12	OK								
92	14	OK								
92	15	OK								
92	16	OK								
92	18	OK								
92	39A	OK								
92	39B	OK								
92	40	OK								
92	42	OK								
92	44	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0023

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2012

[Handwritten Signature]
 INSPECTOR'S SIGNATURE

1-17-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	45	OK								
92	46	OK								
92	69A	OK								
92	69B	OK								
92	71	OK								
92	72	OK								
92	70	OK - RESTROOM								
92	13	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	41	OUT OF SERVICE								
92	43	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	48	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	73	OK								
92	75	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0023

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
 2901 SANDRIDGE ROAD
 ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2012

Ted Swanton
 INSPECTOR'S SIGNATURE DATE 1-17-12



COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	76	OK								
92	77	OK								
92	79A	OK								
92	79B	OK								
92	80	OK								
92	84	OK								
92	88	OK								
92	90	OK								
92	91	OK								
92	93	OK								
92	94	OK								
92	95	OK								
92	96	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0023

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL
2901 SANDRIDGE ROAD
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 17, 2012

Todd Swettow
INSPECTOR'S SIGNATURE 1-17-12
DATE



Building	Room	Deficiency Description and Corrective Action Required:	Maint "M"	Oper "O"	Fac "C"	Info Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	81	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	74	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	82	EMERGENCY LIGHT VERY WEAK		X						FBC 423.17.1
92	85	EMERGENCY LIGHT OUT - GIRLS RESTROOM		X						FBC 423.17.1
92	86	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	87	BASEBOARD COMING OFF WALL BEHIND TOILET	X							FBC 423.28
92	89	EMERGENCY LIGHT OUT		X						FBC 423.17.1

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0015

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: LAKESIDE ELEMENTARY SCHOOL
2752 MOODY AVENUE
ORANGE PARK, FLORIDA 32073



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: JANUARY 19, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

1-19-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	105	EMERGENCY LIGHT OUT	X							FBC 423.17.1
2	137	GAS & GAS EQUIPMENT STORED INSIDE		X						NFPA 1:21.3.3.5
2	142	EMERGENCY LIGHT OUT	X							FBC 423.17.1
4		OK								
5		OK								
6		OK								
7		OK								
8	804B	REMOVE STORED MATERIALS		X						

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0015

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: LAKESIDE ELEMENTARY SCHOOL
2752 MOODY AVENUE
ORANGE PARK, FLORIDA 32073



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: JANUARY 19, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

1-19-12
DATE


Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	10	OK								
92	11	OK								
92	12	OK								
92	13	OK								
92	14	OK								
92	15	OK								
92	16	OK								
92	17	PROJECTOR OUTLET ABOVE CEILING			X					NFPA 70 110.12
92	18	OK								
92	19	EMERGENCY LIGHT OUT	X							FBG 423.17.1
92	20	OK								
92	21	OK								
92	22	PROJECTOR OUTLET ABOVE CEILING			X					NFPA 70 110.12

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0015

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: LAKESIDE ELEMENTARY SCHOOL
2752 MOODY AVENUE
ORANGE PARK, FLORIDA 32073



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: JANUARY 19, 2012


[Handwritten Signature]
INSPECTOR'S SIGNATURE

1-19-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. 'M'	Oper. 'O'	Fac. 'C'	Info. Serv. 'I.S.'	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	23	OK								
92	24	OK								
92	25	OK								
92	26	OK								
92	27	OK								
92	42	OK								
92	43	OK								
92	44	OK								
92	45	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	46	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	47	RAMP EXCEEDS 1-12 SLOPE	X							FBC 11.4.8
92	48	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0015



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKESIDE ELEMENTARY SCHOOL
2752 MOODY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 19, 2012

[Signature]
INSPECTOR'S SIGNATURE

1-19-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Pac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	51	OK								
92	52	OK								
92	53	OK								
92	54	OK								
92	55	OK								
92	56	OK								
92	57	OK								
92	58	OK								
92	59	OK								
92	60	OK								
92	61	OK								
92	62	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0041

COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT

FACILITY: MCRAE ELEMENTARY SCHOOL
6770 COUNTY ROAD 315C
KEYSTONE HEIGHTS, FLORIDA 32656



STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

INSPECTION DATE: JANUARY 24, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

1-24-12
DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	102	EXIT LIGHT OUT	X							FBC 1016.3.1
2	212	PIANO BLOCKING EXIT		X						FBC 423.20.1
2	203	SPRINKLER CERTIFICATE OUT OF DATE	X							69A-58.008
3		OK								
5	514	NO EVACUATION SHEET		X						FBC 423.14.2.4
6	625	NO EVACUATION SHEET		X						FBC 423.14.2.4

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0041



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: MCRAE ELEMENTARY SCHOOL
6770 COUNTY ROAD 315C
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 24, 2012

[Handwritten Signature]

INSPECTOR'S SIGNATURE

1-24-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	401	OK								
92	402	OK								
92	403	OK								
92	404	OK								
92	405	OUT OF SERVICE								
92	406	OK								
92	407	OK								
92	408	OK								
92	701	OK								
92	702	OK								
92	703	OK								
92	704	OK								
92	705	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0041



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: MCRAE ELEMENTARY SCHOOL
6770 COUNTY ROAD 315C
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 24, 2012

[Signature]
INSPECTOR'S SIGNATURE

1-24-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. 'M'	Oper. 'O'	Fac. 'C'	Info. Serv. 'I.S.'	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	706	OK								
92	707	OK								
92	708	OK								
92	801	OK								
92	802	OK								
92	803	OK								
92	804	OK								
92	806	OK								
92	821	OK								
92	823	OK								
92	824	OK								
92	825	OK								
92	826	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0041

FACILITY: MCRAE ELEMENTARY SCHOOL
6770 COUNTY ROAD 315C
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: JANUARY 24, 2012

[Handwritten Signature]
 INSPECTOR'S SIGNATURE

1-24-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	827	OK								
92	828	OK								
92	842	OK								



FISCAL YEAR 2011-2012

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY: 0009

FACILITY: MIDDLEBURG ELEMENTARY SCHOOL
3958 MAIN STREET
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 23, 2012

[Signature]
INSPECTOR'S SIGNATURE

1-23-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def/ Cited	Scheduled for Correction	Rule
1		OK - UNDER CONSTRUCTION; WILL BE FINISHED 1/27/12								
2		OK								
3		OK								
4		OK								
6		OK								
7	85	LENSE COVER MISSING		X						NFPA 70 401.3
9	116	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12



FISCAL YEAR 2011-2012

**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY: 0009

FACILITY: MIDDLEBURG ELEMENTARY SCHOOL
3958 MAIN STREET
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 23, 2012

[Signature]
 INSPECTOR'S SIGNATURE

1-23-12
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	23	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	24	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	25	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	35	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	37	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	38	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	39	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	41	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	42	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	57	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	64A	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	64B	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12



FISCAL YEAR 2011-2012

COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101

DISTRICT: CLAY FACILITY: 0009

FACILITY: MIDDLEBURG ELEMENTARY SCHOOL
3958 MAIN STREET
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: JANUARY 23, 2012

[Signature]
 INSPECTOR'S SIGNATURE

1-23-12
 DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	66	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	67	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	68	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	69	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	26A	TWO PROJECTORS WITH PLUG ABOVE CEILING			X					NFPA 70 110.12
92	26B	TWO PROJECTORS WITH PLUG ABOVE CEILING			X					NFPA 70 110.12
92	29A	TWO PROJECTORS WITH PLUG ABOVE CEILING			X					NFPA 70 110.12
92	29B	TWO PROJECTORS WITH PLUG ABOVE CEILING			X					NFPA 70 110.12
92	40	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12
92	43	PROJECTOR PLUG ABOVE CEILING			X					NFPA 70 110.12

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0019



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: MONTCLAIR ELEMENTARY SCHOOL
2398 MOODY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 25, 2012

[Signature]
INSPECTOR'S SIGNATURE

1-25-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
4		OK								
5		OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0019



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: MONTCLAIR ELEMENTARY SCHOOL
2398 MOODY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 25, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

1-25-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. 'M'	Oper. 'O'	Fac. 'C'	Info. Serv. 'I.S.'	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
96	836	OK - RESTROOM								
92	21	OK								
92	22	OK								
92	23	OK								
92	24	OK								
92	25	OK								
92	26	OK								
92	27	OK								
92	28	OK								
92	29	OK								
92	30	OK								
92	31	OK								
92	32	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0019

FACILITY: MONTCLAIR ELEMENTARY SCHOOL
2398 MOODY AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 25, 2012

[Handwritten Signature]
 INSPECTOR'S SIGNATURE

1-25-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required	Maint. 'M'	Oper. 'O'	Pac. 'C'	Info. Serv. 'I.S.'	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	33	OK								
92	34	OK								
92	35	OK								
92	36	OK								
92	37	OK								
92	38	OK								
92	39	OK								
92	40	OK								
92	41	OK								
92	42	OK								
92	44	OK								
92	45	OK								
92	46A/B	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0049



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: OAKLEAF VILLAGE ELEMENTARY SCHOOL
410 OAKLEAF VILLAGE PARKWAY
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: JANUARY 27, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

1-27-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
20		FIRE SPRINKLER BELL NOT WIRED	X							NFPA 101

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0049



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: OAKLEAF VILLAGE ELEMENTARY SCHOOL
410 OAKLEAF VILLAGE PARKWAY
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: JANUARY 27, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

1-27-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "IS"	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	908	OK								
92	909	OK								
92	910	OK								
92	911	OK								
92	912	OK								
92	913	OK								
92	914	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0004



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: ORANGE PARK ELEMENTARY SCHOOL
1401 PLAINFIELD AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 30, 2012

Ted Sweatt 1-30-12
INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
3		OK								
4		OK								
5		OK								
7		OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0004



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: ORANGE PARK ELEMENTARY SCHOOL
1401 PLAINFIELD AVENUE
ORANGE PARK, FLORIDA 32073


INSPECTION DATE: JANUARY 30, 2012

Ted Sweetland 1-30-12
INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	21	EMERGENCY LIGHT OUT		X						FBC 423.17.1
92	22	OK								
92	23	OK								
92	24	OK								
92	34	OK								
92	35	OK								
92	36	OK								
92	37	OK								
92	38	OK								
92	39A	OK								
92	39B	OK								
92	41	OK								
92	42	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0004



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: ORANGE PARK ELEMENTARY SCHOOL
1401 PLAINFIELD AVENUE
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: JANUARY 30, 2012

Ted Sweetman
INSPECTOR'S SIGNATURE 1-30-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	43	OK								
92	44	OK								
92	45	OK								
92	50	OK								
92	51	OK								
92	52	OK								
92	53	OK								
92	54	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0051



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: PLANTATION OAKS ELEMENTARY SCHOOL
4150 PLANTATION OAKS BOULEVARD
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: JANUARY 31, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

1-31-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def Cited	Scheduled for Correction	Rule
1	514	STAINED CEILING TILE		X						
1	603	STAINED CEILING TILE		X						

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0024



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: ROBERT M. PATERSON ELEMENTARY SCHOOL
5400 PINE AVENUE
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 2, 2012

[Signature]
INSPECTOR'S SIGNATURE 2-2-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	146	FILE CABINET BLOCKING EXIT		X						FBC 423.20.1
2	208	FIRE SPRINKLER BELL NOT WIRED	X							NFPA 70 110.12
2	208	REMOVE GAS BOTTLES		X						NFPA 1.21.3.3.5
3		OK								
4	408	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
5		OK								
6		OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0024



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: ROBERT M. PATERSON ELEMENTARY SCHOOL
5400 PINE AVENUE
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 2, 2012

Tom Sweatt 2-2-12
INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	OK								
92	2	OK								
92	3	OK								
92	4	OK								
92	5	OK								
92	6	OK								
92	8	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	11	OK								
92	12	OK								
92	13	OK								
92	14	OK								
92	15	OK								
92	16	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0024



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: ROBERT M. PATERSON ELEMENTARY SCHOOL
5400 PINE AVENUE
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 2, 2012

[Handwritten Signature]
INSPECTOR'S SIGNATURE

2-2-12
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	18	OK								
92	21	OK								
92	22	OK								
92	23	OK								
92	24	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	25	OK								
92	26	OK								
92	27	OK								
92	28	OK								
92	41	OK								
92	42	OK								
92	43	OK								
92	44	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0024

FACILITY: ROBERT M. PATERSON ELEMENTARY SCHOOL
5400 PINE AVENUE
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 2, 2012

Tom Sweetman
 INSPECTOR'S SIGNATURE 2-2-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	45	OK								
92	46	OK								
92	47	OK								
92	48	OK								
92	49	OK								
92	50	OK								
92	51	OK								
92	52	OK								
92	53	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0043

FACILITY: RIDEOUT ELEMENTARY SCHOOL
3065 APALACHICOLA BOULEVARD
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 6, 2012

Ted Sweetland
 INSPECTOR'S SIGNATURE 2-6-12
DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	113	OUTLET COVER MISSING AT TV OUTLET		X						NFPA 70-110
		BALLFIELDS & DUGOUTS • FENCE INSTALLED IMPROPERL • ROOFS NOT FINISHED			X					

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0043

FACILITY: RIDEOUT ELEMENTARY SCHOOL
3065 APALACHICOLA BOULEVARD
MIDDLEBURG, FLORIDA 32068

INSPECTION DATE: FEBRUARY 6, 2012

Ted Sweetland
 INSPECTOR'S SIGNATURE 2-6-12
DATE




**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	10	OK								
92	11	OK								
92	13	OK								
92	20	OK								
92	21	OK								
92	22	OK								
92	23	OK								
92	24	OK								
92	25	OK								
92	12	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
92	14	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0020



**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: RIDGEVIEW ELEMENTARY SCHOOL
421 JEFFERSON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: FEBRUARY 6, 2012

Tod Sweetland 2-6-12
INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Gited	Scheduled for Correction	Rule
1	121	EXIT LIGHT OUT		X						FBC 1016.3
1	102	FIRE ALARM CERTIFICATE OUT OF DATE 7/2010	X							NFPA 72-10.6.2
2	208	EXIT LIGHT OUT		X						FBC 1016.3
3		OK								
6	622	BANNERS BLOCK EXIT LIGHTS - MOVE TO EDGE OF HALL OR REMOVE								
6	623	MAINTAIN 6 FT HALL - REMOVE DESK		X						
6	611	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
7	703	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0020

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: RIDGEVIEW ELEMENTARY SCHOOL
421 JEFFERSON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: FEBRUARY 6, 2012

Ted Sweetener
INSPECTOR'S SIGNATURE

2-6-12
DATE




Building	Room	Deficiency Description and Corrective Action Required:	Maint "M"	Oper. "O"	Fac "C"	Info. Serv. "I.S."	Cost	No. of times Def Cited	Scheduled for Correction	Rule
92	711A	OK								
92	711B	OK								
92	712	OK								
92	714	OK								
92	718	OK								
92	728	OK								
92	729	OK								
92	730	OK								
92	731	OK								
92	732	OK								
92	733	OK								
92	734	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0020

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT**

FACILITY: RIDGEVIEW ELEMENTARY SCHOOL
421 JEFFERSON AVENUE
ORANGE PARK, FLORIDA 32065



**STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

INSPECTION DATE: FEBRUARY 6, 2012

Ted Swettone 2-6-12
INSPECTOR'S SIGNATURE DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	735	OK								
92	737	OK								
92	741	OK								
92	743	OK								
92	715	OUTLET ABOVE CEILING TO PROJECTOR		X						NFPA 70-110
92	713	OK								
92	716	OK								
92	736	OK								
92	742	OUT OF SERVICE								
92	717	RAMP OUT OF LEVEL - BOARD BROKEN	X							FBG 1013.3.7
92	744	OK								
92	745	OK								

FISCAL YEAR 2011-2012


DISTRICT: CLAY FACILITY: 0020

**COMPREHENSIVE SAFETY & SANITATION
INSPECTION REPORT
STATE BOARD OF EDUCATION
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
"CASUALTY SAFETY & SANITATION INSPECTION"
IN COMPLIANCE WITH
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: RIDGEVIEW ELEMENTARY SCHOOL
421 JEFFERSON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: FEBRUARY 6, 2012

Tod Sweetland
INSPECTOR'S SIGNATURE 2-6-12
DATE



Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	746	OK								
92	748	OK								
92	749	OK								
92	750	OK								
92	751	OK								
92	752	OK								
92	754	OK								
92	756	OK								
92	758	OK								
92	759	OK								
92	760	OK								
92	738	OK								

FISCAL YEAR 2011-2012

DISTRICT: CLAY FACILITY: 0020

FACILITY: RIDGEVIEW ELEMENTARY SCHOOL
421 JEFFERSON AVENUE
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: FEBRUARY 6, 2012

Ted Sweetman
 INSPECTOR'S SIGNATURE 2-6-12
 DATE



**COMPREHENSIVE SAFETY & SANITATION
 INSPECTION REPORT
 STATE BOARD OF EDUCATION
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5
 "CASUALTY SAFETY & SANITATION INSPECTION"
 IN COMPLIANCE WITH
 F.S. 1013.12, 1013.20 & NFPA 101**

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "G"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	747	OK								
92	753	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
92	755	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
92	757	NO ROOM NUMBER		X						FBC 423.14.2.3
92	757	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	772	LENSE COVER MISSING		X						NFPA 70-110