


**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0013

FACILITY: CLAY HIGH SCHOOL  
2025 HIGHWAY 16 WEST  
GREEN COVE SPRINGS, FLORIDA 320643

INSPECTION DATE: FEBRUARY 4, 2010

*[Signature]*  
INSPECTOR'S SIGNATURE

*[Signature]*  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
3A		OK								
3B	303	NO EVACUATION SHEET		X						FBC 423.14.2.4
3C	340	EXIT LIGHT OUT	X							FBC 1006.3.1
4	401	EXIT LIGHT OUT	X							FBC 1006.3.1
4	401	NO COVER ON LIGHT	X							NFPA 70
5	510B	EXIT LIGHT OUT	X							FBC 1006.3.1
6	601	ROOF LEAK	X							
7A	702	NO EVACUATION SHEET	X							FBC 423.14.2.4
7A	706	NO EVACUATION SHEET	X							FBC 423.14.2.4
11	1104	BROKEN OUTLET COVERS	X							NFPA 70
11	1114	BROKEN OUTLET COVERS	X							NFPA 70
11	1124	MISSING OUTLET COVERS	X							NFPA 70

**FISCAL YEAR 2009-2010**


**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0013

FACILITY: CLAY HIGH SCHOOL  
2025 HIGHWAY 16 WEST  
GREEN COVE SPRINGS, FLORIDA 320643

INSPECTION DATE: FEBRUARY 4, 2010

INSPECTOR'S SIGNATURE:  DATE: 2-4-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	5A&B	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	7	OK								
92	8	OK								
92	17	OK								
92	18	OK								
92	19	OK								
92	20	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	31	OK								
92	32	OK								
92	33	OK								
92	41	OK								
92	42	OK								
92	43	OK								
92	44	OK								

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL  
2233 VILLAGE SQUARE PARKWAY  
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 16, 2010

*[Signature]*  
INSPECTOR'S SIGNATURE DATE 2-16-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1A	57	EXIT LIGHT OUT	X							FBC 1006.3.1
1C	001	EXIT LIGHT OUT	X							FBC 1006.3.1
1D	130	TILE ON FLOOR MISSING	X							FBC 804.2.3
1E	168	MOLD ON CEILING		X						FBC 804.2.3
1	140	CEILING TILES STAINED		X						FBC 804.2.3
1	141	WATER PENETRATION @ EXIT DOORS WETTING WOOD FLOOR	X							
2	205	MOLD ON CEILING TILE		X						FBC 804.2.3
2	205	LIGHT FIXTURES BROKEN	X							FBC 1006.3.1
2	206	STAINED CEILING TILE		X						FBC 804.2.3
2	205	SIGNAGE MISSING @ ENTRANCE	X							
2	207	SIGNAGE MISSING @ ENTRANCE	X							
2	207	LIGHT FIXTURE BROKEN	X							FBC 1006.3.1
2	228	CONDENSATION PROBLEM	X							

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL  
2233 VILLAGE SQUARE PARKWAY  
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 16, 2010

INSPECTOR'S SIGNATURE: *[Signature]*  
DATE: 2/16/10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
10		SIGN @ PARKING LOT FOR HANDICAP RAMP - "DO NOT BLOCK" SOUTH BUS LOT	X							
10	681	EXIT LIGHT OUT	X							FBC 1006.3.1
10	1019	MOVE EXIT LIGHT TO 1019 B	X							
31	005	REST @ EXTERIOR DOOR FRAME	X							

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL  
2233 VILLAGE SQUARE PARKWAY  
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 16, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 2-16-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	10	OK								
92	11	OK								
92	12	OK								
92	13	OK								
92	14	RAMP EXCEEDS 1/12 SLOPE	X							FBC 11.4.8
92	14	HOLE IN SIDING EAST SIDE	X							
92	15	OK								
92	20	OK								
92	21	OK								
92	22	NO EVACUATION SHEET		X						FBC 423.14.2.4
92	23	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	24	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	24	RAMP EXCEEDS 1/12 SLOPE	X							FBC 11.4.8

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL  
2233 VILLAGE SQUARE PARKWAY  
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 16, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: *2/16/10*

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	25	OK								
92	30	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	30	NO EVACUATION SHEET	X	X						FBC 423.14.2.4
92	31	RAMP EXCEEDS 1/12 SLOPE	X					3	3	FBC 11.4.8
92	32	RAMP EXCEEDS 1/12 SLOPE	X						3	FBC 11.4.8
92	33	EMERGENCY LIGHT OUT								FBC 423.17.1
92	34	RAMP EXCEEDS 1/12 SLOPE	X						3	FBC 423.17.1
92	35	OK								
92	40	OK								
92	41	RAMP EXCEEDS 1/12 SLOPE	X						3	FBC 11.4.8
92	42	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	43	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	44	EMERGENCY LIGHT OUT	X							FBC 423.17.1

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL  
2233 VILLAGE SQUARE PARKWAY  
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 16, 2010

INSPECTOR'S SIGNATURE: *[Signature]*

DATE: 2/16/10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	45	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	46	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	47	RAMP EXCEEDS 1/12 SLOPE	X							FBC 11.4.8
92	48	OK								
92	49	THERMOSTAT COVER BROKEN	X							
92	50	OK								
92	51	EXTENSION CORD RUNS THROUGH CEILING		X						NFPA 110.26
92	52	EXTENSION CORD RUNS THROUGH CEILING		X						NFPA 110.26
92	53	OK								
92	60	OK								
92	61	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	62	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	62	EXTENSION CORD THROUGH CEILING		X						NFPA 110.26

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL  
2233 VILLAGE SQUARE PARKWAY  
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 16, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 2-16-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	63	OK								
92	64	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	70	OK								
92	71	THRESHOLD MISSING @ RAMP DOOR	X							
92	72	OK								
92	73	DOOR BLOCKED BY DESK		X						FBC 423.20.1
92	80	OK								
92	81	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	82	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	83	OK								
92	84	OK								
92	85	OK								
92	86	EXIT LIGHTS MISSING	X							FBC 423.17.1



**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"**

**IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL  
2233 VILLAGE SQUARE PARKWAY  
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: FEBRUARY 16, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 2/16/10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	87	EMERGENCY LIGHT OUT	X							FBC 423.17.1
92	90	OK								
92	91	RAMP EXCEEDS 1/12 SLOPE	X					3		FBC 11.4.8
92	92	RAMP EXCEEDS 1/12 SLOPE	X					3		FBC 11.4.8
92	92	OK								
92	94	OK								
92	95	OK								
92	96	OK								
92	97	OK								

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL  
2900 S.W. ORCHID AVENUE  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: FEBRUARY 18, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 2/18/10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	143	CEILING TILES FALLING		X						
1	192	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205
2	68	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205
4	406	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205
4	410	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205
4	401	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205
4	401	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205
5	510B	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205
6		OK		X						69A-58.1205
7		EROSION UNDER SIDEWALK	X							
8	803	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205
9		OK								
18		OK								
20	17	OUTLET COVER BROKEN		X						69A-58



**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL  
2900 S.W. ORCHID AVENUE  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: FEBRUARY 18, 2010

INSPECTOR'S SIGNATURE: [Signature] DATE: 2/18/10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	1	OK								
92	2	OK								
92	3	OK								
92	4	OK								
92	5	EXTEND CONCRETE RAMP	X							
92	6	OK								
92	7	OK								
92	11	FILING CABINET IN FRONT OF ELECTRICAL		X						69A-58.801
92	12	OK								
92	13	OK								
92	14	OK								
92	15	OK								
92	16	OK								
92	17	OK								

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL  
2900 S.W. ORCHID AVENUE  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: FEBRUARY 18, 2010

INSPECTOR'S SIGNATURE: [Signature] DATE: 2/18/10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	18	OK								
92	19	OK								
92	20	RAMP IN POOR CONDITION - WOOD		X						
92	21	OK								
92	22	OK								
92	23	ELECTRICAL PANEL & KNOCKOUTS MISSING	X							69A-58.809
92	23	COMPUTER & PHONE LINES HUNG OVER DOOR				X				
92	24	OK								
92	25	OK								
92	26	OK								
92	27	OK								
92	28	OK								
92	29	OK								
92	30	OK								

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION"  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL  
2900 S.W. ORCHID AVENUE  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: FEBRUARY 18, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: *2/18/10*

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	50	OK								
92	51	OK								
92	52	OK								
92	53	OK								
92	54	ELECTRICAL PANEL BLOCKED BY BOOKSHELF		X						69A-58.801
92	55	COMPUTER CABLE RUN ON CANOPY FROM ROOM 57				X				
92	56	OK								
92	57	OK								
92	58	OK								
92	59	OK								
92	60	OK								
92	61	IMPROPER USE OF POWER STRIP & EXTENSION CORDS	X							69A-58.804
92	62	OK								
92	63	OK								

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0011

FACILITY: KEYSTONE HEIGHTS HIGH SCHOOL  
2900 S.W. ORCHID AVENUE  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: FEBRUARY 18, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 2/18/10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	64	OK								
92	65	OK								
92	72	OK								
92	74	OK								
92	76	OK								
92	78	OK								
92	80	COMPUTER CABLE RUN ON GROUND BEHIND BUILDING AND HUNG ON FENCE				X				
92	82	BULB OUT EMERGENCY LIGHT BY STAIRS		X						69A-58.204
92	84	RAMP DOOR STICKS		X						69A-58.299
92	90	OK								
92	91	OK								

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT CLAY FACILITY # 0007

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: MARCH 24, 2010

*[Signature]*  
INSPECTOR'S SIGNATURE

3-24-10  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	101	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	112	CEILING OPEN	X							
1	112	EXPOSED WIRES @ CLOCK OUTLET	X							NFPA 70
1	113	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	115	MOLD ON CEILING		X						FBC 804.2.3
1	109	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	110	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	111	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	118	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	121	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	100	CEILING FALLING @ ROOM 119	X							
1	117	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	128	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	129	NO EVACUATION SHEET		X						FBC 423.14.2.4



**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0007

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: MARCH 24, 2010

*Ed Weather*  
INSPECTOR'S SIGNATURE

3-24-10  
DATE

Building	Ro13 00m	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	130	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	203	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	203	CEILING TILE OUT		X						FBC 804.2.3
1	212	CEILING TILE STAINED & FALLING		X						FBC 804.2.3
1	213	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	214	PROJETOR NOT INSTALLED PROPERLY	X							
1	216	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	220	CEILING TILE OUT		X						FBC 804.2.3
1	224	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	800	CEILING TILE MOLD BY ROOM 223A		X						FBC 804.2.3
1	231	NO EVACUATION SHEET		X						FBC 423.14.2.4
1	9	LENS MISSING ON LIGHT	X	X						NFPA 708 401.3
2	225	PROJECTOR NOT INSTALLED PROPERLY	X							
4	5H	EXIT LIGHT OUT	X							FBC 423.17.1

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0007

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: MARCH 24, 2010

*Ed Swettenham*  
INSPECTOR'S SIGNATURE

3-24-10

DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
4	13	LIGHT SWITCH NOT SECURE	X							NFPA 70
4	17	LIGHT BULBS EXPOSED	X							NFPA 70
4	21A	STAINED CEILING TILES		X						FBC 804.2.3
4	21A	ROOF LEAK	X							
4	21A	LENS MISSING ON LIGHT	X							FBC 1006.3.1
10	124	MOLD ON CEILING		X						FBC 804.2.3
10	124	CEILING TILE MISSING		X						FBC 804.2.3
12	141	NO EVACUATION SHEET		X						FBC 423.14.2.4
12	153	EXIT LIGHT OUT		X						FBC 1006.3.1
17B	2	NO EVACUATION SHEET		X						FBC 423.14.2.4
22	4	NO EVACUATION SHEET		X						FBC 423.14.2.4
22	5	NO EVACUATION SHEET		X						FBC 423.14.2.4
24	1	OUTLET BROKEN		X						NFPA 10.4.1
24	5	CEILING TILE MISSING		X						FBC 804.2.3

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0007

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: MARCH 24, 2010

*[Signature]*  
INSPECTOR'S SIGNATURE

3-24-10

DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
24	14	CEILING TILE MISSING		X						FBC 804.2.3
24	28	BROKEN OUTLET COVER		X						NFPA 70
24	32	CEILING TILE OUT		X						FBC 804.2.3
24	34	CEILING TILE OUT		X						FBC 804.2.3
27	2	FLOURESCENT BULBS NOT PROTECTED		X						NFPA 708 401.3
27	1	CEILING J-BOX MISSING	X							NFPA 70
31		BUILDING NUMBER - FLAMABLE STORAGE SIGN ON EXTERIOR		X						
51	2	FIRE ALARM EXP. JAN. 2010, LAST INSPECTION JAN. 2009	X							NFPA 70
51	18	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
51	17	FIX PANIC HARDWARE & REMOVE PADLOCK	X							
50	12	REMOVE TRACTORS FROM UNDER GRANDSTAND		X						

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0007

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: MARCH 24, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 3-24-10

Building	Ro13 00m	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
***NUMBERING SYSTEM DOES NOT MATCH F.I.S.H. ON ALL PORTABLES***										
92	13A	EMERGENCY LIGHT OUT		X						69A-58.204
92	13B	EMERGENCY LIGHT OUT		X						69A-58.204
92	24	OK								
92	25	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
92	26	OK								
92	27	OK								
92	28	OK								
92	29	OK								
92	30	NO EMERGENCY EVACUATION SHEET		X						FBC 423.14.2.4
92	31	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	32	THRESHOLD MISSING BY RAMP		X						
92	35	OK								
92	36	FIRE EXTINGUISHER MISSING TAG		X						69A-58.503

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0007

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: MARCH 24, 2010

*[Signature]*  
INSPECTOR'S SIGNATURE

3-24-10  
DATE

Building	Ro13 00m	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	37	OK								
92	38	OK								
92	39	EMERGENCY LIGHT - ONE BULB OUT		X						
92	40	OK								
92	41	RAMP EXCEEDS SLOPE 1/12			X					FBC 11.4.8
92	42	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	43	EMERGENCY LIGHT OUT		X						69A-58.204
92	43	CANNOT OPEN ELECTRICAL PANEL - MOVE CABINET		X						69A-58.899
92	44	FIRE EXTINGUISHER TAG MISSING		X						69A-58.503
92	45	OK								
92	46	OK								
92	47	NO EMERGENCY EVACUATION SHEET		X						69A-58.1205
92	48	EMERGENCY LIGHT/EXIT LIGHT LOOSE BY STARIS		X						
92	49	FIRE EXTINGUISHER TAG MISSING		X						69A-58.503

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0007

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: MARCH 24, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 3-24-10

Building	Ro13 00m	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	50	EXIT/EMERGENCY LIGHT HANGING FROM WIRES BY RAMP		X						NFPA 70 110.12
92	51	EMERGENCY LIGHT ON BULB NOT WORKING		X						69A-58.204
92	51	DOOR HANDLE MISSING IN STORAGE ROOM		X						
92	52	EMERGENCY LIGHT NOT WORKING BY STAIRS		X						69A-58.204
92	53	EMERGENCY LIGHT WEAK		X						
92	54	NO EMERGENCY EVACUATION SHEET		X						FBC 423.17.1
92	55	OK								
92	56	EMERGENCY LIGHT WILL NOT GO OFF		X						
92	58	OK								
92	59	OK								
92	60	NO EMERGENCY EVACUATION SHEET		X						69A-58.1205
92	61	OK								
92	62	EMERGENCY LIGHT OUT BY RAMP DOOR		X						69A-58.204
92	63	EMERGENCY EVACUATION SHEET MISSING		X						FBC 423.17.1

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION"  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0007

FACILITY: ORANGE PARK HIGH SCHOOL  
2300 KINGSLEY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: MARCH 24, 2010

*[Signature]*  
INSPECTOR'S SIGNATURE

3-24-10  
DATE

INSPECTOR'S SIGNATURE

Building	Ro13 0om	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	64	OIK								
92	65	ELECTRICAL PANEL LATCH BROKEN		X						69A-58.899
92	66	TRIP HAZARD AT END OF RAMP		X						
92	67	EMERGENCY LIGHT NOT WORKING BY STAIRS		X						69A-58.204
92	72	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	73	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	74	LIGHT OUT STORAGE ROOM		X						69A-58.204

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT CLAY FACILITY # 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: MARCH 3, 2010

INSPECTOR'S SIGNATURE  
*[Signature]*

DATE  
3-3-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	149	CEILING TILES HANGING	X							FBC 804.2.3
1	149	NO MAXIMUM OCCUPANCY SIGN		X						FBC 423.14.2.3
1	151	BROKEN OUTLET COVER	X							NFPA 70
2	217	CEILING TILE OUT		X						FBC 804.2.3
2	233	NO ROOM NUMBER	X							
2	233	LIGHT BULB NOT PROTECTED		X						NFPA 70
2	238	CEILING ELECTRICAL BOX OPEN	X							
3	315	NO EVACUATION SHEET		X						FBC 423.14.2.4
3	313	DUCT ABOVE CEILING LEAKING	X							
3	320	NO EVACUATION SHEET		X						FBC 423.14.2.4
3	332	GRILL MISSING	X							
3	340	GRATE MISSING IN CEILING		X						
5	509	PROJECTOR NOT INSTALLED PROPERLY								
5	528	NO EVACUATION SHEET		X						FBC 423.14.2.4



**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT CLAY FACILITY # 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: MARCH 3, 2010

*[Signature]*  
INSPECTOR'S SIGNATURE

3390

DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
6	633	CEILING TILE OUT		X						FBC 804.2.3
6	635	MAGNETIC DOOR HOLDER BROKEN	X							
6	649	CEILING PROJECTOR NOT INSTALLED PROPERLY	X							
6	657	CEILING PROJECTOR NOT INSTALLED PROPERLY	X							
6	658	CEILING PROJECTOR NOT INSTALLED PROPERLY	X							
6	679	CEILING PROJECTOR NOT INSTALLED PROPERLY	X							
6	675	CEILING TILE OUT		X						FBC 804.2.3
6		NORTH END EXTERIOR WALL LIGHT BROKEN	X							
7		EXTERIOR SOFFIT FALLING	X							
8	829	CLEAN UP WIRE		X						
8	879	INSTALL COVERS ON ELECTRICAL	X							NFPA 70
9	911	WEST SIDE ELECTRICAL COVERS MISSING	X							NFPA 70
9	911	EAST SIDE ELECTRICAL COVERS MISSING	X							NFPA 70
9	901	EMERGENCY LIGHT BROKEN	X							FBC 423.17.1



**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION"  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT CLAY FACILITY # 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: MARCH 3, 2010

INSPECTOR'S SIGNATURE [Signature] DATE 3-3-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
96	2	LENSE BROKEN - EMERGENCY LIGHT NOT WORKING		X						69A-58.204
96	42	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	1	EMERGENCY LIGHT IN SHOWER NOT WORKING		X						69A-58.204
92	3	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	3	ELECTRICAL PANEL NOT LABELED		X						69A-58.204
92	4	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	5	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	6	OK								
92	7	OK								
92	8	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	9	OK								
92	10	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	10	NO EVACUATION SHEET		X						69A-58.1205
92	10	DOOR HANDLE VERY LOOSE		X						69A-58.299

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION"  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: MARCH 3, 2010

INSPECTOR'S SIGNATURE: *[Signature]*

DATE: 3-3-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	11	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	12	OK								FBC 423.17.1
92	13	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	13	BATTERIES BAD, LEAKING, REPLACE		X						
92	14	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	21	OK								
92	22	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	23	OK								
92	24	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	25	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	26	OK								
92	27	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	28	OK								
92	29	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION"  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: MARCH 3, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 3-3-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	30	LIGHT OUT IN RESTROOM								
92	31	NO EMERGENCY EVACUATION SHEET	X							FBC 423.14.2.4
92	32	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	33	RESTROOM DOOR DAMAGED	X							
92	34	OK								
92	41	REAR CORNER BLOCKS TWISTED		X						
92	43	RAMP EXCEEDS 1/12 SLOPE	X							FBC 11-4.8
92	44	OK								
92	45	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	46	OK								
92	47	OK								
92	48	OK								
92	49	LOTS OF LIGHTS NOT WORKING		X						FBC 423,17.1

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY # 0022

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION"  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: MARCH 3, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 3-3-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	50	WIRE TO CANOPY AT END OF RAMP NOT ATTACHED TO STRAP	X							
92	51	OK								
92	52	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	53	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	54	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1204
92	61	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	62	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	63	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	64	OK								
92	65	OK								
92	66	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	67	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	67	FIRE EXTINGUISHER MISSING		X						69A-58.506

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"**

**IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY # 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: MARCH 3, 2010

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 3-3-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	67	EXIT BLOCKED		X						69A-58.211
92	68	OK								
92	69	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	69	CEILING TILE MISSING IN CLOSET		X						FBC 804.2.3
92	70	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	71	OK								
92	72	ELECTRICAL PANEL NOT LABELED	X							69A-58.802
92	73	OK								
92	74	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	74	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205
92	81	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	82	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	83	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	84	OK								

**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"**

**IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**



DISTRICT: CLAY FACILITY #: 0022

FACILITY: RIDGEVIEW HIGH SCHOOL  
466 MADISON AVENUE  
ORANGE PARK, FLORIDA 32065

INSPECTION DATE: MARCH 3, 2010

INSPECTOR'S SIGNATURE: *[Signature]*

DATE: 3-3-10

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	85	OK								
92	86	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	87	OK	X							
92	88	OK	X							
92	89	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	90	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	91	OK								
92	92	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	101A	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	101B	EMERGENCY LIGHT NOT WORKING		X						FBC 423.17.1
92	103	OK								