

**FISCAL YEAR 2009-2010**



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0046

FACILITY: ARGYLE ELEMENTARY SCHOOL  
2625 SPENCER PLANTATION BOULEVARD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 22, 2009

*Larry A. Swann*  
 INSPECTOR'S SIGNATURE

10-22-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Main. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
3		OK								
4		OK								
5		OK								
6		OK								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0046



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: ARGYLE ELEMENTARY SCHOOL  
2625 SPENCER PLANTATION BOULEVARD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 22, 2009

*Larry D. Swann*  
 INSPECTOR'S SIGNATURE

10-22-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Main. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	701	OK								
92	702	OK								
92	703	OK								
92	704	EVACUATION SHEET MISSING		X						69A-58.1205
92	705	OUT OF SERVICE								
92	706	OK								
92	707	OK								
92	708	OUT OF SERVICE								
92	709	OUT OF SERVICE								
92	710	OUT OF SERVICE								
92	711	EVACUATION SHEET MISSING		X						69A-58.1205
92	711	RAMPE EXCEEDS 1/12 SLOPE	X							FBC 11.8.4
92	712	OUT OF SERVICE								

**FISCAL YEAR 2009-2010**



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0046

FACILITY: ARGYLE ELEMENTARY SCHOOL  
2625 SPENCER PLANTATION BOULEVARD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 22, 2009

*[Signature]*  
 INSPECTOR'S SIGNATURE

10-22-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Main. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	713	OK								
92	714	RAMP EXCEEDS 1/12 SLOPE	X							
92	801	OK								
92	802	EVACUATION SHEET MISSING		X						69A-58.1205
92	803	EVACUATION SHEET MISSING		X						69A-58.1205
92	804	OK								
92	805	OK								
92	806	EVACUATION SHEET MISSING		X						69A-58.1205
92	807	ROOF LEAKS	X							
92	808	OK								
92	809	OUT OF SERVICE								
92	810	OUT OF SERVICE								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0046



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: ARGYLE ELEMENTARY SCHOOL  
2625 SPENCER PLANTATION BOULEVARD  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: OCTOBER 22, 2009

*[Handwritten Signature]*  
 INSPECTOR'S SIGNATURE

10-22-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Main. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	901	BULB MISSING IN RESTROOM LIGHT		X						69A-58.899
92	902	OK								
92	903	RAMP EXCEEDS 1/12 SLOPE	X							
92	904	OK								
92	905	OK								
92	906	OK								
92	907	OUT OF SERVICE								
92	908	OUT OF SERVICE								
92	909	OUT OF SERVICE								
92	910	OUT OF SERVICE								
92										

**FISCAL YEAR 2009-2010**



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0002

FACILITY: CHARLES E. BENNETT ELEMENTARY SCHOOL  
1 SOUTH OAKRIDGE AVENUE  
GREEN COVE SPRINGS, FLORIDA 32068

INSPECTION DATE: OCTOBER 27, 2009

*[Handwritten Signature]*  
 INSPECTOR'S SIGNATURE

10-27-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
4		OK								
5		OK								
9		OK								
10	1B	BROKEN SWITCH PLATE COVER		X						69A-58.807
11		OK								
14		OK								
16		OK								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0002



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: CHARLES E. BENNETT ELEMENTARY SCHOOL  
1 SOUTH OAKRIDGE AVENUE  
GREEN COVE SPRINGS, FLORIDA 32068

INSPECTION DATE: OCTOBER 27, 2009

*[Handwritten Signature]*  
 INSPECTOR'S SIGNATURE

102709  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92 -	40	OK								
92	41	OK								
92	42	OK								
92	43	OK								
92	45	OK								
92	46	USED AS STORAGE								
92	47	OK								
92	48	USED AS STORAGE								
92	49	OK								
92	50	OK								
92	51	USED AS STORAGE								
92	52	EMERGENCY LIGHT NOT WORKING		X						69A-58.204

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0002



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: CHARLES E. BENNETT ELEMENTARY SCHOOL  
1 SOUTH OAKRIDGE AVENUE  
GREEN COVE SPRINGS, FLORIDA 32068

INSPECTION DATE: OCTOBER 27, 2009

*[Handwritten Signature]*  
 INSPECTOR'S SIGNATURE

10-27-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	53	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	54	USED AS STORAGE								
92	55	GLOBE MISSING IN STORAGE ROOM		X						69A-58.899
92	56	RAMP IN POOR CONDITION	X							69A-58.299
92	56	FLO LIGHT LINKING		X						69A-58.199
92	57	FIRE EXTINGUISHER NEEDS TO BE REPLACED		X						69A-58.501
92	58	OK								
92	59	OK								
92	501	OK								
92	502	OK								
92	503	OK								
92	602 A/B	OK								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0002



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: CHARLES E. BENNETT ELEMENTARY SCHOOL  
1 SOUTH OAKRIDGE AVENUE  
GREEN COVE SPRINGS, FLORIDA 32068

INSPECTION DATE: OCTOBER 27, 2009

*[Handwritten Signature]*  
 INSPECTOR'S SIGNATURE

10-27-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	604	OK								
92	702	OK								
92	703	OK								
92	704	OK								
92	803	OK								





**FISCAL YEAR 2009-2010**



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0047

FACILITY: COPPERGATE ELEMENTARY SCHOOL  
2250 COUNTY ROAD NORTH  
MIDDLEBURG, FLORIDA 32043

INSPECTION DATE: NOVEMBER 3, 2009

INSPECTOR'S SIGNATURE \_\_\_\_\_ DATE \_\_\_\_\_

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	501	OK								
92	502	OK								
92	503	OK								
92	504	OK								
92	511	OK								
92	512	OK								
92	513	OK								
92	514	OK								
92	516	OK								
92	518	OK								
92	520	OK								

**FISCAL YEAR 2009-2010**



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0021

FACILITY: CLAY HILL ELEMENTARY SCHOOL  
6345 STATE ROAD 218  
JACKSONVILLE, FLORIDA 32234

INSPECTION DATE: OCTOBER 29, 2009

*Larry P. [Signature]*  
 INSPECTOR'S SIGNATURE

10-29-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
5	502	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205
6		OK								
7	707	EMERGENCY EVACUATION SHEET MISSING		X						69A-58.1205

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0021



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: CLAY HILL ELEMENTARY SCHOOL  
6345 STATE ROAD 218  
JACKSONVILLE, FLORIDA 32234

INSPECTION DATE: OCTOBER 29, 2009

*[Signature]*  
 INSPECTOR'S SIGNATURE

10-29-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	682	SOFFIT ON WEST SIDE FALLING		X						
92	701	OK								
92	702	OK								
92	703	OK								
92	704	OK								
92	705	OK								
92	706	OK								
92	707	OK								
92	708	OK								
92	709	RAMP EXCEEDS 1/12 SLOPE	X					3		69A-58.299
92	710	OK								
92	712	STORAGE TOO HIGH IN CLOSET - MUST BE 24" FROM CEILING		X						69A-58.199

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0021



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**


FACILITY: CLAY HILL ELEMENTARY SCHOOL  
6345 STATE ROAD 218  
JACKSONVILLE, FLORIDA 32234

INSPECTION DATE: OCTOBER 29, 2009

*[Signature]*  
 INSPECTOR'S SIGNATURE

10-29-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	760	RAMP EXCEEDS 1/12 SLOPE	X					3		69A-58.299
92	762	RAMP EXCEEDS 1/12 SLOPE	X							69A-58.299
92	764									
92	766	OK								



**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0008

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL  
2250 COUNTY ROAD NORTH  
MIDDLEBURG, FLORIDA 32043

INSPECTION DATE: NOVEMBER 5, 2009

*[Signature]*  
INSPECTOR'S SIGNATURE

11-5-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
SITE		HOLES IN ASPHALT; SPORTS COURT AREA, SWING SET IS RUSTY - REPLACE SINK HOLES, AROUND CAMPUS ALL PLAYGROUND EQUIPMENT NEEDS SERVICE	X							69A-58.202
4	108	COVER MISSING PANEL - VIDEO		X						
4	106	STAINED CEILING TILES - LEAK		X						
5	107	KNOCKOUT MISSING	X							
5	108	LIGHT COVER MISSING		X						
5	112	INTERCOM WIRES EXPOSED		X						
5	100	CEILING TILES FALLING		X						
6	601B	EMERGENCY LIGHT FALLING		X						
6	601B	CAN LIGHT BROKEN		X						
7	702	NO EMERGENCY EVACUATION SHEET		X						69A-58.1205
7	705	NO EMERGENCY EVACUATION SHEET		X						69A-58.1205

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0008



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL  
2250 COUNTY ROAD NORTH  
MIDDLEBURG, FLORIDA 32043

INSPECTION DATE: NOVEMBER 5, 2009

*[Handwritten Signature]*  
 INSPECTOR'S SIGNATURE

11-5-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
7	711	CLEANOUT NOT COVERED, PLUMBING	X							
8	810	DIRTY CEILING		X						
9	910	COVER MISSING THERMOSTAT		X						
9	900A	SINK HOLES @ DOWNSPOUTS	X							
BY PORTABLE 843		DRINKING FOUNTAIN WATER DRAINS ACROSS SIDEWALK	X							

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0008



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL  
2250 COUNTY ROAD NORTH  
MIDDLEBURG, FLORIDA 32043

INSPECTION DATE: NOVEMBER 5, 2009

*[Signature]*  
INSPECTOR'S SIGNATURE

11-5-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	836	OK								
92	837	NO EMERGENCY EVACUATION SHEET		X						69A-58.1205
92	838	NO EMERGENCY EVACUATION SHEET		X						69A-58.1205
92	839	OK								
92	840	CABINET IN FRONT OF PANEL - MOVE		X						69A-58.801
92	840	BARE WIRES OLD CLOCK, REMOVE	X							
92	842 A	OK								
92	842B	OK								
92	843	EXTINGUISHER MISSING TAG		X						69A-58.801
92	844	NO EMERGENCY EVACUATION SHEET								69A-58.1205
92	845	LIGHT MISSING COVER IN CLOSET		X						69A-58.899
92	847	OK								





**FISCAL YEAR 2009-2010**

**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0008

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL  
2250 COUNTY ROAD NORTH  
MIDDLEBURG, FLORIDA 32043

INSPECTION DATE: NOVEMBER 5, 2009

*Randy A. Swan*  
 INSPECTOR'S SIGNATURE

11-5-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	849	DOOR RUBS LANDING STAIRS – HARD TO OPEN		X						69A-58.299
92	869	OK								
92	870	OK								
92	871	OK								
92	872	LIGHT MISSING COVER IN CLOSET		X						69A-58.899
92	873	OPEN COMMUNICATION BOX OUTSIDE BY STAIRS		X						69A-58.899
92	874	REPLACE DUCT TAPE WITH KNOCKOUT IN PANEL	X							69A-58.807
92	876	OK								
92	888	OK								
92	889	OK								
92	890	OK								
92	891	NO EMERGENCY EVAUCATION SHEET		X						69A-58.1205

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0008



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL  
2250 COUNTY ROAD NORTH  
MIDDLEBURG, FLORIDA 32043

INSPECTION DATE: NOVEMBER 5, 2009

*[Handwritten Signature]*  
 INSPECTOR'S SIGNATURE

11-5-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	892	OK								
92	893	OK								
92	894	OK								
92	895	OK								
92	896	OK								
92	897	OK								
92	899	RAMP EXCEEDS 1/12 SLOPE	X							69A-58.299
92	921	OK								
92	923	NO EMERGENCY EVACUATION SHEET		X						69A-58.1205

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0008



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: DOCTORS INLET ELEMENTARY SCHOOL  
2250 COUNTY ROAD NORTH  
MIDDLEBURG, FLORIDA 32043

INSPECTION DATE: NOVEMBER 5, 2009

*[Signature]*  
 INSPECTOR'S SIGNATURE

11-5-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	892	OK								
92	893	OK								
92	894	OK								
92	895	OK								
92	896	OK								
92	897	OK								
92	899	RAMP EXCEEDS 1/12 SLOPE	X					3		69A-58.299
92	921	OK								
92	923	NO EMERGENCY EVACUATION SHEET		X						69A-58.1205

**FISCAL YEAR 2009-2010**



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL  
4425 LAKESHORE DRIVE  
ORANGE PARK, FLORIDA 32043

INSPECTION DATE: NOVEMBER 10, 2009

*[Signature]*  
INSPECTOR'S SIGNATURE

11-10-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2	201	CEILING TILE STAINED		X						
2	216	CEILING TILE STAINED		X						
2	230	CEILING TILE STAINED		X						
3	314	CEILING TILE STAINED		X						
3	309	COVER PLATE ON "J" BOX MISSING	X							
4		OK								
5		OK								
7		OK								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0044



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL  
4425 LAKESHORE DRIVE  
ORANGE PARK, FLORIDA 32043

INSPECTION DATE: NOVEMBER 10, 2009

*[Signature]*  
INSPECTOR'S SIGNATURE

11-10-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	601	OK								
92	602	OK								
92	603	OK								
92	604	OK								
92	605	OK								
92	606	OK								
92	607	EMERGENCY LIGHT OUT	X							
92	607	ELECTRICAL PANEL DOOR PAINTED SHUT		X						
92	607	BOXES OF PAPER BLOCKING REAR DOOR		X						
92	608	EMERGENCY LIGHT NOT WORKING	X							
92	797	EMERGENCY LIGHT NOT WORKING	X							
92	798	EMERGENCY LIGHT NOT WORKING	X							

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0044



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL  
4425 LAKESHORE DRIVE  
ORANGE PARK, FLORIDA 32043

INSPECTION DATE: NOVEMBER 10, 2009

*[Handwritten Signature]*  
 INSPECTOR'S SIGNATURE

11-10-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	799	EMERGENCY LIGHT NOT WORKING	X							
92	800	OK								
92	801	OK								
92	802	OK								
92	803	OK								
92	804	OK								
92	805	OK								
92	806	OK								
92	807	OK								
92	809	OK								
92	812	EMERGENCY LIGHT NOT WORKING	X							
92	824	OK								

**FISCAL YEAR 2009-2010**



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL  
4425 LAKESHORE DRIVE  
ORANGE PARK, FLORIDA 32043

INSPECTION DATE: NOVEMBER 10, 2009

*[Handwritten Signature]*  
INSPECTOR'S SIGNATURE

11-10-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	826	OK								
92	828	OK								
92	832	OK								
92	830	OK								
92	841	EMERGENCY LIGHT NOT WORKING	X							
92	842	OK								
92	843	OK								
92	844	RESTROOM DOOR STICKS	X							
92	840	OK								
92	848	OK								
92	850	OK								
92	910	LIGHT GLOBE IN RESTROOM MISSING								

**FISCAL YEAR 2009-2010**



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0044

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL  
4425 LAKESHORE DRIVE  
ORANGE PARK, FLORIDA 32043

INSPECTION DATE: NOVEMBER 10, 2009

*[Signature]*  
 INSPECTOR'S SIGNATURE


11-10-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	860	OK								
92	861	LIGHT GLOBE IN RESTROOM MISSING	X							
92	862	ROOF LEAKS	X							
92	901	EMERGENCY LIGHT NOT WORKING	X							
92	901	CEILING TILE MISSING IN RESTROOM		X						
92	902	EMERGENCY LIGHT NOT WORKING	X							
92	903	EMERGENCY LIGHT NOT WORKING	X							
92	903	NO SIGN ON BOYS RESTROOM	X							
92	903	SIDING ROTTED ON EXTERIOR	X							
92	904	OK								
92	905	OK								
92	906	OK								



**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0044



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: FLEMING ISLAND ELEMENTARY SCHOOL  
4425 LAKESHORE DRIVE  
ORANGE PARK, FLORIDA 32043


INSPECTION DATE: NOVEMBER 10, 2009

*[Signature]*  
 INSPECTOR'S SIGNATURE

11-10-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	907	OK								
92	908	OK								
92	909	OK								

**FISCAL YEAR 2009-2010**



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0005

FACILITY: GROVE PARK ELEMENTARY SCHOOL  
1643 MILLER STREET  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 13, 2009

*[Signature]*  
INSPECTOR'S SIGNATURE

11-13-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	100A	EXPOSED WIRES – WIRES NOT IN JUNCTION	X							69A-58-809
1	110	BROKEN SWITCH COVER		X						69A-58-807
2	OK									
6	EXT.	REPLACE EXTERIOR LIGHTS; LESS WATTAGE		X						
6	603	EMERGENCY EVACUATION SHEET MISSING		X						69A-58-1205
7	EXT	REPLACE EXTERIOR LIGHTS; LESS WATTAGE		X						
8		OK								
9	3	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0005



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: GROVE PARK ELEMENTARY SCHOOL  
1643 MILLER STREET  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 13, 2009

INSPECTOR'S SIGNATURE \_\_\_\_\_ DATE \_\_\_\_\_

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	5	OK								
92	6	OK								
92	7	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205
92	8	OK								
92	9	OK								
92	10	OK								
92	27	OK								
92	28	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205
92	28	WATER IN LIGHT - POSSIBLE ROOF LEAK	X							
92	29	OK								
92	30	OK								
92	31	TOILET MISSING BOLT TO FLOOR	X							
92	37	OK								
92	38	OK								

**FISCAL YEAR 2009-2010**



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

DISTRICT: CLAY FACILITY #: 0005

FACILITY: GROVE PARK ELEMENTARY SCHOOL  
1643 MILLER STREET  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 13, 2009

*Joel Sweetland*  
 \_\_\_\_\_  
 INSPECTOR'S SIGNATURE

11-13-09  
 \_\_\_\_\_  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	43	OK								
92	44	EMERGENCY LIGHT NOT WORKING		X						69A-58-204
92	71	OK								
92	500	OK								
92	501	OK								
92	503	OK								
92	504	OK								
92	505	FLOURESCENT LIGHTS HAVE NO COVERS		X						69A-58-899
92	505	EMERGENCY LIGHT NOT WORKING		X						69A-58-204
92	506	GLOBE MISSING LIGHT IN CLOSET		X						69A-58-899
92	507	OK								
92	520 A/B	EXHAUST FAN NOT WORKING IN RESTROOM ON BOTH SIDES		X						69A-58-999
92	521 A/B	OK								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0005



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: GROVE PARK ELEMENTARY SCHOOL  
1643 MILLER STREET  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: NOVEMBER 13, 2009

*Ted Sweatt*  
 INSPECTOR'S SIGNATURE

11-13-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	522	OK								
92	523	OK								
92	524	SIDING POOR CONDITION BY STRAPS	X							
92	525	OK								
92	526	LIGHT BULB MISSING GLOBE		X						69A-58-899
92	527	LIGHT BULB MISSING GLOBE		X						69A-58-899
92	528	OK								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0010



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL  
335 S. PECAN STREET  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: NOVEMBER 19, 2009

*Ted Sweetow*  
 INSPECTOR'S SIGNATURE 11-19-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	1	FIRE ALARM CERTIFICATION OVERDUE	X							
2		OK								
3		OK								
4		OK								
5	4	NO EVACUATION SHEET		X						FBC 423.14.2.4
6	5	NO EVACUATION SHEET		X						FBC 423.14.2.4
7		OK								
8	7	NO EVACUATION SHEET		X						FBC 423.14.2.4
9	907	NO EVACUATION SHEET		X						FBC 423.14.2.4
9	908	NO EVACUATION SHEET		X						FBC 423.14.2.4
9	918	NO EVACUATION SHEET		X						FBC 423.14.2.4
9	920	NO EVACUATION SHEET		X						FBC 423.14.2.4
10	24	NO EVACUATION SHEET		X						FBC 423.14.2.4
10	23	NO EVACUATION SHEET		X						FBC 423.14.2.4

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0010



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL  
335 S. PECAN STREET  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: NOVEMBER 19, 2009

*Tad Sweatt*  
 INSPECTOR'S SIGNATURE

11-19-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
10	31	NO EVACUATION SHEET		X						FBC 423.14.2.4
11	1110	NO EXIT LIGHT	X							FBC 423.17.1
11	1105	NO EXIT LIGHT	X							FBC 423.17.1
12	1202	REMOVE LIGHT, CONDUIT, LADDER	X							
12	1210	NO EVACUATION SHEET		X						FBC 423.14.2.4
12	1211	NO EVACUATION SHEET		X						FBC 423.14.2.4
12	1214	NO EVACUATION SHEET		X						FBC 423.14.2.4

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0010



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL  
335 S. PECAN STREET  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: NOVEMBER 19, 2009


*Ted Sweetland*  
 INSPECTOR'S SIGNATURE 11-19-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	701	OK								
92	702	MOVE TABLE - TOO CLOSE TO EXIT		X						
92	703	OK								
92	704	OK								
92	705	OK								
92	706	OK								
92	707	OK								
92	708	AV WIRES OVERHEAD	X							
92	709	OUT OF SERVICE								
92	710	OK								
92	713	CLOSET LIGHT MISSING GLOBE	X							
92	714	OK								
92	715	OUT OF SERVICE								
92	716	OK								



**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0010



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: KEYSTONE HEIGHTS ELEMENTARY SCHOOL  
335 S. PECAN STREET  
KEYSTONE HEIGHTS, FLORIDA 32656

INSPECTION DATE: NOVEMBER 19, 2009

*Joel Sweatt*  
INSPECTOR'S SIGNATURE

11-19-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	717	OK								
92	718	OK								
92	719	RESTROOM LIGHT MISSING GLOBE	X							
92	720	RESTROOM LIGHT MISSING GLOBE	X							
92	720	EXTENSION CORD TO COMPUTER	X							
92	721	OK								
92	722	RAMP EXCEEDS 1/12 SLOPE	X					3		FBC 11-4.8
92	724	OK								
92	750	OK								
92	751	OK								
92	768	OUT OF SERVICE								
92	770	RAMP EXCEEDS 1/12 SLOPE	X					3		FBC 11-4.8
92	771	ROOF LEAKS IN STORAGE ROOM	X							
92	772	OUT OF SERVICE								
92	773	OK								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0023



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL  
2901 SANDRIDGE ROAD  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 7, 2009

*Joel Sweetman*  
 \_\_\_\_\_  
 INSPECTOR'S SIGNATURE

11-7-09  
 \_\_\_\_\_  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	125	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205
1	131	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205
1	133	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205
1	135	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205
1	136	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205
2	206	ROOM NUMBER MISSING		X						69A-58-199
2	216	EXIT LIGHT OUT		X						69A-58-202
2	225	EXIT LIGHT OUT		X						69A-58-202
2	211	CEILING GRID FALLING		X						69A-58-199
3		OK								
4		OK								
5		OK								
6		OK								
7		OK								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0023



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL  
2901 SANDRIDGE ROAD  
GREEN COVE SPRINGS, FLORIDA 32043


INSPECTION DATE: NOVEMBER 7, 2009

*Ted Sweatman*  
INSPECTOR'S SIGNATURE 11-7-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
SITE		YARD BY PORTABLE 18 OPEN PLUMBING	X							
SITE		YARD BY PORTABLE 45 OLD PLUMBING PIPES	X							
92	9	NEED TO MOVE FIRE EXTINGUISHER TO WITHIN 15 FT. OF STOVE		X						69A-58-507
92	10	NEED TO MOVE FIRE EXTINGUISHER TO WITHIN 15 FT. OF STOVE		X						69A-58-507
92	11	NEED TO MOVE FIRE EXTINGUISHER TO WITHIN 15 FT. OF STOVE		X						69A-58-507
92	12	NEED TO MOVE FIRE EXTINGUISHER TO WITHIN 15 FT. OF STOVE		X						69A-58-507
92	12	GLOBE MISSING IN RESTROOM		X						69A-58-899
92	13	NEED TO MOVE FIRE EXTINGUISHER TO WITHIN 15 FT. OF STOVE		X						69A-58-507
92	14	OK								
92	15	NEED TO MOVE FIRE EXTINGUISHER TO WITHIN 15 FT. OF STOVE		X						69A-58-507
92	16	EMPTY - OUT OF SERVICE								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0023



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL  
2901 SANDRIDGE ROAD  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 7, 2009

*Todd Sweatt*  
INSPECTOR'S SIGNATURE 11-7-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	18	EMERGENCY LIGHT NOT WORKING		X						69A-58-204
92	39	USED FOR STORAGE - POWER OFF								
92	40	OK								
92	41	POWER OFF								
92	42	OK								
92	43	USED FOR STORAGE								
92	44	EMERGENCY LIGHT NOT WORKING		X						69A-58-204
92	45	EMPTY								
92	46	SCREW TOP LEFT CORNER PANEL PULLED THROUGH - REPLACE		X						69A-58-809
92	48	OK								
92	69A/B	OK								
92	70	OK								
92	71	OK								
92	72	EMPTY								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0023



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL  
2901 SANDRIDGE ROAD  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 7, 2009

*Ted Sweetman*  
 \_\_\_\_\_  
 INSPECTOR'S SIGNATURE

11-7-09  
 \_\_\_\_\_  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	73	OK								
92	74	POWER OFF								
92	75	OK								
92	76	OK								
92	77	OK								
92	78	POWER OFF								
92	79A/B	OK								
92	80	OK								
92	81	OK								
92	82	OK								
92	84	OK								
92	85	RAMP EXCEEDS 1/12 SLOPE	X					3		FBC 11.4.8
92	86	OK								
92	87	POWER OFF								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0023



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKE ASBURY ELEMENTARY SCHOOL  
2901 SANDRIDGE ROAD  
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: NOVEMBER 7, 2009

*Zed Sweetman*  
INSPECTOR'S SIGNATURE

11-7-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	88	EMERGENCY LIGHT NOT WORKING		X						69A-58-204
92	89	OK								
92	90	OK								
92	91	OK								
92	92	POWER OFF								
92	93	OK								
92	94	OK								
92	95	OK								
92	96	OK								

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0015



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKESIDE ELEMENTARY SCHOOL  
2752 MOODY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: DECEMBER 1, 2009

*Ted Sweetman*  
 INSPECTOR'S SIGNATURE

12-1-09  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1		OK								
2		OK								
6		NUMBERS MISSING ON EXTERIOR		X						69A-58.1308
7		NUMBERS MISSING ON EXTERIOR		X						69A-58.1308
7	711	ROOM NUMBER MISSING		X						69A-58-199
7	706	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205
8	803	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205
8	807	NO EMERGENCY EVACUATION SHEET		X						69A-58-1205

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0015



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKESIDE ELEMENTARY SCHOOL  
2752 MOODY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: DECEMBER 1, 2009

*Ted Sweatt*  
 INSPECTOR'S SIGNATURE 12-1-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	10	WATER STAIN IN CENTER OF ROOM LEAKS	X							
92	11	EMERGENCY LIGHT NOT WORKING		X						69A-58.204
92	12	OK								
92	13	OK								
92	14	OPEN SPACE ELEC. PANEL - KNOCKOUT NEEDED		X						69A-58-807
92	15	OK								
92	16	EXCESSIVE PAPERWORK ON WALLS 20% MAX		X						69A-58-106
92	17	OK								
92	18	OK								
92	19	OK								
92	20	EMERGENCY LIGHT MISSING	X							69A-58-204
92	21	OK								
92	22	RAMP EXCEEDS 1/12 SLOPE	X					3		69A-48-299
92	23	OK								



**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0015



**COMPREHENSIVE SAFETY & SANITATION  
INSPECTION REPORT  
STATE BOARD OF EDUCATION  
ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
"CASUALTY SAFETY & SANITATION  
INSPECTION"  
IN COMPLIANCE WITH  
F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKESIDE ELEMENTARY SCHOOL  
2752 MOODY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: DECEMBER 1, 2009

*Tom Sweathome*  
INSPECTOR'S SIGNATURE

12-1-09  
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	24	OK								
92	25	OK								
92	26	OK								
92	27	OK								
92	42A/B	OK								
92	43	OK								
92	44	OK								
92	45	RAMP EXCEEDS 1/12 SLOPE	X					3		69A-58-299
92	46	RAMP EXCEEDS 1/12 SLOPE	X					3		69A-58-299
92	47	RAMP EXCEEDS 1/12 SLOPE	X					3		69A-58-299
92	51A/B	OK								
92	52	OK								
92	53	OK								
92	54	HEAT DETECTOR LOOSE AT CEILING		X						69A-58-499

**FISCAL YEAR 2009-2010**

DISTRICT: CLAY FACILITY #: 0015



**COMPREHENSIVE SAFETY & SANITATION  
 INSPECTION REPORT  
 STATE BOARD OF EDUCATION  
 ADMINISTRATIVE RULES S.R.E.F. - CHAPTER 5  
 "CASUALTY SAFETY & SANITATION  
 INSPECTION"  
 IN COMPLIANCE WITH  
 F.S. 1013.12, 1013.20 & NFPA 101**

FACILITY: LAKESIDE ELEMENTARY SCHOOL  
2752 MOODY AVENUE  
ORANGE PARK, FLORIDA 32073

INSPECTION DATE: DECEMBER 1, 2009

*Ted Sweatt*  
 \_\_\_\_\_  
 INSPECTOR'S SIGNATURE

12-1-09  
 \_\_\_\_\_  
 DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	57	OK								
92	58	POWER OFF								
92	59	OK								
92	60	OK EMPTY								
92	61	OK								
92	62	OK								
92	63	OK								