

State Fire Marshal - Inspection Report

District Clay

School CHARLES E BENNETT ELEMENTARY

Address 1 S OAKRIDGE AVENUE

Inspection date 2009-10-27

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
69A-58.204	0203 EXIT LIGHTS INOPERABLE EMERGENCY MODE	92-	RELOCATABLE 52	2009-11-27	0	N/A
69A-58.204	0204 OPERATIONAL	92-	RELOCATABLE 53	2009-11-27	0	N/A
69A-58.501	0506 EXTINGUISHER MISSING FROM LOCATION	92-	RELOCATABLE 57	2009-11-27	0	N/A
69A-58.1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	92-	RELOCATABLE 57	2009-11-27	0	N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(OR)

Acknowledgement N/A. **No**


Primary inspector
 larry, swanson

Additional inspector
 N/, A

State Fire Marshal - Inspection Report

District Clay

School FLEMING ISLAND ELEMENTARY

Address 4425 LAKESHORE DRIVE

Inspection date 2009-11-10

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
69-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	607	2009-12-10	0	N/A
	0801 INADEQUATE ACCESS TO ELECTRICAL PANEL	92- RELOCATABLE	607	2009-12-10	0	N/A
	0211 BLOCKED/LOCKED EXITS	92- RELOCATABLE	607	2009-12-10	0	N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	608	2009-12-10	0	N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	797	2009-12-10	0	N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	798	2009-12-10	0	N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	812	2009-12-10	0	N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	841	2009-12-10	0	N/A
	0209 RATED OPENINGS NOT MAINTAINED	92- RELOCATABLE	844	2009-12-10	0	RESTROOM DOOR STICKS
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	901	2009-12-10	0	
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	902	2009-12-10	0	N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92- RELOCATABLE	903	2009-12-10	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1)(b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

State Fire Marshal - Inspection Report

District - Clay

School - GROVE PARK ELEMENTARY

Address - 1643 MILLER STREET

Inspection date - 2009-11-13

Notes -

Inspectors present

State No **District Yes** **Local No**

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
69A-58.809	0899 UTILITIES OTHER	1-	100A	2009-12-13	0 EXPOSED WIRES - WIRES NOT IN JUNCTION
69A-58.1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	7-	603	2009-12-13	0 N/A
69A-58-1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	9-	3	2009-12-13	0 N/A
69A-58.1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	92-	7	2009-12-13	0 N/A
69A-58.1205	1205 FIRE EVACUATION PLAN(S) NOT POSTED	92-	28	2009-12-13	0 N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-	44	2009-12-13	0 N/A
69A-58.204	0204 EMERG LIGHTS NOT OPERATIONAL	92-	505	2009-12-13	0 N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**

I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**

I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**



Primary Inspector
Jerry, Swanson

Additional Inspector
N/, A

State Fire Marshal - Inspection Report

District - Clay

School - KEYSTONE HEIGHTS ELEMENTARY

Address - 335 S PECAN STREET

Inspection date - 2009-11-19

Notes -

Inspectors present

State No District Yes Local No

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
	0401 ALARM LOG NOT MAINT/PRESENT	1-	1	2009-12-19	0	N/A
FBC423.14.2.4 0010	IMMINENT HAZARD	5-	4	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	6-	5	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	8-	7	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	9-	907	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	9-	908	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	9-	918	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	10-	924	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	9-	920	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	10-	24	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	10-	31	2009-12-19	0	N/A
FBC423.17.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	11-	1110	2009-12-19	0	N/A
FBC.423.17.1 0202	EXIT LIGHTS INOPERABLE NORMAL MODE	11-	1105	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	12-	1210	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	12-	1211	2009-12-19	0	N/A
FBC423.14.2.4 1205	FIRE EVACUATION PLAN (S) NOT POSTED	12-	1214	2009-12-19	0	N/A
0211	BLOCKED/LOCKED EXITS	92-	702	2009-12-19	0	N/A

Statements acknowledged

I hereby certify that the district has complied with section 1013.12(1) **No**
(b), F.S.

I hereby certify that the local authority having jurisdiction has **No**
complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of **No**
this inspection date.

(OR)

Acknowledgement N/A. **No**



Primary inspector
Larry, swanson

Additional inspector
N/A

State Fire Marshal - Inspection Report

District Clay

School LAKE ASBURY ELEMENTARY

Address 2901 SANDRIDGE ROAD

Inspection date 2009-11-24

Notes -

Inspectors present

State No District Yes Local No

Ref	Code Violation	Bldg	Room	Comp date	Cited	Notes
69a-58-1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-	PERMANENT	125	2010-01-10	0 N/A
69A-58-1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-	PERMANENT	131	2010-01-08	0 N/A
69A-58-1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-	PERMANENT	133	2010-01-08	0 N/A
69A-58.1205	FIRE EVACUATION PLAN(S) NOT POSTED	1-	PERMANENT	135	2010-01-08	0 N/A
69A-58.202	EXIT LIGHTS INOPERABLE NORMAL MODE	1-	PERMANENT	136	2010-01-08	0 N/A
69A-58.202	EXIT LIGHTS INOPERABLE NORMAL MODE	2-	PERMANENT	216	2010-01-08	0 N/A
69A-58.202	EXIT LIGHTS INOPERABLE NORMAL MODE	2-	PERMANENT	225	2010-01-08	0 N/A
69A-58.507	TRAVEL DISTANCE TO EXTINGUISHER EXCEEDED	92-	RELOCATABLE	9	2010-01-08	0 N/A
69A-58.507	TRAVEL DISTANCE TO EXTINGUISHER EXCEEDED	92-	RELOCATABLE	10	2010-01-08	0 N/A
69A-58.507	TRAVEL DISTANCE TO EXTINGUISHER EXCEEDED	92-	RELOCATABLE	11	2010-01-08	0 N/A
69A-58.507	TRAVEL DISTANCE TO EXTINGUISHER EXCEEDED	92-	RELOCATABLE	12	2010-01-08	0 N/A
69A-58.507	TRAVEL DISTANCE TO EXTINGUISHER EXCEEDED	92-	RELOCATABLE	13	2010-01-08	0 N/A
69A-58.507	TRAVEL DISTANCE TO EXTINGUISHER EXCEEDED	92-	RELOCATABLE	15	2010-01-08	0 N/A
69A-58.204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE	18	2010-01-08	0 N/A
69A-58.204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE	44	2010-01-08	0 N/A
69A-58.204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE	88	2010-01-08	0 N/A

Statements acknowledged


I hereby certify that the district has complied with section 1013.12(1) No (b), F.S.

I hereby certify that the local authority having jurisdiction has **No** complied with section 1013.12(2)(b), F.S.

I hereby certify that the required fire drills have been completed as of **No** this inspection date.

(Or)

Acknowledgement N/A. **No**



Primary inspector
Jerry, Swanson

Additional inspector
N/A

State Fire Marshal - Inspection Report

District Clay

School LAKESIDE ELEMENTARY

Address 2752 MOODY ROAD

Inspection date 2009-12-01

Notes -


Inspectors present

State No District Yes Local No

Ref	Code Violation	Bldg	Room	Comp date	Cited Notes
69A-58.1308	BLDG ADDRESS/I.D. NOT PRESENT/VISIBLE	6-	PERMANENT NA	2009-01-10	0 N/A
69A-58.1205	FIRE EVACUATION PLAN(S) NOT POSTED	7-	PERMANENT 706	2010-01-10	0 N/A
69A-58.1205	OPERATING FEATURES	8-	PERMANENT 803	2010-01-10	0 N/A
69A-58.1205	FIRE EVACUATION PLAN(S) NOT POSTED	8-	PERMANENT 807	2010-01-10	0 N/A
69A-58.204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE 11	2010-01-10	0 N/A
69A-58.807	OPEN ELECTRICAL JUNCTION BOX	92-	RELOCATABLE 14	2010-01-10	0 N/A
69A-58.807	ACCUMULATION OF COMBUSTIBLE MATERIALS	92-	RELOCATABLE 16	2010-01-10	0 EXCESSIVE PAPERWORK ON WALLS 20% MAX
69A-58.204	EMERG LIGHTS NOT OPERATIONAL	92-	RELOCATABLE 20	2010-01-10	0 N/A

Statements acknowledgedI hereby certify that the district has complied with section 1013.12(1) (b), F.S. **No**I hereby certify that the local authority having jurisdiction has complied with section 1013.12(2)(b), F.S. **No**I hereby certify that the required fire drills have been completed as of this inspection date. **No**

(Or)

Acknowledgement N/A. **No**

Primary inspector
Larry, SwansonAdditional inspector
N/A