


CILLEY SENIOR HIGH SCHOOL



FISCAL YEAR 2005-2006

FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12 & RULE 69A-58



ANNUAL PERMANENT BUILDING INSPECTION ANNUAL RELOCATABLE BUILDING INSPECTION
FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

TYPE OF INSPECTION

DISTRICT: CLAY FACILITY #: 0013

FACILITY: CLAY HIGH SCHOOL
2025 HIGHWAY 16 WEST
GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: SEPTEMBER 14, 2005

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 9-14-05

Building	Room	Deficiency Description and Corrective Action Required:	Maint "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	110	Storage in exit passage		X						FBC 423.20.1
1	132A	Ceiling grid hanging down; tiles missing	X	X						FBC 804.2.3
1	123	Equipment stored in exit; in landing		X						FBC 423.20.1
1	138	Missing emergency light	X							FBC 423.17.1
1	138	Missing extinguisher		X						FBC 423.7.3
1	138F	Emergency light not working		X						FBC 423.17.1
1	138A	Ceiling tiles missing		X						FBC 804.2.3
2	201	Emergency light not working		X						FBC 423.17.1
2	209A	Smoke detector hanging	X							FBC 423.7.7
2	209A	3 Panel covers missing	X							NFPA 70 312.5
2	209A	Panel knockouts missing	X							NFPA 70 312.5
2	215	Duplex outlet cover missing on column	X							NFPA 70 312.5
3	310A	Emergency light not working southend of hall		X						FBC 423.17.1
3	329	Electrical panel cover missing	X							NFPA 312.5

FISCAL YEAR 2005-2006

FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12 & RULE 69A-58



TYPE OF INSPECTION

ANNUAL PERMANENT BUILDING INSPECTION
 ANNUAL RELOCATABLE BUILDING INSPECTION
 FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0013

FACILITY: CLAY HIGH SCHOOL
 2025 HIGHWAY 16 WEST
 GREEN COVE SPRINGS, FLORIDA 32043

INSPECTION DATE: SEPTEMBER 14, 2005

INSPECTOR'S SIGNATURE: *[Signature]* DATE: 9.14.05

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
3	329	Storage in electrical room to be removed		X						NFPA 70 110-26
3	366	Fire panel cover missing over panel	X							NFPA 70 312.5
3	366A	Ceiling tile missing (2)		X						FBC 804.2.3
3	382	Emergency light not working (3 d. RR Boys)	X							FBC 423.17.1
5	510B	Extension cords (2 cords together)		X						NFPA 70 400-8
5	510A/B	Exit lights misleading (possibly remove)	X							FBC 1016.3.1
5	512	Two extension cords plugged together		X						NFPA 70 400-8
5	517A/B	Exit lights misleading (possibly need to remove)	X							FBC 1015.3.1
8	813	Fire extinguisher (K) missing		X						NFPA 1 13.6.6.7
8	830	Canvas backdrop needs to be removed		X						FBC 804.2.3
8	831	Emergency light hanging down (high ceiling)	X							FBC 423.17.1
11	1129	Panel cover missing electrical room	X							NFPA 70 312.5
11	1129	Panel cover missing in computer room				X				NFPA 70 312.5
33		Stadium handrails missing			X					NFPA 101 312.5.6.7

FISCAL YEAR 2005-2006

FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12 & RULE 69A-58



TYPE OF INSPECTION

ANNUAL PERMANENT BUILDING INSPECTION ANNUAL RELOCATABLE BUILDING INSPECTION
 FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 3

DISTRICT: CLAY FACILITY #: 0013

FACILITY: CLAY HIGH SCHOOL
2025 HIGHWAY 16 WEST
GREEN COVE SPRINGS, FLORIDA 32043


INSPECTION DATE: SEPTEMBER 14, 2005

Ed Sweeten
INSPECTOR'S SIGNATURE Sept 14, 2005
DATE

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	8	Fire extinguisher not signed		X						NFPA 1 7-6.4.1
92	8	Electric panel access blocked with table		X						NFPA 70 110-26
92	7	Replace non-skid on ramp	X							FBC 1013.9
	33	OK								

FLEMING ISLAND

SENIOR HIGH SCHOOL



FISCAL YEAR 2005-2006

**FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12 & RULE 69A-58**



TYPE OF INSPECTION

ANNUAL PERMANENT BUILDING INSPECTION
 ANNUAL RELOCATABLE BUILDING INSPECTION
 FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 1

DISTRICT: CLAY FACILITY #: 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL
2233 VILLAGE SQUARE PARKWAY
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: SEPTEMBER 23, 2005

INSPECTOR'S SIGNATURE: [Signature] DATE: Sept 23, 2005

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
1	272	Cover on "J" box above panel 2 BPH	X							NFPA 70 312.5
1	291	No emergency evacuation sheet		X						FBC 423.14.2.4
1	281	Material to close to ceiling		X						NFPA 13 - 13.8.5.5.3
1	302	Cover plate under window	X							NFPA 70 314.2
1	303	Surge protector's piggy backed		X						NFPA 70 527.2
1	306	Emergency evacuation missing		X						FBC 423.14.2.4
1	315	Entrance/exit door drags	X							NFPA 1 4&1.8.5
2	207	Light fixture broken	X							FBC 423
2	205	Light fixture broken	X							FBC
2	202	East side switch cover	X							NFPA 70 314.1
2	227	Ceiling tile missing		X						FBC 804.2.3
40	001	Excessive material stored		X						NFPA 4.4.3.1
40	001	Gas grill with LP tank in room		X						NFPA 1 21.3.3.5
40	001	LP tank in room		X						NFPA 1 21.3.3.5

FISCAL YEAR 2005-2006

FIRE SAFETY INSPECTION REPORT FOR EDUCATIONAL FACILITIES FLORIDA STATUTES 1013.12 & RULE 69A-58


TYPE OF INSPECTION

ANNUAL PERMANENT BUILDING INSPECTION ANNUAL RELOCATABLE BUILDING INSPECTION
FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 1

DISTRICT: CLAY FACILITY #: 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL
2233 VILLAGE SQUARE PARKWAY
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: SEPTEMBER 23, 2005

INSPECTOR'S SIGNATURE:  DATE: 9.23.05

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
40	001	Stadium hand rails		X						NFPA -1 12.2.5.6.7

FISCAL YEAR 2005-2006

FIRE SAFETY INSPECTION REPORT
FOR EDUCATIONAL FACILITIES
FLORIDA STATUTES 1013.12 & RULE 69A-58



DISTRICT: CLAY FACILITY #: 0044

FACILITY: FLEMING ISLAND HIGH SCHOOL
2233 VILLAGE SQUARE PARKWAY
ORANGE PARK, FLORIDA 32003

INSPECTION DATE: SEPTEMBER 23, 2005

INSPECTOR'S SIGNATURE _____
DATE 9-23-05

ANNUAL PERMANENT BUILDING INSPECTION ANNUAL RELOCATABLE BUILDING INSPECTION
FIRE DRILL LOG: NUMBER OF DRILLS PERFORMED: 1

TYPE OF INSPECTION

Building	Room	Deficiency Description and Corrective Action Required:	Maint. "M"	Oper. "O"	Fac. "C"	Info. Serv. "I.S."	Cost	No. of times Def. Cited	Scheduled for Correction	Rule
92	48	Emergency light out		X						FBC 423.17.1
92	80	Disconnect; wired improperly			X					NFPA 70.312.5